



Daylight and Sunlight

Cundy Street Quarter

Daylight and Sunlight Addendum

Prepared by: Jessica Rawlings

Reference: 13752

Date: 22/04/2021



By Email

Grosvenor Estate Belgravia
70 Grosvenor Street
London
W1K 3JP

To Whom It May Concern,

Re: The Cundy Street Quarter – Daylight and Sunlight Addendum

GIA have been instructed by Grosvenor Estate Belgravia (the Applicant) to provide daylight and sunlight advice in relation to the proposed redevelopment of the Cundy Street Quarter, Belgravia. Recommendations were made by Westminster Planning Committee which this letter sets out and seeks to address.

The scheme was heard at the WCC Planning (Major Applications) Sub-Committee on 16 February 2021. The decision was "to defer the application to allow for officers to discuss with Applicant the implications of reducing the height of Building A1 by a storey. The purpose of reducing the height of Building A1 being to reduce the levels of harm to the residential amenity of the neighbouring residents (with particular reference to daylight and sunlight gains). Following a substantial debate on this item the Committee generally considered the application to be acceptable in all other respects save for the identified harm caused by the height of Building A1".

This document sets out the proposed changes to Building A, and associated minor changes to Buildings B and C. These changes have resulted from an extensive period of review to the design and associated Daylight/Sunlight impact to neighbouring properties, as well as discussions with WCC officers and residents of Ebury Street/Mozart Terrace.

The main objective has been to propose a design change which would achieve a very similar level of Daylight/Sunlight benefit to removing the top floor of Building A1 but mitigating the loss of floor area and therefore the loss of Affordable Housing, meanwhile ensuring that the design architecturally responds to the design change and context.

An Addendum Daylight, Sunlight and Overshadowing Chapter of the Environmental Statement has also been prepared separately to this letter.

The Submitted Scheme

Figure 01 below illustrates the scheme submitted under the planning reference 20/03307/FULL which was considered at Westminster Planning Committee on 16th February 2021. Full drawings can be found in Appendix 01.

DATE / REF

•

22/04/2021

JR/13752

ADDRESS

•

THE WHITEHOUSE

BELVEDERE ROAD

LONDON SE1 8GA

•

CONTACT

•

TEL 020 7202 1400

FAX 020 7202 1401

MAIL@GIA.UK.COM

•

WWW.GIA.UK.COM




Figure 01 – the Submitted Scheme

The relevant Daylight and Sunlight results for the submitted scheme were summarised and reported on within the ES Chapter that was submitted as part of the planning submission, as well as the standalone Daylight and Sunlight report dated May 2020.

After considering the scheme as submitted, the Committee noted that they were minded to defer the application to allow for officers to discuss with Applicant the implications of reducing the height of Building A1 by a storey.

Fifth Floor removal Option

The Fifth Floor Removal Option provided by DSDHA removes the top floor from Building A1 of the Submitted Scheme, as suggested by the Planning Committee.

GIA's analysis of this scheme has looked at the potential daylight and sunlight alterations that may occur to all surrounding relevant residential properties, as per the reports on the Submitted Scheme. However, for the purposes of this letter, GIA have focused on the properties situated closest to Block A1 along Mozart Terrace, Ebury Street and Cundy Street which will have a view of the proposed massing changes. A full copy of the daylight and sunlight results can be found in Appendix 02.

Table 01 below provides details on the Vertical Sky Component ('VSC') results for those properties closest to the Fifth Floor Removal Option.

Vertical Sky Component						
	Window			Loss		
	Total	Pass	Comp.(%)	20%-30%	30%-40%	40%+
176 Mozart Terrace	13	7	53.8%	4	2	0
174 Mozart Terrace	10	2	20.0%	6	2	0
172 Mozart Terrace	18	2	11.1%	10	5	1
170 Mozart Terrace	6	2	33.3%	4	0	0
168 Mozart Terrace	13	8	61.5%	5	0	0
166 Mozart Terrace	12	8	66.7%	4	0	0
164 Mozart Terrace	12	11	91.7%	1	0	0
162 Mozart Terrace	10	10	100.0%	0	0	0
102 Eaton Terrace	32	32	100.0%	0	0	0
180 Mozart Terrace	9	1	11.1%	4	4	0
182 Mozart Terrace	8	4	50.0%	4	0	0
184 Mozart Terrace	11	11	100.0%	0	0	0
186 Mozart Terrace	7	7	100.0%	0	0	0
188 Mozart Terrace	10	10	100.0%	0	0	0
190 Ebury Street	4	4	100.0%	0	0	0
192 Ebury Street	5	5	100.0%	0	0	0
194 Ebury Street	5	5	100.0%	0	0	0
1 Ebury Square-Block A	85	70	82.4%	6	5	4
1 Ebury Square-Block B	277	240	86.6%	7	3	27

Table 01 – VSC compliance with baseline BRE

As detailed within the submitted daylight and sunlight report, a flexible interpretation of the BRE Guidelines and consideration of the local context must be taken into consideration.

This was accepted by Westminster Council who noted in their committee report that:

“For the purposes of the daylight assessment, officers have given weight to the suggested alternative 15% VSC retained value in assessing the impact of this proposed development. This is because of the importance of the development overall in achieving benefits which too are material considerations to be weighed in the balance. Properties that are affected by reduced daylight that see retained VSC values in the mid- teens are therefore considered to have a reasonable amount of daylight in the context of this particular development in this particular central urban location. This approach is supported by Policy D6 (D) of the Publication London Plan which sets out that the design of development should provide sufficient daylight and sunlight to new and surrounding housing that is appropriate for its context”.

Table 02 below therefore considers the total number of windows within the selection of properties that meet the alternative VSC target of 15% VSC:

	Submitted Scheme	Fifth Floor Removal Option	Difference
176 Mozart Terrace	7	7	0
174 Mozart Terrace	8	8	0
172 Mozart Terrace	15	15	0
170 Mozart Terrace	3	5	+2
168 Mozart Terrace	11	11	0
166 Mozart Terrace	9	9	0
164 Mozart Terrace	10	10	0
162 Mozart Terrace	8	9	+1
102 Eaton Terrace	24	24	0
180 Mozart Terrace	6	6	0
182 Mozart Terrace	6	6	0
184 Mozart Terrace	9	9	0
186 Mozart Terrace	6	6	0
188 Mozart Terrace	8	8	0
190 Ebury Street	4	4	0
192 Ebury Street	5	5	0
194 Ebury Street	5	5	0
1 Ebury Square-Block A	55	55	0
1 Ebury Square-Block B	192	192	0
Totals:	391	394	+3

Table 02 – Alternative target summary for VSC

In the baseline scenario, of the 547 windows assessed within the above 19 properties, 441 windows have VSC levels of 15% or greater (80.6%) For the submitted scheme, 391 windows of the total 547 assessed (71.5%) from the selection of properties noted meet the criteria of 15%. This increases to 394 (72%) when the top floor of Building A1 is removed.

When considering the room-based daylight assessment, the No Sky Line (NSL), against the baseline BRE criteria, the results are set out in Table 03 overleaf:

No Sky Line (Room)						
	Total	Pass	Comp.(%)	20%-30%	30%-40%	40%+
1 Ebury Square-Block A	53	48	90.6%	2	3	0
1 Ebury Square-Block B	142	133	93.7%	2	1	6
176 Mozart Terrace	9	1	11.1%	5	2	1
174 Mozart Terrace	7	0	0%	1	1	5
172 Mozart Terrace	9	1	11.1%	0	0	8
170 Mozart Terrace	4	0	0%	0	1	3
168 Mozart Terrace	8	0	0%	3	3	2
166 Mozart Terrace	5	2	40.0%	0	1	2
164 Mozart Terrace	8	4	50.0%	2	0	2
162 Mozart Terrace	4	2	50.0%	0	0	2
102 Eaton Terrace	17	13	76.5%	3	1	0
180 Mozart Terrace	5	0	0%	1	1	3
182 Mozart Terrace	4	2	50.0%	0	0	2
184 Mozart Terrace	6	1	16.7%	3	1	1
186 Mozart Terrace	4	0	0%	2	1	1
188 Mozart Terrace	6	6	100.0%	0	0	0
190 Ebury Street	4	4	100.0%	0	0	0
192 Ebury Street	2	2	100.0%	0	0	0
194 Ebury Street	3	3	100.0%	0	0	0

Table 03 – NSL compliance with baseline BRE

As noted within the submitted scheme daylight and sunlight report, the BRE Guidelines state that *‘where room layouts are known, the impact on the daylighting distribution in the existing building can be found by plotting the ‘no sky line’ in each of the main rooms.’* (P7, para 2.2.8).

Despite considerable effort to obtain accurate floorplans for all properties, this was not possible and therefore a number of rooms within surrounding properties are modelled on assumed dimensions. Whilst some of the NSL results are therefore on the basis of assumed room layouts, we have included the results of this room-based assessment regardless, as it is a helpful indicator of potential daylight amenity to the room as a whole. This should, however, be kept in mind when reviewing the results.

Based on the results shown within Table 03, there is an increase in the number of rooms showing compliance with the baseline BRE Guidelines from 216 rooms for the submitted scheme, to 222 rooms within the Fifth Floor removal option for these selected properties.

In relation to sunlight, the Annual Probable Sunlight Hours (APSH) methodology has been adopted, and the assessment against BRE baseline criteria is detailed for the relevant properties in table 04 below:

Annual Probable Sunlight Hours									
	Window			Annual			Winter		
	Total	Pass	Comp.(%)	20%-30%	30%-40%	40%+	20%-30%	30%-40%	40%+
1 Ebury Square-Block A	68	51	75.0%	2	1	6	0	0	17
1 Ebury Square-Block B	147	116	78.9%	5	0	16	0	0	29
176 Mozart Terrace	12	6	50.0%	0	2	1	0	0	6
174 Mozart Terrace	10	9	90.0%	0	1	0	0	0	1
172 Mozart Terrace	16	13	81.3%	0	0	3	0	0	3
170 Mozart Terrace	6	2	33.3%	1	0	2	0	0	4
168 Mozart Terrace	13	9	69.2%	1	0	1	1	0	2
166 Mozart Terrace	12	9	75.0%	0	1	1	0	1	2
164 Mozart Terrace	12	11	91.7%	0	0	1	0	0	1
162 Mozart Terrace	10	9	90.0%	1	0	0	0	0	1
102 Eaton Terrace	17	16	94.1%	0	0	0	0	0	1
180 Mozart Terrace	9	7	77.8%	0	1	1	0	0	2
182 Mozart Terrace	8	7	87.5%	0	1	0	0	0	0
184 Mozart Terrace	11	10	90.9%	0	0	0	0	1	0
186 Mozart Terrace	7	7	100.0%	0	0	0	0	0	0
188 Mozart Terrace	10	10	100.0%	0	0	0	0	0	0
190 Ebury Street	4	4	100.0%	0	0	0	0	0	0
192 Ebury Street	5	5	100.0%	0	0	0	0	0	0
194 Ebury Street	5	5	100.0%	0	0	0	0	0	0

Table 04 – APSH compliance with baseline BRE

Based on the results shown within Table 04, there is an increase in the number of windows showing compliance with the baseline BRE Guidelines from 294 windows for the submitted scheme, to 306 windows within the Fifth Floor removal option for these selected properties.

The New Proposal

The New Proposal provided to GIA by DSDHA is near identical in form to the Fifth Floor Removal Option but has re-provided the lost elements of massing from the removal of the top floor on Block A1 with stepped back massing.

Detailed information of the design changes made to Building A can be found in the Design & Access Statement. For Building A the following changes have been made:

- top floor of A1 substantially set back;
- adjusted mansard roof design;
- architectural changes to roof top of A1 and A2;
- Slab thickness reductions resulting in lower building height of 150mm;
- Extra set back floor on Cundy Street.

An image depicting this scheme is shown in figure 02 below:




Figure 02 – The New Proposal

Full technical analysis for all relevant neighbouring properties can be found within the appendices of this letter and within the other documents forming the amendment submission in respect of the New Proposal.

Therefore, for the purposes of this letter, comparisons will be drawn on those properties which are discussed above only, as they are the closest neighbours to the elements of massing which are being altered. A full copy of the daylight and sunlight results can be found in Appendix 02.

Table 05 below provides details on the Vertical Sky Component ('VSC') results for those properties closest for the New Proposal.

Vertical Sky Component						
	Window			Loss		
	Total	Pass	Comp.(%)	20%-30%	30%-40%	40%+
176 Mozart Terrace	13	7	53.8%	4	2	0
174 Mozart Terrace	10	4	40.0%	4	2	0
172 Mozart Terrace	18	2	11.1%	10	5	1
170 Mozart Terrace	6	3	50.0%	3	0	0
168 Mozart Terrace	13	9	69.2%	4	0	0
166 Mozart Terrace	12	8	66.7%	4	0	0
164 Mozart Terrace	12	11	91.7%	1	0	0
162 Mozart Terrace	10	10	100.0%	0	0	0
102 Eaton Terrace	32	32	100.0%	0	0	0
180 Mozart Terrace	9	2	22.2%	3	4	0

182 Mozart Terrace	8	4	50.0%	4	0	0
184 Mozart Terrace	11	11	100.0%	0	0	0
186 Mozart Terrace	7	7	100.0%	0	0	0
188 Mozart Terrace	10	10	100.0%	0	0	0
190 Ebury Street	4	4	100.0%	0	0	0
192 Ebury Street	5	5	100.0%	0	0	0
194 Ebury Street	5	5	100.0%	0	0	0
1 Ebury Square-Block A	85	70	82.4%	6	6	3
1 Ebury Square-Block B	277	240	86.6%	7	2	28

Table 05 – VSC compliance with baseline BRE

The table below considers the total number of windows within the selection of properties that meet the alternative VSC target of 15% VSC for the Submitted Scheme, Fifth Floor Removal Option and the New Proposal:

	Submitted Scheme	Fifth Floor Removal Option	New Proposal
176 Mozart Terrace	7	7	7
174 Mozart Terrace	8	8	8
172 Mozart Terrace	15	15	15
170 Mozart Terrace	3	5	5
168 Mozart Terrace	11	11	11
166 Mozart Terrace	9	9	9
164 Mozart Terrace	10	10	10
162 Mozart Terrace	8	9	9
102 Eaton Terrace	24	24	24
180 Mozart Terrace	6	6	6
182 Mozart Terrace	6	6	6
184 Mozart Terrace	9	9	9
186 Mozart Terrace	6	6	6
188 Mozart Terrace	8	8	8
190 Ebury Street	4	4	4
192 Ebury Street	5	5	5
194 Ebury Street	5	5	5
1 Ebury Square-Block A	55	55	55
1 Ebury Square-Block B	192	192	192
Totals:	391	394	394

Table 06 – Alternative target summary for VSC

Table 06 demonstrates that the same number of windows achieve a minimum of 15% VSC when comparing the Fifth Floor Removal Option and the New Proposal.

Of the 547 windows assessed within the above 19 key properties, 394 (72%) will continue to enjoy VSC levels of 15% or greater. Of the 153 windows which will experience retained VSC levels of less than 15%, the majority (147 windows) will experience either no change or a small improvement (0.1-03%) when comparing the Fifth Floor Removal Option with the New Proposal. The six remaining windows will retain 0.1% less VSC when comparing the New Proposal with the Fifth Floor Removal Option which is considered insignificant.

When considering the room-based daylight assessment, the No Sky Line (NSL) against the baseline BRE criteria, the results are set out in Table 07:

No Sky Line (Room)						
	Total	Pass	Comp.(%)	20%-30%	30%-40%	40%+
1 Ebury Square-Block A	53	48	90.6%	3	2	0
1 Ebury Square-Block B	142	133	93.7%	3	1	5
176 Mozart Terrace	9	1	11.1%	5	2	1
174 Mozart Terrace	7	0	0%	1	1	5
172 Mozart Terrace	9	1	11.1%	0	0	8
170 Mozart Terrace	4	0	0%	0	1	3
168 Mozart Terrace	8	0	0%	2	4	2
166 Mozart Terrace	5	2	40.0%	0	1	2
164 Mozart Terrace	8	4	50.0%	2	0	2
162 Mozart Terrace	4	2	50.0%	0	0	2
102 Eaton Terrace	17	13	76.5%	3	1	0
180 Mozart Terrace	5	0	0%	1	1	3
182 Mozart Terrace	4	2	50.0%	0	0	2
184 Mozart Terrace	6	1	16.7%	3	1	1
186 Mozart Terrace	4	0	0%	2	1	1
188 Mozart Terrace	6	6	100.0%	0	0	0
190 Ebury Street	4	4	100.0%	0	0	0
192 Ebury Street	2	2	100.0%	0	0	0
194 Ebury Street	3	3	100.0%	0	0	0

Table 07 – NSL compliance with baseline BRE

We would note that there is no change between the fifth floor removal scheme and the New Proposal in relation to the number of rooms achieving BRE compliance.

In relation to sunlight, the Annual Probable Sunlight Hours (APSH) methodology has been adopted, and the assessment against BRE baseline criteria is detailed for the relevant properties in table 08 below:

Annual Probable Sunlight Hours									
	Window			Annual			Winter		
	Total	Pass	Comp.(%)	20%-30%	30%-40%	40%+	20%-30%	30%-40%	40%+
1 Ebury Square-Block A	68	50	73.5%	3	1	6	0	0	18
1 Ebury Square-Block B	147	115	78.2%	6	0	16	0	0	29
176 Mozart Terrace	12	6	50.0%	0	1	1	0	0	6
174 Mozart Terrace	10	9	90.0%	0	1	0	0	0	1
172 Mozart Terrace	16	13	81.3%	0	0	3	0	0	3
170 Mozart Terrace	6	1	16.7%	1	0	2	0	0	5
168 Mozart Terrace	13	9	69.2%	1	0	1	1	0	2
166 Mozart Terrace	12	9	75.0%	0	1	1	0	1	2
164 Mozart Terrace	12	11	91.7%	0	0	1	0	0	1

162 Mozart Terrace	10	9	90.0%	1	0	0	0	0	1
102 Eaton Terrace	17	16	94.1%	0	0	0	0	0	1
180 Mozart Terrace	9	7	77.8%	0	1	1	0	0	2
182 Mozart Terrace	8	7	87.5%	0	1	0	0	0	0
184 Mozart Terrace	11	10	90.9%	0	0	0	0	1	0
186 Mozart Terrace	7	7	100.0%	0	0	0	0	0	0
188 Mozart Terrace	10	10	100.0%	0	0	0	0	0	0
190 Ebury Street	4	4	100.0%	0	0	0	0	0	0
192 Ebury Street	5	5	100.0%	0	0	0	0	0	0
194 Ebury Street	5	5	100.0%	0	0	0	0	0	0

Table 08 – APSH compliance with baseline BRE

We would note that there 306 windows within the selected properties meet the baseline BRE guidelines for APSH for the Fifth Floor removal option, with 303 windows meeting the baseline BRE Guidelines for the New Proposal.

This is due to a single window in the following three properties showing a transgression from the baseline BRE guidelines for the New Proposal – each of 1 Ebury Square Block A, B and 170 Mozart Terrace.

Summary

GIA has worked closely with the architect, wider design team and the Applicant to seek an alternative scheme to the Committee's suggestion of removing the top floor of Building A1.

The new proposal provides a very similar level of Daylight/Sunlight benefit to removing the top floor of Building A1 (Fifth Floor Removal Option) but mitigating the loss of floor area and therefore the loss of Affordable Housing, meanwhile ensuring that the design architecturally responds to the design change and context.

Based on the BRE summaries and the accepted alternative target for VSC detailed within this report, we can confirm that the New Proposal demonstrates the same/materially similar improvements to those seen with the Fifth Floor Removal Option, with the exact same number of windows continuing to achieve 15% or greater VSC.

Where 15% VSC is not achieved, there is generally no difference in the retained VSC levels between the Fifth Floor Removal Option and the New Proposal, or a very small improvement of 0.1-0.3%. In the very limited incidences where a window does not retain 15% VSC or greater and has a lower retained VSC level with the New Proposal, the difference does not exceed 0.1%.

Materially similar results can also be seen for the NSL and APSH assessments when comparing the Fifth Floor Removal Option and the New Proposal.

Yours faithfully,
For and on behalf of GIA



Jessica Rawlings
Associate Partner
jessica.rawlings@gia.uk.com


Cc. Elliot Hathaway - GIA

Encl. Appendix 01 – Submitted Scheme and New Proposal Drawings
Appendix 02 – Daylight and Sunlight Results

N.B This letter has been prepared for 'Grosvenor' by GIA as their appointed Daylight & Sunlight consultants. It is accurate as at the time of publication and based upon the information we have been provided with as set out in the letter. It does not take into account changes that have taken place since the letter was written nor does it take into account private information on internal layouts and room uses of adjoining properties unless this information is publicly available.

APPENDIX 01

DRAWINGS



SOURCES OF INFORMATION

GROSVENOR
IR02-290518
CUNDY STREET Model B Issue 22-12-17.dwg

VERTEX
IR03-030718
13752_Belgravia_Estate_Cundy_Street_MASTER.dwg

NOTES:
PROPOSED SCHEME SHOWN IN TEAL

N.B. DO NOT SCALE OFF THIS DRAWING

PROJECT:
BELGRAVIA ESTATE


DRAWING NAME:
PLAN VIEW PROPOSED
PROPOSED IR39
06.03.2020

DWN BY	SCALE	CHK BY	DATE	REV No.
EVVE	1:8500A3	CRC	MAR.20	A
PROJ No.	REL No.	ADDR No.	IS No.	DWG No.
13752	09	-	03	01



The Whitehouse
Belvedere Road
London SE1 8GA
t 020 7202 1400
f 020 7202 1401
mail@gia.uk.com
www.gia.uk.com

L O N D O N • M A N C H E S T E R



3D VIEW
NTS

SOURCES OF INFORMATION

GROSVENOR
IR02-290518
CUNDY STREET Model B Issue 22-12-17.dwg

VERTEX
IR03-030718
13752_Belgravia_Estate_Cundy_Street_MASTER.dwg

NOTES:
PROPOSED SCHEME SHOWN IN TEAL
ALL HEIGHTS AND DIMENSIONS GIVEN IN m AOD

N.B. DO NOT SCALE OFF THIS DRAWING

PROJECT:
BELGRAVIA ESTATE


DRAWING NAME:
3D VIEW PROPOSED
PROPOSED IR39
06.03.2020

DWN BY	SCALE	CHK BY	DATE	REV No.
EVVE	NTS	CRC	MAR.20	A
PROJ No.	REL No.	ADDR No.	IS No.	DWG No.
13752	09	-	03	02



The Whitehouse
Belvedere Road
London SE1 8GA
t 020 7202 1400
f 020 7202 1401
mail@gia.uk.com
www.gia.uk.com

L O N D O N • M A N C H E S T E R



3D VIEW
NTS

SOURCES OF INFORMATION

GROSVENOR
IR02-290518
CUNDY STREET Model B Issue 22-12-17.dwg

VERTEX
IR03-030718
13752_Belgravia_Estate_Cundy_Street_MASTER.dwg

NOTES:
PROPOSED SCHEME SHOWN IN TEAL
ALL HEIGHTS AND DIMENSIONS GIVEN IN m AOD

N.B. DO NOT SCALE OFF THIS DRAWING

PROJECT:
BELGRAVIA ESTATE

DRAWING NAME:
3D VIEW PROPOSED
PROPOSED IR39
06.03.2020


DWN BY	SCALE	CHK BY	DATE	REV No.
EVVE	NTS	CRC	MAR.20	A
PROJ No.	REL No.	ADDR No.	IS No.	DWG No.
13752	09	-	03	03



The Whitehouse
Belvedere Road
London SE1 8GA
t 020 7202 1400
f 020 7202 1401
mail@gia.uk.com
www.gia.uk.com

L O N D O N • M A N C H E S T E R

DSDHA ADDENDUM SCHEME



SOURCES OF INFORMATION

GROSVENOR
IR02 - 290518
CUNDY STREET Model B Issue 22-12-17.dwg

VERTEX
IR03-030718
13752_Belgravia_Estate_Cundy_Street_MASTER.dwg

NOTES:
PROPOSED SCHEME SHOWN IN TEAL

N.B. DO NOT SCALE OFF THIS DRAWING

PROJECT:
BELGRAVIA ESTATE


DRAWING NAME:
PLAN VIEW PROPOSED
PROPOSED IR54
RECEIVED 07.04.2021

DWN BY	SCALE	CHK BY	DATE	REV No.
EVVE	1:850@A3		APR.21	A
PROJ No.	REL No.	ADDR No.	IS No.	DWG No.
13752	24	-	01	01



The Whitehouse
Belvedere Road
London SE1 8GA
t 020 7202 1400
f 020 7202 1401
mail@gia.uk.com
www.gia.uk.com

L O N D O N · M A N C H E S T E R



SOURCES OF INFORMATION

GROSVENOR
IR02 - 290518
CUNDY STREET Model B Issue 22-12-17.dwg

VERTEX
IR03-030718
13752_Belgravia_Estate_Cundy_Street_MASTER.dwg

NOTES:
PROPOSED SCHEME SHOWN IN TEAL
ALL HEIGHTS AND DIMENSIONS GIVEN IN m AOD

N.B. DO NOT SCALE OFF THIS DRAWING


PROJECT:
BELGRAVIA ESTATE

DRAWING NAME:
3D VIEW PROPOSED
PROPOSED IR54
RECEIVED 07.04.2021

DWN BY	SCALE	CHK BY	DATE	REV No.
EVVE	NTS		APR.21	A
PROJ No.	REL No.	ADDR No.	IS No.	DWG No.
13752	24	-	01	02

gia
L O N D O N · M A N C H E S T E R

The Whitehouse
Belvedere Road
London SE1 8GA
t 020 7202 1400
f 020 7202 1401
mail@gia.uk.com
www.gia.uk.com



3D VIEW
NTS

SOURCES OF INFORMATION

GROSVENOR
IR02 - 290518
CUNDY STREET Model B Issue 22-12-17.dwg

VERTEX
IR03-030718
13752_Belgravia_Estate_Cundy_Street_MASTER.dwg

NOTES:
PROPOSED SCHEME SHOWN IN TEAL
ALL HEIGHTS AND DIMENSIONS GIVEN IN m AOD

N.B. DO NOT SCALE OFF THIS DRAWING

PROJECT:
BELGRAVIA ESTATE

DRAWING NAME:
3D VIEW PROPOSED
PROPOSED IR54
RECEIVED 07.04.2021

DWN BY	SCALE	CHK BY	DATE	REV No.
EVVE	NTS		APR.21	A
PROJ No.	REL No.	ADDR No.	IS No.	DWG No.
13752	24	-	01	03



The Whitehouse
Belvedere Road
London SE1 8GA
t 020 7202 1400
f 020 7202 1401
mail@gia.uk.com
www.gia.uk.com

L O N D O N · M A N C H E S T E R

DAYLIGHT AND SUNLIGHT RESULTS

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK A																			
F00	R1	RESIDENTIAL	LIVING ROOM		W1/F00	22.6	22.6	0	0.0%	98.8	98.4	0.2	0.4%	12	1	11	0	8.3%	100.0%
			LIVING ROOM		W2/F00	15.8	15.8	0	0.0%					11	2	10	1	81%	50.0%
			LIVING ROOM		W3/F00	16.7	16.6	0.1	0.6%					21	3	20	3	4.8%	0.0%
			LIVING ROOM		W4/F00	24.5	12.7	11.8	48.2%					48	6	24	0	50.0%	100.0%
	R2	RESIDENTIAL	KITCHEN-DINING		W5/F00	21.4	9.4	12	56.1%	90.1	60.6	13.6	32.7%	48	8	18	0	62.5%	100.0%
			KITCHEN-DINING		W6/F00	15.6	9.8	5.8	37.2%					30	8	11	0	63.3%	100.0%
			KITCHEN-DINING		W7/F00	13.6	9.3	4.3	31.6%					26	7	10	0	61.5%	100.0%
	R3	RESIDENTIAL	BEDROOM		W8/F00	10.4	9.1	1.3	12.5%	44.1	44.1	0.0	0.0%	21	6	15	0	28.6%	100.0%
	R4	RESIDENTIAL	BEDROOM		W9/F00	10.1	9.3	0.8	7.9%	31.5	30.7	0.2	2.3%	19	5	15	1	21.1%	80.0%
	R5	RESIDENTIAL	BEDROOM		W10/F00	10.2	9.9	0.3	2.9%	43.8	43.8	0.0	0.0%	20	5	18	3	10.0%	40.0%
	R6	RESIDENTIAL	BEDROOM		W11/F00	10.3	10.2	0.1	1.0%	35.7	35.7	0.0	0.0%	19	5	17	3	10.5%	40.0%
			BEDROOM		W12/F00	10.5	10.4	0.1	1.0%					18	4	17	3	5.6%	25.0%
	R7	RESIDENTIAL	BEDROOM		W13/F00	13.2	13.1	0.1	0.8%	63.5	63.5	0.0	0.0%	22	5	20	3	9.1%	40.0%
	R8	RESIDENTIAL	BEDROOM		W14/F00	15.1	15.1	0	0.0%	69.4	69.4	0.0	0.0%	26	5	25	4	3.8%	20.0%
F01	R1	RESIDENTIAL	LKD		W1/F01	29.2	29.2	0	0.0%	99.2	99.2	0.0	0.0%	29	5	28	4	3.4%	20.0%
			LKD		W2/F01	29.9	29.9	0	0.0%					29		28	1	3.3%	20.0%
			LKD		W3/F01	30.5	30.4	0.1	0.3%					28	5	27	4	3.6%	20.0%
			LKD		W4/F01	27.2	15.9	11.3	41.5%					62	13	35	1	43.5%	92.3%
	R2	RESIDENTIAL	BEDROOM		W5/F01	24.4	12.5	11.9	48.8%	94.3	71.2	6.1	24.5%	57	9	28	0	50.9%	100.0%
			BEDROOM		W6/F01	17.8	11.9	5.9	33.1%					32	8	15	0	53.1%	100.0%
	R3	RESIDENTIAL	BEDROOM		W7/F01	15.8	11.4	4.4	27.8%	71.1	45.2	4.0	36.4%	29	8	16	0	44.8%	100.0%
	R4	RESIDENTIAL	BEDROOM		W8/F01	12.7	11.1	1.6	12.6%	30.3	30.3	0.0	0.0%	24	7	19	2	20.8%	71.4%
	R5	RESIDENTIAL	BEDROOM		W9/F01	12.3	11.2	1.1	8.9%	23.2	23.2	0.0	0.0%	22	6	18	2	18.2%	66.7%
	R6	RESIDENTIAL	BEDROOM		W10/F01	12	11.3	0.7	5.8%	23.5	23.5	0.0	0.0%	23	6	20	3	13.0%	50.0%
	R7	RESIDENTIAL	BEDROOM		W11/F01	11.9	11.4	0.5	4.2%	31.6	31.6	0.0	0.0%	22	6	20	4	9.1%	33.3%
	R8	RESIDENTIAL	BEDROOM		W12/F01	12.1	11.9	0.2	1.7%	31.4	31.4	0.0	0.0%	22	7	20	5	9.1%	28.6%
	R9	RESIDENTIAL	BEDROOM		W13/F01	12.3	12.1	0.2	1.6%	23.9	23.9	0.0	0.0%	23	7	21	5	8.7%	28.6%
	R10	RESIDENTIAL	BEDROOM		W14/F01	12.5	12.3	0.2	1.6%	23.7	23.7	0.0	0.0%	21	6	20	5	4.8%	16.7%
	R11	RESIDENTIAL	BEDROOM		W15/F01	12.8	12.7	0.1	0.8%	31.9	31.9	0.0	0.0%	22	6	21	5	4.5%	16.7%
	R12	RESIDENTIAL	BEDROOM		W16/F01	15.1	15	0.1	0.7%	59	59	0.0	0.0%	25	6	25	6	0.0%	0.0%
	R13	RESIDENTIAL	BEDROOM		W17/F01	17	17	0	0.0%	59.6	59.6	0.0	0.0%	28	6	28	6	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK A (CONTINUED)																			
F02	R1	RESIDENTIAL	LKD		W1/F02	31.7	31.7	0	0.0%	99.2	99.2	0.0	0.0%	31	3	30	3	3.2%	16.7%
			LKD		W2/F02	32.4	32.3	0.1	0.3%					31	3	30	3	3.2%	16.7%
			LKD		W3/F02	33	32.9	0.1	0.3%					31	3	30	3	3.2%	16.7%
			LKD		W4/F02	29.9	19.6	10.3	34.4%					65	15	46	2	29.2%	86.7%
	R2	RESIDENTIAL	BEDROOM		W5/F02	27.3	16.2	11.1	40.7%	94.9	76.6	4.8	19.3%	64	14	39	0	39.1%	100.0%
			BEDROOM		W6/F02	20.4	14.5	5.9	28.9%					37	12	22	0	40.5%	100.0%
	R3	RESIDENTIAL	BEDROOM		W7/F02	18.4	14.1	4.3	23.4%	73.2	51.8	3.3	29.2%	35	13	22	1	37.1%	92.3%
	R4	RESIDENTIAL	BEDROOM		W8/F02	15.2	13.7	1.5	9.9%	34.7	34.7	0.0	0.0%	27	8	23	4	14.8%	50.0%
	R5	RESIDENTIAL	BEDROOM		W9/F02	14.8	13.7	1.1	7.4%	26.5	26.5	0.0	0.0%	28	8	25	5	10.7%	37.5%
	R6	RESIDENTIAL	BEDROOM		W10/F02	14.5	13.7	0.8	5.5%	26.7	26.7	0.0	0.0%	27	8	25	6	7.4%	25.0%
	R7	RESIDENTIAL	BEDROOM		W11/F02	14.4	13.8	0.6	4.2%	36.3	36.3	0.0	0.0%	26	7	24	5	7.7%	28.6%
	R8	RESIDENTIAL	BEDROOM		W12/F02	14.5	14.3	0.2	1.4%	36.3	36.3	0.0	0.0%	26	7	24	5	7.7%	28.6%
	R9	RESIDENTIAL	BEDROOM		W13/F02	14.7	14.5	0.2	1.4%	27.6	27.6	0.0	0.0%	26	7	25	6	3.8%	14.3%
	R10	RESIDENTIAL	BEDROOM		W14/F02	14.9	14.7	0.2	1.3%	27.4	27.4	0.0	0.0%	27	6	27	6	0.0%	0.0%
	R11	RESIDENTIAL	BEDROOM		W15/F02	15.2	15.1	0.1	0.7%	37.1	37.1	0.0	0.0%	26	6	26	6	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W16/F02	17.5	17.4	0.1	0.6%	65.8	65.8	0.0	0.0%	31	6	31	6	0.0%	0.0%
	R13	RESIDENTIAL	BEDROOM		W17/F02	19.3	19.2	0.1	0.5%	66.2	66.2	0.0	0.0%	33	6	33	6	0.0%	0.0%
F03	R1	RESIDENTIAL	LKD		W1/F03	34.1	34	0.1	0.3%	99.4	99.2	0.1	0.2%	32	7	31	6	3.1%	14.3%
			LKD		W2/F03	34.7	34.7	0	0.0%					32	7	31	6	3.1%	14.3%
			LKD		W3/F03	35.3	35.3	0	0.0%					32	7	31	6	3.1%	14.3%
			LKD		W4/F03	32.9	24.4	8.5	25.8%					70	20	55	6	21.4%	70.0%
	R2	RESIDENTIAL	BEDROOM		W5/F03	30.7	21	9.7	31.6%	96.1	88.5	2.0	7.9%	67	17	47	1	29.9%	94.1%
			BEDROOM		W6/F03	23.6	17.8	5.8	24.6%					43	16	28	1	34.9%	93.8%
	R3	RESIDENTIAL	BEDROOM		W7/F03	21.7	17.4	4.3	19.8%	78.9	62	2.6	21.5%	39	14	28	3	28.2%	78.6%
	R4	RESIDENTIAL	BEDROOM		W8/F03	18.4	16.9	1.5	8.2%	42.9	42.9	0.0	0.0%	34	11	30	7	11.8%	36.4%
	R5	RESIDENTIAL	BEDROOM		W9/F03	18	16.8	1.2	6.7%	32.5	32.5	0.0	0.0%	33	10	30	7	9.1%	30.0%
	R6	RESIDENTIAL	BEDROOM		W10/F03	17.6	16.8	0.8	4.5%	32.4	32.4	0.0	0.0%	32	10	29	7	9.4%	30.0%
	R7	RESIDENTIAL	BEDROOM		W11/F03	17.5	16.8	0.7	4.0%	43.9	43.9	0.0	0.0%	32	10	30	8	6.3%	20.0%
	R8	RESIDENTIAL	BEDROOM		W12/F03	17.6	17.2	0.4	2.3%	45.1	45.1	0.0	0.0%	31	8	30	7	3.2%	12.5%
	R9	RESIDENTIAL	BEDROOM		W13/F03	17.7	17.5	0.2	1.1%	34.1	34.1	0.0	0.0%	32	8	31	7	3.1%	12.5%
	R10	RESIDENTIAL	BEDROOM		W14/F03	18	17.8	0.2	1.1%	35	35	0.0	0.0%	33	9	32	8	3.0%	11.1%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK A (CONTINUED)

	R11	RESIDENTIAL	BEDROOM		W15/F03	18.3	18.1	0.2	11%	46.5	46.5	0.0	0.0%	31	8	30	7	3.2%	12.5%
	R12	RESIDENTIAL	BEDROOM		W16/F03	20.4	20.3	0.1	0.5%	76.4	76.4	0.0	0.0%	39	8	38	7	2.6%	12.5%
	R13	RESIDENTIAL	BEDROOM		W17/F03	22	21.9	0.1	0.5%	71.1	71.1	0.0	0.0%	41	8	40	7	2.4%	12.5%
F04	R1	RESIDENTIAL	LKD		W3/F04	36.3	31.2	5.1	14.0%	99	99	0.0	0.0%	78	26	69	17	11.5%	34.6%
			LKD		W4/F04	35.7	29.7	6	16.8%					77	25	65	13	15.6%	48.0%
			LKD		W5/F04	34.9	28	6.9	19.8%					75	25	61	11	18.7%	56.0%
			LKD		W6/F04	28.8	23.7	5.1	17.7%					55	20	45	10	18.2%	50.0%
			LKD		W7/F04	26.7	22.5	4.2	15.7%					54	20	45	11	16.7%	45.0%
	R2	RESIDENTIAL	BEDROOM		W8/F04	24.4	22.6	1.8	7.4%	83.1	82.4	0.1	0.8%	45	13	40	8	11.1%	38.5%
			BEDROOM		W9/F04	24.4	22.9	1.5	6.1%					46	13	43	10	6.5%	23.1%
	R3	RESIDENTIAL	LKD		W1/F04	33.6	33.6	0	0.0%	99.6	99.6	0.0	0.0%	30	7	30	7	0.0%	0.0%
			LKD		W2/F04	34	34	0	0.0%					30	7	30	7	0.0%	0.0%
			LKD		W10/F04	23.9	22.8	1.1	4.6%					48	15	45	12	6.3%	20.0%
			LKD		W11/F04	23.1	22.1	1	4.3%					47	14	44	11	6.4%	21.4%
	R4	RESIDENTIAL	BEDROOM		W12/F04	22.8	22.4	0.4	1.8%	74.1	74.1	0.0	0.0%	39	9	38	8	2.6%	11.1%
			BEDROOM		W13/F04	23	22.6	0.4	1.7%					44	10	43	9	2.3%	10.0%
	R5	RESIDENTIAL	BEDROOM		W14/F04	23.6	23.6	0	0.0%	84.6	84.6	0.0	0.0%	46	12	45	11	2.2%	8.3%
			BEDROOM		W15/F04	23.4	23.2	0.2	0.9%					47	13	45	11	4.3%	15.4%
	R6	RESIDENTIAL	LKD		W16/F04	25.2	25.1	0.1	0.4%	98.9	98.9	0.0	0.0%	43	8	43	8	0.0%	0.0%
			LKD		W17/F04	26.9	26.8	0.1	0.4%					53	12	52	11	1.9%	8.3%
			LKD		W18/F04	37.4	37.4	0	0.0%					17	2	17	2	0.0%	0.0%
			LKD		W19/F04	37.8	37.8	0	0.0%					18	2	18	2	0.0%	0.0%
			LKD		W20/F04	38.1	38.1	0	0.0%					20	2	20	2	0.0%	0.0%

1 EBURY SQUARE-BLOCK B

F00	R1	RESIDENTIAL	RECEPTION		W1/F00	0.4	0.4	0	0.0%	43.3	41.4	6.6	4.5%	0	0	0	0	0.0%	0.0%
			RECEPTION		W2/F00	0.5	0.5	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W3/F00	0.6	0.6	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W4/F00	0.7	0.7	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W5/F00	0.7	0.7	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W15/F00	9.9	9.9	0	0.0%					19	7	19	7	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			RECEPTION		W16/F00	11	9.8	1.2	10.9%					25	12	20	7	20.0%	41.7%
	R2	RESIDENTIAL	BEDROOM		W6/F00	0.3	0	0.3	100.0%	29.3	15.5	2.3	47.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W7/F00	0	0	0	-	12.3	12.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4 (3)	RESIDENTIAL	LIVING ROOM		W8/F00	1.3	0.1	1.2	92.3%	33.8	19.7	6.5	41.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R7 (3)	RESIDENTIAL	LIVING ROOM		W12/F00	12.4	10	2.4	19.4%	85.4	84.7	0.5	0.9%	28	6	23	2	17.9%	66.7%
	R8 (3)	RESIDENTIAL	LIVING ROOM		W13/F00	13.5	11.2	2.3	17.0%	97.6	96.1	0.8	1.5%	29	7	25	4	13.8%	42.9%
	R9 (3)	RESIDENTIAL	LIVING ROOM		W14/F00	14.1	12	2.1	14.9%	97.5	97.4	0.0	0.1%	28	9	24	5	14.3%	44.4%
	R10 (3)	RESIDENTIAL	LIVING ROOM		W17/F00	14.1	13.2	0.9	6.4%	99.9	99.9	0.0	0.0%	31	12	27	8	12.9%	33.3%
	R11 (3)	RESIDENTIAL	LIVING ROOM		W18/F00	13.6	13	0.6	4.4%	98.4	98.4	0.0	0.1%	30	12	29	11	3.3%	8.3%
	R12 (3)	RESIDENTIAL	LIVING ROOM		W19/F00	12.9	12.6	0.3	2.3%	96.4	96.3	0.0	0.1%	27	13	26	12	3.7%	7.7%
F01	R1	RESIDENTIAL	LKD		W1/F01	25.4	25.3	0.1	0.4%	91	91	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F01	22	22	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F01	20.3	20.3	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F01	19.4	19.4	0	0.0%	35.6	35.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F01	18.4	18.4	0	0.0%	28.6	28.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F01	17.5	17.5	0	0.0%	35.2	35.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F01	17.3	17.2	0.1	0.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F01	1.4	1.4	0	0.0%	3.6	3.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F01	1.3	1.3	0	0.0%	3.7	3.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F01	16.9	16.7	0.2	1.2%	34.7	33	0.4	4.7%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F01	16.9	16.6	0.3	1.8%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F01	17.5	16.8	0.7	4.0%	26.9	25.8	0.3	4.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F01	18	16.7	1.3	7.2%	28.6	26.4	0.6	7.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F01	18.4	16.4	2	10.9%	75.1	59.7	3.6	20.5%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F01	19.4	16.7	2.7	13.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F01	21.5	17.8	3.7	17.2%	95.4	71.8	10.3	24.8%	17	5	3	0	92.4%	10%
			BEDROOM		W17/F01	23.5	6.9	16.6	70.6%					54	14	11	0	79.6%	100.0%
			BEDROOM		W18/F01	24.7	6.6	18.1	73.3%					58	16	9	0	84.5%	100.0%
	R14	RESIDENTIAL	BEDROOM		W21/F01	24.2	6	18.2	75.2%	73.7	7.3	12.9	90.0%	55	11	10	0	81.8%	100.0%
	R15	RESIDENTIAL	LKD		W22/F01	22.7	5.9	16.8	74.0%	77.7	77	0.9	0.8%	52	9	11	1	78.8%	88.9%
			LKD		W23/F01	11.3	8.7	2.6	23.0%					24	6	18	2	25.0%	66.7%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			LKD		W24/F01	4.8	0.8	4	83.3%					20	8	10	1	50.0%	87.5%
			LKD		W25/F01	30.2	24.2	6	19.9%					55	11	39	5	29.1%	54.5%
			LKD		W26/F01	30.1	24.7	5.4	17.9%					54	13	40	5	25.9%	61.5%
			LKD		W27/F01	31	26.1	4.9	15.8%					54	13	42	5	22.2%	61.5%
	R16	RESIDENTIAL	BEDROOM		W28/F01	12.6	11.3	1.3	10.3%	57.9	54.9	1.0	5.2%	26	8	23	5	11.5%	37.5%
	R17	RESIDENTIAL	LKD		W29/F01	31.3	27.5	3.8	12.1%	85.2	85	0.2	0.2%	59	19	46	8	22.0%	57.9%
			LKD		W30/F01	31.3	27.9	3.4	10.9%					59	19	49	10	16.9%	47.4%
			LKD		W31/F01	5.2	5.2	0	0.0%					14	1	14	1	0.0%	0.0%
			LKD		W32/F01	13.2	12.5	0.7	5.3%					26	8	25	7	3.8%	12.5%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F01	12.9	12.8	0.1	0.8%	97.2	97.2	0.0	0.0%	27	9	26	8	3.7%	11.1%
	R19	RESIDENTIAL	BEDROOM		W34/F01	30.8	28.5	2.3	7.5%	99.1	99.1	0.0	0.0%	62	22	52	12	16.1%	45.5%
	R21	RESIDENTIAL	LKD		W35/F01	30.5	28.4	2.1	6.9%	84.5	84.5	0.0	0.0%	62	22	54	14	12.9%	36.4%
			LKD		W36/F01	12.7	12.7	0	0.0%					27	9	27	9	0.0%	0.0%
	R22 (3)	RESIDENTIAL	LKD		W37/F01	29.3	27.8	1.5	5.1%	85.1	85.1	0.0	0.0%	61	21	55	15	9.8%	28.6%
			LKD		W38/F01	27.5	26.5	1	3.6%					51	17	49	15	3.9%	11.8%
	R23	RESIDENTIAL	BEDROOM		W39/F01	27.7	26.5	1.2	4.3%	92.9	92.9	0.0	0.0%	55	20	50	15	9.1%	25.0%
			BEDROOM		W40/F01	1.9	1.9	0	0.0%					0	0	0	0	0.0%	0.0%
			BEDROOM		W41/F01	11.4	11.4	0	0.0%					22	9	22	9	0.0%	0.0%
F02	R1	RESIDENTIAL	LKD		W1/F02	28.2	28.2	0	0.0%	92.8	92.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F02	25.4	25.4	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F02	24	24	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F02	23.3	23.3	0	0.0%	43.4	43.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F02	22.5	22.4	0.1	0.4%	36.9	36.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F02	21.8	21.7	0.1	0.5%	49.1	49.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F02	21.5	21.5	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F02	4.1	4.1	0	0.0%	12	12	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F02	4	4	0	0.0%	11.1	11.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F02	21.2	21	0.2	0.9%	48.6	48.3	0.1	0.7%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F02	21.3	21	0.3	1.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F02	21.7	21.1	0.6	2.8%	35.2	35.2	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F02	22.2	21	1.2	5.4%	35.8	35.8	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R10	RESIDENTIAL	BEDROOM		W14/F02	22.5	20.8	1.7	7.6%	84	74	2.3	11.9%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F02	23.4	21	2.4	10.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F02	25.2	21.7	3.5	13.9%	96.6	75.8	9.1	21.6%	18	0	8	0	55.6%	0.0%
			BEDROOM		W17/F02	26.4	9.1	17.3	65.5%					61	16	17	0	72.1%	100.0%
			BEDROOM		W18/F02	27.5	8.6	18.9	68.7%					64	17	15	0	76.6%	100.0%
	R14	RESIDENTIAL	BEDROOM		W21/F02	27.2	7.7	19.5	71.7%	77.7	10.6	13.0	86.4%	64	15	14	1	78.1%	93.3%
	R15	RESIDENTIAL	LKD		W22/F02	26	7.5	18.5	71.2%	84.4	83.3	1.5	1.3%	64	14	13	1	79.7%	92.9%
			LKD		W23/F02	12.6	9.4	3.2	25.4%					26	8	20	3	23.1%	62.5%
			LKD		W24/F02	6	1	5	83.3%					23	11	10	1	56.5%	90.9%
			LKD		W25/F02	32.3	25.7	6.6	20.4%					60	16	41	6	31.7%	62.5%
			LKD		W26/F02	31.2	25.3	5.9	18.9%					57	18	41	6	28.1%	66.7%
			LKD		W27/F02	32.8	27.6	5.2	15.9%					61	19	47	8	23.0%	57.9%
	R16	RESIDENTIAL	BEDROOM		W28/F02	13.6	12.2	1.4	10.3%	63.5	60.7	0.9	4.4%	27	9	24	6	11.1%	33.3%
	R17	RESIDENTIAL	LKD		W29/F02	33	29	4	12.1%	91.8	91.3	0.4	0.4%	63	21	51	10	19.0%	52.4%
			LKD		W30/F02	33	29.4	3.6	10.9%					63	22	52	11	17.5%	50.0%
			LKD		W31/F02	5.6	5.6	0	0.0%					13				0.0%	0.0%
			LKD		W32/F02	14.1	13.4	0.7	5.0%					27	9	26	8	3.7%	11.1%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F02	13.8	13.6	0.2	1.4%	97.4	97.4	0.0	0.0%	27	9	26	8	3.7%	11.1%
	R19	RESIDENTIAL	BEDROOM		W34/F02	32.3	30	2.3	7.1%	99.2	99.2	0.0	0.0%	62	22	54	14	12.9%	36.4%
	R20	RESIDENTIAL	LKD		W35/F02	31.9	29.9	2	6.3%	87.3	87.2	0.0	0.0%	62	22	55	15	11.3%	31.8%
			LKD		W36/F02	13.6	13.6	0	0.0%					27	9	27	9	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F02	30.8	29.3	1.5	4.9%	92.9	92.7	0.1	0.2%	62	22	57	17	8.1%	22.7%
			LKD		W38/F02	27.6	26.6	1	3.6%					51	17	49	15	3.9%	11.8%
	R22	RESIDENTIAL	BEDROOM		W39/F02	29.1	27.9	1.2	4.1%	93.2	93.2	0.0	0.0%	57	20	52	15	8.8%	25.0%
			BEDROOM		W40/F02	2.3	2.3	0	0.0%					12	2	12	2	0.0%	0.0%
			BEDROOM		W41/F02	12.1	12.1	0	0.0%					22	9	22	9	0.0%	0.0%
F03	R1	RESIDENTIAL	LKD		W1/F03	31.6	31.6	0	0.0%	97	97	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F03	29.5	29.5	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F03	28.5	28.5	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F03	28.1	28.1	0	0.0%	64.9	64.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F03	27.5	27.5	0	0.0%	56.5	56.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R4	RESIDENTIAL	BEDROOM		W6/F03	26.8	26.8	0	0.0%	78.4	78.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F03	26.7	26.6	0.1	0.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F03	7.2	7.2	0	0.0%	29.5	29.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F03	7.2	7.2	0	0.0%	28.7	28.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F03	26.4	26.2	0.2	0.8%	79.1	79.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F03	26.5	26.1	0.4	1.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F03	27	26.4	0.6	2.2%	55.5	55.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F03	27.3	26.3	1	3.7%	54.6	54.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F03	27.4	26	1.4	5.1%	94.2	93.3	0.2	1.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F03	28.1	26.1	2	7.1%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F03	29.6	26.6	3	10.1%	96.7	79.3	7.6	18.0%	65		16	5	30.4%	16.0%
			BEDROOM		W17/F03	29.7	12.3	17.4	58.6%					65	17	27	1	58.5%	94.1%
			BEDROOM		W18/F03	30.6	11.5	19.1	62.4%					67	19	24	1	64.2%	94.7%
	R14	RESIDENTIAL	BEDROOM		W21/F03	30.5	10	20.5	67.2%	82.5	14.8	13.1	82.0%	68	18	20	1	70.6%	94.4%
	R15	RESIDENTIAL	LKD		W22/F03	29.6	9.6	20	67.6%	90.6	89.8	1.0	0.8%	69	18	19	1	72.5%	94.4%
			LKD		W23/F03	13.8	10.1	3.7	26.8%					27	9	20	3	25.9%	66.7%
			LKD		W24/F03	7.2	1.2	6	83.3%					25	13	10	1	60.0%	92.3%
			LKD		W25/F03	34.4	27.1	7.3	21.2%					64	20	45	6	29.7%	70.0%
			LKD		W26/F03	33.8	27.6	6.2	18.3%					60	18	45	6	25.0%	66.7%
			LKD		W27/F03	34.5	29.1	5.4	15.7%					61	19	47	7	23.0%	63.2%
	R16	RESIDENTIAL	BEDROOM		W28/F03	14.4	13	1.4	9.7%	69.4	66.8	0.9	3.8%	27	9	25	7	7.4%	22.2%
	R17	RESIDENTIAL	LKD		W29/F03	34.5	30.5	4	11.6%	93.4	92.1	1.2	1.4%	66	23	55	12	16.7%	47.8%
			LKD		W30/F03	34.4	30.9	3.5	10.2%					65	23	55	13	15.4%	43.5%
			LKD		W31/F03	6.2	6.2	0	0.0%					17	2	17	2	0.0%	0.0%
			LKD		W32/F03	14.9	14.3	0.6	4.0%					28	10	27	9	3.6%	10.0%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F03	14.6	14.4	0.2	1.4%	97.5	97.5	0.0	0.0%	28	10	27	9	3.6%	10.0%
	R19	RESIDENTIAL	BEDROOM		W34/F03	33.7	31.5	2.2	6.5%	99.2	99.2	0.0	0.0%	63	23	57	17	9.5%	26.1%
	R20	RESIDENTIAL	LKD		W35/F03	33.4	31.4	2	6.0%	88.4	88.4	0.0	0.0%	63	23	57	17	9.5%	26.1%
			LKD		W36/F03	14.4	14.4	0	0.0%					28	10	28	10	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F03	32.2	30.7	1.5	4.7%	95.5	95.5	0.0	0.0%	63	23	58	18	7.9%	21.7%
			LKD		W38/F03	30.2	29.2	1	3.3%					53	18	51	16	3.8%	11.1%

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: BSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R22	RESIDENTIAL	BEDROOM		W39/F03	30.4	29.3	1.1	3.6%	93.3	93.3	0.0	0.0%	58	21	55	18	5.2%	14.3%
			BEDROOM		W40/F03	2.7	2.7	0	0.0%					14	2	14	2	0.0%	0.0%
			BEDROOM		W41/F03	12.8	12.8	0	0.0%					25	10	25	10	0.0%	0.0%
F04	R1	RESIDENTIAL	LKD		W1/F04	35.2	35.1	0.1	0.3%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F04	33.9	33.9	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F04	33.3	33.3	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F04	33.3	33.2	0.1	0.3%	99.6	99.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F04	32.9	32.8	0.1	0.3%	82.1	82.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F04	32.3	32.2	0.1	0.3%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F04	32.2	32.1	0.1	0.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F04	10.5	10.5	0	0.0%	66.1	66.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F04	10.5	10.5	0	0.0%	65.6	65.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F04	32	31.8	0.2	0.6%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F04	32	31.7	0.3	0.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F04	32.5	32	0.5	1.5%	89.4	89.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F04	32.7	31.9	0.8	2.4%	90.2	90.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F04	32.6	31.5	1.1	3.4%	99	98.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F04	33	31.5	1.5	4.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F04	33.9	31.7	2.2	6.5%	98	86.6	5.0	11.6%	26	2	30	0	23.1%	100.0%
			BEDROOM		W17/F04	33	16.8	16.2	49.1%					71	21	39	2	45.1%	90.5%
			BEDROOM		W18/F04	33.7	15.6	18.1	53.7%					73	23	37	1	49.3%	95.7%
	R14	RESIDENTIAL	BEDROOM		W21/F04	33.6	12.9	20.7	61.6%	95.8	20.5	14.6	78.6%	74	23	29	1	60.8%	95.7%
	R15	RESIDENTIAL	LKD		W22/F04	33	12.6	20.4	61.8%	92.7	90.8	2.5	1.9%	72	21	29	1	59.7%	95.2%
			LKD		W23/F04	14.7	10.9	3.8	25.9%					27	9	20	3	25.9%	66.7%
			LKD		W24/F04	8.1	1.4	6.7	82.7%					26	14	12	2	53.8%	85.7%
			LKD		W25/F04	36.1	28.7	7.4	20.5%					65	21	48	7	26.2%	66.7%
			LKD		W26/F04	34.4	28.3	6.1	17.7%					60	21	45	8	25.0%	61.9%
			LKD		W27/F04	36	30.7	5.3	14.7%					66	22	53	10	19.7%	54.5%
	R16	RESIDENTIAL	BEDROOM		W28/F04	15.2	13.9	1.3	8.6%	72.7	70.5	0.8	3.0%	28	10	26	8	7.1%	20.0%
	R17	RESIDENTIAL	LKD		W29/F04	35.9	32	3.9	10.9%	94.4	92.4	1.8	2.1%	66	23	55	12	16.7%	47.8%
			LKD		W30/F04	35.8	32.4	3.4	9.5%					66	23	58	15	12.1%	34.8%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA

UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS	LOSS %	EX.		PR.		LOSS %	
												SQM		ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			LKD		W31/F04	6.8	6.8	0	0.0%					18	5	18	5	0.0%	0.0%
			LKD		W32/F04	15.7	15.1	0.6	3.8%					28	10	27	9	3.6%	10.0%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F04	15.4	15.2	0.2	1.3%	97.6	97.6	0.0	0.0%	28	10	27	9	3.6%	10.0%
	R19	RESIDENTIAL	BEDROOM		W34/F04	35	32.9	2.1	6.0%	99.2	99.2	0.0	0.0%	65	23	59	17	9.2%	26.1%
	R20	RESIDENTIAL	LKD		W35/F04	34.7	32.9	1.8	5.2%	90.2	90.2	0.0	0.0%	64	23	58	17	9.4%	26.1%
			LKD		W36/F04	15.2	15.2	0	0.0%					28	10	28	10	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F04	33.7	32.3	1.4	4.2%	96	95.9	0.0	0.0%	63	23	60	20	4.8%	13.0%
			LKD		W38/F04	30.3	29.4	0.9	3.0%					52	18	51	17	1.9%	5.6%
	R22	RESIDENTIAL	BEDROOM		W39/F04	32	31	1	3.1%	93.4	93.4	0.0	0.0%	62	22	59	19	4.8%	13.6%
			BEDROOM		W40/F04	3.3	3.3	0	0.0%					15	2	15	2	0.0%	0.0%
			BEDROOM		W41/F04	13.6	13.6	0	0.0%					26	10	26	10	0.0%	0.0%
F05	R1	RESIDENTIAL	LKD		W1/F05	37.1	37	0.1	0.3%	99.5	99.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F05	36	36	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F05	35.8	35.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F05	36.5	36.5	0	0.0%	99.8	99.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F05	36.4	36.3	0.1	0.3%	89.4	89.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F05	35.4	35.4	0	0.0%	99.6	99.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F05	35.3	35.2	0.1	0.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F05	12.6	12.6	0	0.0%	87.4	87.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F05	12.7	12.7	0	0.0%	86.6	86.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F05	35.4	35.2	0.2	0.6%	99.5	99.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F05	35.3	35	0.3	0.8%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F05	36.3	36	0.3	0.8%	95.6	95.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F05	36.2	35.7	0.5	1.4%	96.8	96.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F05	35.6	35	0.6	1.7%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F05	35.7	34.8	0.9	2.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F05	36.8	35.4	1.4	3.8%	98	91.6	2.8	6.5%	24	5	25	5	8.0%	30.0%
			BEDROOM		W17/F05	36.2	22.7	13.5	37.3%					75	25	53	6	29.3%	76.0%
			BEDROOM		W18/F05	36.5	21	15.5	42.5%					75	25	49	3	34.7%	88.0%
	R14	RESIDENTIAL	BEDROOM		W21/F05	36.5	16.3	20.2	55.3%	96.4	28.1	13.3	70.8%	79	27	41	2	48.1%	92.6%
	R15	RESIDENTIAL	LKD		W22/F05	36.1	16.2	19.9	55.1%	94.5	91.6	3.8	3.0%	79	27	38	4	51.9%	85.2%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			LKD		W23/F05	18.1	14.2	3.9	21.5%					32	10	25	4	21.9%	60.0%
			LKD		W24/F05	8.8	2	6.8	77.3%					31	16	17	3	45.2%	81.3%
			LKD		W25/F05	35.6	28.7	6.9	19.4%					62	22	46	8	25.8%	63.6%
			LKD		W26/F05	36.4	30.7	5.7	15.7%					61	21	49	9	19.7%	57.1%
			LKD		W27/F05	35.5	30.6	4.9	13.8%					62	22	51	11	17.7%	50.0%
	R16	RESIDENTIAL	BEDROOM		W28/F05	18.6	17.4	1.2	6.5%	73.5	72.2	0.4	18%	33	10	31	8	6.1%	20.0%
	R17	RESIDENTIAL	LKD		W29/F05	35.3	31.8	3.5	9.9%	95	93.4	1.5	1.7%	62	22	53	13	14.5%	40.9%
			LKD		W30/F05	35	32.3	2.7	7.7%					57	18	52	13	8.8%	27.8%
			LKD		W31/F05	7.6	7.6	0	0.0%					19	2	19	2	0.0%	0.0%
			LKD		W32/F05	19.2	18.3	0.9	4.7%					33	12	31	10	6.1%	16.7%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F05	18.8	18.6	0.2	1.1%	97.8	97.8	0.0	0.0%	33	10	33	10	0.0%	0.0%
	R19	RESIDENTIAL	BEDROOM		W34/F05	34.6	32.7	1.9	5.5%	98.6	98.6	0.0	0.0%	61	22	55	16	9.8%	27.3%
	R20	RESIDENTIAL	LKD		W35/F05	33.9	32.6	1.3	3.8%	90.4	90.4	0.0	0.0%	56	18	54	16	3.6%	11.1%
			LKD		W36/F05	18.9	18.8	0.1	0.5%					34	12	34	12	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F05	32.9	32	0.9	2.7%	96.6	96.6	0.0	0.0%	53	18	52	17	1.9%	5.6%
			LKD		W38/F05	33.6	32.5	1.1	3.3%					58	22	55	19	5.2%	13.6%
	R22	RESIDENTIAL	BEDROOM		W39/F05	31.5	30.9	0.6	1.9%	93.3	93.3	0.0	0.0%	53	18	52	17	1.9%	5.6%
			BEDROOM		W40/F05	4.5	4.5	0	0.0%					19		19	2	0.0%	0.0%
			BEDROOM		W41/F05	17.4	17.4	0	0.0%					32	12	32	12	0.0%	0.0%
F06	R1	RESIDENTIAL	BEDROOM		W1/F06	34.6	34.6	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W2/F06	38.9	38.8	0.1	0.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W3/F06	38.7	38.7	0	0.0%	97.6	97.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W5/F06	25.7	25.7	0	0.0%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W6/F06	30.9	30.9	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F06	25	25	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5 (3)	RESIDENTIAL	BEDROOM		W8/F06	38.1	38.1	0	0.0%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6 (3)	RESIDENTIAL	BEDROOM		W9/F06	38	38	0	0.0%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F06	24.2	24.2	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F06	31.2	31.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W12/F06	25.9	25.9	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R9 (3)	RESIDENTIAL	BEDROOM		W14/F06	38.7	38.5	0.2	0.5%	98	98	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R10	RESIDENTIAL	BEDROOM		W15/F06	38.9	38.6	0.3	0.8%	100	100	0.0	0.0%	35	7	31	5	8.1%	14.3%
			BEDROOM		W16/F06	38.9	29.5	9.4	24.2%					78	27	65	14	16.7%	48.1%
	R11	RESIDENTIAL	LKD		W17/F06	37.5	25.5	12	32.0%	100	100	0.0	0.0%	67	25	48	6	28.4%	76.0%
			LKD		W18/F06	38.9	24.1	14.8	38.0%					80	28	59	9	26.3%	67.9%
			LKD		W19/F06	38	32.4	5.6	14.7%					67	23	58	14	13.4%	39.1%
	R12	RESIDENTIAL	BEDROOM		W20/F06	37.9	33.3	4.6	12.1%	85.3	85.2	0.0	0.1%	67	23	60	16	10.4%	30.4%
			BEDROOM		W21/F06	37.8	34	3.8	10.1%					67	23	60	16	10.4%	30.4%
	R13	RESIDENTIAL	BEDROOM		W22/F06	28.7	28.2	0.5	1.7%	100	100	0.0	0.0%	37	9	36	8	2.7%	11.1%
			BEDROOM		W23/F06	33.8	31	2.8	8.3%					52	16	48	12	7.7%	25.0%
			BEDROOM		W24/F06	27.1	24.2	2.9	10.7%					55	20	50	15	9.1%	25.0%
	R14	RESIDENTIAL	LKD		W25/F06	36.3	35	1.3	3.6%	94.2	94.2	0.0	0.0%	64	20	61	17	4.7%	15.0%
	R15	RESIDENTIAL	LKD		W26/F06	37	35.2	1.8	4.9%	94.2	94.2	0.0	0.0%	67	23	64	20	4.5%	13.0%
	R16	RESIDENTIAL	BEDROOM		W27/F06	25.1	25.1	0	0.0%	99.2	99.2	0.0	0.0%	32	5	32	5	0.0%	0.0%
			BEDROOM		W28/F06	31.7	31.5	0.2	0.6%					48	15	47	14	2.1%	6.7%
			BEDROOM		W29/F06	27.9	27.2	0.7	2.5%					55	19	53	17	3.6%	10.5%
	R17	RESIDENTIAL	BEDROOM		W30/F06	36.1	35	1.1	3.0%	85.8	85.8	0.0	0.0%	64	23	62	21	3.1%	8.7%
			BEDROOM		W31/F06	35.8	34.7	1.1	3.1%					63	23	62	22	1.6%	4.3%
	R18	RESIDENTIAL	LKD		W32/F06	35	34.1	0.9	2.6%	100	100	0.0	0.0%	63	23	62	22	1.6%	4.3%
			LKD		W33/F06	29.9	29.9	0	0.0%					35	3	35	2	0.0%	0.0%
			LKD		W34/F06	32.1	32.1	0	0.0%					9	0	9	0	0.0%	0.0%
F07	R1	RESIDENTIAL	BEDROOM		W1/F07	34.3	34.3	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W2/F07	13.8	13.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W3/F07	7.2	7.2	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W4/F07	39.2	39.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F07	25.9	25.9	0	0.0%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W6/F07	31.9	31.9	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F07	26.1	26.1	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R4 (3)	RESIDENTIAL	BEDROOM		W8/F07	39.2	39.1	0.1	0.3%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R5 (3)	RESIDENTIAL	BEDROOM		W9/F07	39.2	39.2	0	0.0%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W10/F07	25	25	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F07	31.5	31.5	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS	LOSS %	EX.		PR.		LOSS %	
												SQM		ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)

			BEDROOM		W12/F07	26.2	26.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W13/F07	39.2	39.2	0	0.0%	100	100	0.0	0.0%	31	7	31	7	0.0%	0.0%
			BEDROOM		W14/F07	7.2	6.9	0.3	4.2%					14	4	14	4	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W15/F07	13.8	13.8	0	0.0%	100	100	0.0	0.0%	39	4	39	4	0.0%	0.0%
			BEDROOM		W16/F07	37.1	30.2	6.9	18.6%					72	26	65	19	9.7%	26.9%
	R9	RESIDENTIAL	LKD		W17/F07	37.5	28.8	8.7	23.2%	100	100	0.0	0.0%	70	25	60	15	14.3%	40.0%
			LKD		W18/F07	37.9	27.2	10.7	28.2%					73	27	63	17	13.7%	37.0%
			LKD		W19/F07	13.8	10.3	3.5	25.4%					19	12	14	7	26.3%	41.7%
	R10	RESIDENTIAL	BEDROOM		W20/F07	7.1	2	5.1	71.8%	87.7	86.8	0.4	1.1%	14	12	7	5	50.0%	58.3%
			BEDROOM		W21/F07	38.4	35.1	3.3	8.6%					67	23	62	18	7.5%	21.7%
	R11	RESIDENTIAL	BEDROOM		W22/F07	30	29.6	0.4	1.3%	100	100	0.0	0.0%	37	9	37	9	0.0%	0.0%
			BEDROOM		W23/F07	35.9	33.6	2.3	6.4%					58	16	54	12	6.9%	25.0%
			BEDROOM		W24/F07	29.7	27.4	2.3	7.7%					60	21	57	18	5.0%	14.3%
	R12	RESIDENTIAL	LKD		W25/F07	38.4	36.4	2	5.2%	94.4	94.4	0.0	0.0%	67	23	64	20	4.5%	13.0%
	R13	RESIDENTIAL	LKD		W26/F07	38.1	36.6	1.5	3.9%	94.4	94.4	0.0	0.0%	67	23	65	21	3.0%	8.7%
	R14	RESIDENTIAL	BEDROOM		W27/F07	27.9	27.9	0	0.0%	99.2	99.2	0.0	0.0%	33	6	33	6	0.0%	0.0%
			BEDROOM		W28/F07	34.8	34	0.8	2.3%					56	15	56	15	0.0%	0.0%
			BEDROOM		W29/F07	29.6	28.7	0.9	3.0%					59	20	58	19	1.7%	5.0%
	R15	RESIDENTIAL	BEDROOM		W30/F07	37.3	36.3	1	2.7%	86.9	86.9	0.0	0.0%	65	23	65	23	0.0%	0.0%
			BEDROOM		W31/F07	3.1	3.1	0	0.0%					8	0	8	0	0.0%	0.0%
	R16	RESIDENTIAL	LKD		W32/F07	11.7	11.7	0	0.0%	100	100	0.0	0.0%	15	8	15	8	0.0%	0.0%
			LKD		W33/F07	32.1	32.1	0	0.0%					15	0	15	0	0.0%	0.0%
			LKD		W34/F07	34.3	34.3	0	0.0%					14	0	14	0	0.0%	0.0%

11 PIMLICO ROAD

F02	R1	RESIDENTIAL	LIVING ROOM		W1/F02	29.4	22.1	7.3	24.8%	99.2	99	0.1	0.2%	N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W2/F02	29.6	21.9	7.7	26.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W3/F02	29.6	21.7	7.9	26.7%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W4/F02	29.7	21.6	8.1	27.3%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W5/F02	29.7	21.1	8.6	29.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W6/F02	29.9	14.1	15.8	52.8%					N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: BSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

11 PIMLICO ROAD (CONTINUED)																			
			LIVING ROOM		W7/F02	30.2	14.3	15.9	52.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W8/F02	30.3	14.5	15.8	52.1%	74	26.1	5.3	64.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	BEDROOM		W9/F02	30.3	14.6	15.7	51.8%	82.1	19.6	13.1	76.1%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W10/F02	30.3	14.7	15.6	51.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	LIVING ROOM		W11/F02	29.9	14.5	15.4	51.5%	92.5	38.6	19.3	58.2%	N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W12/F02	30.3	15.6	14.7	48.5%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W13/F02	30.2	17.7	12.5	41.4%					N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN-RESI		W1/F03	32.3	24	8.3	25.7%	84.6	74.5	2.8	11.9%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W2/F03	32.4	23.8	8.6	26.5%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W3/F03	32.5	23.6	8.9	27.4%					N/A	N/A	N/A	N/A	N/A	N/A

KILMUIR HOUSE																			
F00	R2	RESIDENTIAL	BEDROOM		W7/F00	20	19.8	0.2	1.0%	38.9	38.8	0.0	0.2%	30	6	28	4	6.7%	33.3%
	R3	RESIDENTIAL	BEDROOM		W8/F00	21.3	21.1	0.2	0.9%	39.8	39.8	0.0	0.0%	37	9	35	7	5.4%	22.2%
	R4	RESIDENTIAL	LIVING ROOM		W9/F00	15.1	14.9	0.2	1.3%	30.2	30.1	0.0	0.3%	39	10	36	7	7.7%	30.0%
	R5 (3)	RESIDENTIAL	LIVING ROOM		W10/F00	11.2	11.1	0.1	0.9%	32.7	32.7	0.0	0.0%	21	7	19	5	9.5%	28.6%
	R6	RESIDENTIAL	BEDROOM		W11/F00	21.2	21.1	0.1	0.5%	38.6	38.4	0.0	0.6%	31	5	30	4	3.2%	20.0%
	R7	RESIDENTIAL	BEDROOM		W12/F00	23.1	23	0.1	0.4%	37.3	37.3	0.0	0.0%	40	8	39	7	2.5%	12.5%
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	29.4	28.5	0.9	3.1%	92.4	91.5	0.1	1.0%	66	16	64	14	3.0%	12.5%
	R2	RESIDENTIAL	BEDROOM		W2/F01	24.4	23.8	0.6	2.5%	50.5	46.5	0.5	7.9%	51	14	50	13	2.0%	7.1%
	R3 (3)	RESIDENTIAL	LIVING ROOM		W3/F01	18.1	17.7	0.4	2.2%	40	35.6	0.7	10.8%	50	14	48	12	4.0%	14.3%
	R4	RESIDENTIAL	BEDROOM		W4/F01	22.3	22	0.3	1.3%	44.9	44.8	0.0	0.1%	35	7	33	5	5.7%	28.6%
	R5	RESIDENTIAL	BEDROOM		W5/F01	22.7	22.4	0.3	1.3%	45.5	45.5	0.0	0.0%	43	11	42	10	2.3%	9.1%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F01	13.4	13.2	0.2	1.5%	34.6	33.8	0.1	2.3%	30	12	29	11	3.3%	8.3%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F01	17.5	17.4	0.1	0.6%	39	39	0.0	0.0%	28	9	27	8	3.6%	11.1%
	R8	RESIDENTIAL	BEDROOM		W8/F01	24.4	24.3	0.1	0.4%	47	46.9	0.0	0.0%	41	9	40	8	2.4%	11.1%
	R9	RESIDENTIAL	BEDROOM		W9/F01	25.3	25.2	0.1	0.4%	46.2	46.2	0.0	0.0%	48	12	47	11	2.1%	8.3%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	32.3	31.4	0.9	2.8%	86.8	77.7	1.3	10.5%	71	20	70	19	1.4%	5.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	27	26.4	0.6	2.2%	61.2	58.1	0.4	5.2%	56	16	54	14	3.6%	12.5%
	R3	RESIDENTIAL	LKD		W3/F02	20.7	20.2	0.5	2.4%	77.7	75.8	0.5	2.4%	54	14	54	14	0.0%	0.0%
			LKD		W10/F02	22.4	22.4	0	0.0%					29	5	29	5	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

KILMUJR HOUSE (CONTINUED)																			
	R4	RESIDENTIAL	BEDROOM		W4/F02	24.9	24.5	0.4	1.6%	57.3	57.3	0.0	0.1%	39	8	38	7	2.6%	12.5%
	R5	RESIDENTIAL	BEDROOM		W5/F02	26.2	25.9	0.3	1.1%	58	58	0.0	0.0%	47	12	46	11	2.1%	8.3%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F02	20	19.7	0.3	1.5%	43.3	42.9	0.1	0.9%	50	12	50	12	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F02	16.1	15.9	0.2	1.2%	45	45	0.0	0.1%	32	9	32	9	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F02	25.9	25.8	0.1	0.4%	58.4	58.4	0.0	0.0%	41	7	41	7	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F02	27.7	27.6	0.1	0.4%	57.7	57.7	0.0	0.0%	51	12	51	12	0.0%	0.0%
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	35	34.1	0.9	2.6%	90.8	83.1	1.1	8.5%	77	25	75	23	2.6%	8.0%
	R2	RESIDENTIAL	BEDROOM		W2/F03	29.5	28.7	0.8	2.7%	77	75.8	0.2	1.6%	62	19	59	16	4.8%	15.8%
	R3	RESIDENTIAL	LKD		W3/F03	23.2	22.6	0.6	2.6%	80.2	80.2	0.0	0.0%	60	18	58	16	3.3%	11.1%
			LKD		W10/F03	24.2	24.2	0	0.0%					31	6	31	6	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F03	27.5	27	0.5	1.8%	74.8	74.8	0.0	0.0%	44	10	43	9	2.3%	10.0%
	R5	RESIDENTIAL	BEDROOM		W5/F03	27.8	27.4	0.4	1.4%	75.7	75.7	0.0	0.0%	52	14	51	13	1.9%	7.1%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F03	18.4	18.1	0.3	1.6%	54.1	52.1	0.3	3.6%	38	14	38	14	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F03	22.5	22.2	0.3	1.3%	58.2	58.2	0.0	0.0%	35	11	35	11	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F03	29.4	29.1	0.3	1.0%	75.9	75.9	0.0	0.0%	50	12	49	11	2.0%	8.3%
	R9	RESIDENTIAL	BEDROOM		W9/F03	30.1	29.9	0.2	0.7%	75	75	0.0	0.0%	55	15	54	14	1.8%	6.7%
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	36.9	35.9	1	2.7%	91.9	87.1	0.7	5.2%	79	27	76	24	3.8%	11.1%
	R2	RESIDENTIAL	BEDROOM		W2/F04	31.7	30.7	1	3.2%	95.4	94	0.2	1.5%	64	20	61	17	4.7%	15.0%
	R3	RESIDENTIAL	LKD		W3/F04	25.7	24.9	0.8	3.1%	84	84	0.0	0.0%	64	20	61	17	4.7%	15.0%
			LKD		W10/F04	25.7	25.7	0	0.0%					32	7	32	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F04	29.8	29.1	0.7	2.3%	90.9	90.2	0.1	0.7%	48	13	46	11	4.2%	15.4%
	R5	RESIDENTIAL	BEDROOM		W5/F04	31	30.3	0.7	2.3%	93.1	92.7	0.0	0.4%	56	17	54	15	3.6%	11.8%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F04	24.9	24.4	0.5	2.0%	73.4	70.6	0.5	3.8%	61	18	59	16	3.3%	11.1%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F04	21	20.5	0.5	2.4%	72.9	72.7	0.0	0.2%	42	15	40	13	4.8%	13.3%
	R8	RESIDENTIAL	BEDROOM		W8/F04	30.6	30.1	0.5	1.6%	94.1	94	0.0	0.1%	50	13	48	11	4.0%	15.4%
	R9	RESIDENTIAL	BEDROOM		W9/F04	32.2	31.7	0.5	1.6%	92.7	92.7	0.0	0.0%	58	17	57	16	1.7%	5.9%
F05	R1	RESIDENTIAL	BEDROOM		W1/F05	38	37	1	2.6%	92.3	90.7	0.2	1.7%	79	27	79	27	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F05	33.4	32.1	1.3	3.9%	99.5	99.5	0.0	0.0%	66	21	65	20	1.5%	4.8%
	R3	RESIDENTIAL	LKD		W3/F05	27.3	26.1	1.2	4.4%	89.4	89.2	0.1	0.3%	65	21	64	20	1.5%	4.8%
			LKD		W10/F05	26.8	26.8	0	0.0%					30	7	30	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F05	31.4	30.3	1.1	3.5%	98.4	98.4	0.0	0.0%	50	14	49	13	2.0%	7.1%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA

UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

KILMUJR HOUSE (CONTINUED)																			
	R5	RESIDENTIAL	BEDROOM		W5/F05	31.6	30.6	1	3.2%	99.2	99.2	0.0	0.0%	59	18	58	17	1.7%	5.6%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F05	22.4	21.5	0.9	4.0%	89.9	84	1.0	6.5%	46	19	45	18	2.2%	5.3%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F05	26.3	25.6	0.7	2.7%	89.3	89.3	0.0	0.0%	42	16	42	16	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F05	33	32.3	0.7	2.1%	99.3	99.3	0.0	0.0%	55	16	55	16	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F05	33.6	33	0.6	1.8%	98.5	98.5	0.0	0.0%	61	19	61	19	0.0%	0.0%
F06	R1	RESIDENTIAL	BEDROOM		W1/F06	38.6	37.5	1.1	2.8%	92.2	91.5	0.1	0.7%	79	27	79	27	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F06	34.9	33.3	1.6	4.6%	99.5	99.5	0.0	0.0%	66	21	66	21	0.0%	0.0%
	R3	RESIDENTIAL	LKD		W3/F06	28.8	27.4	1.4	4.9%	92.3	92	0.1	0.4%	66	21	66	21	0.0%	0.0%
			LKD		W10/F06	27.4	27.4	0	0.0%					30	7	30	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F06	32.9	31.6	1.3	4.0%	98.6	98.6	0.0	0.0%	50	14	50	14	0.0%	0.0%
	R5	RESIDENTIAL	BEDROOM		W5/F06	34.1	32.8	1.3	3.8%	99.3	99.3	0.0	0.0%	61	18	61	18	0.0%	0.0%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F06	27.9	26.8	1.1	3.9%	99.3	98.9	0.1	0.4%	64	19	64	19	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F06	23.7	22.8	0.9	3.8%	99.5	99.5	0.0	0.0%	43	16	43	16	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F06	33.4	32.5	0.9	2.7%	99.3	99.3	0.0	0.0%	52	14	52	14	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F06	34.9	34.1	0.8	2.3%	98.5	98.5	0.0	0.0%	62	18	62	18	0.0%	0.0%
F07	R1	RESIDENTIAL	BEDROOM		W1/F07	39	37.9	1.1	2.8%	92.3	92.1	0.0	0.2%	79	27	79	27	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F07	36.3	34.6	1.7	4.7%	99.5	99.5	0.0	0.0%	66	21	66	21	0.0%	0.0%
	R3	RESIDENTIAL	LKD		W3/F07	29.9	28.4	1.5	5.0%	97.4	97.4	0.0	0.0%	66	21	66	21	0.0%	0.0%
			LKD		W10/F07	26.9	26.9	0	0.0%					27	7	27	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F07	34.5	33	1.5	4.3%	98.6	98.6	0.0	0.0%	52	14	52	14	0.0%	0.0%
	R5	RESIDENTIAL	BEDROOM		W5/F07	34.6	33.2	1.4	4.0%	99.2	99.2	0.0	0.0%	65	20	65	20	0.0%	0.0%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F07	24.9	23.7	1.2	4.8%	99.3	99.2	0.0	0.1%	50	21	50	21	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F07	29	27.9	1.1	3.8%	99.6	99.6	0.0	0.0%	42	16	42	16	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F07	35.9	34.9	1	2.8%	99.3	99.3	0.0	0.0%	61	16	61	16	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F07	36.3	35.4	0.9	2.5%	98.6	98.6	0.0	0.0%	66	21	66	21	0.0%	0.0%
F08	R1	RESIDENTIAL	BEDROOM		W1/F08	38.8	37.7	1.1	2.8%	92.3	92.2	0.0	0.1%	76	27	76	27	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F08	37.6	36	1.6	4.3%	99.5	99.5	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R3	RESIDENTIAL	LKD		W3/F08	37.5	36	1.5	4.0%	100	100	0.0	0.0%	67	22	67	22	0.0%	0.0%
			LKD		W10/F08	20.9	20.9	0	0.0%					16	3	16	3	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F08	37.6	36.2	1.4	3.7%	98.7	98.7	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R5	RESIDENTIAL	BEDROOM		W5/F08	37.6	36.3	1.3	3.5%	99.3	99.3	0.0	0.0%	67	22	67	22	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

KILMUJR HOUSE (CONTINUED)																			
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F08	37.4	36.2	1.2	3.2%	99.3	99.2	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F08	37.3	36.2	1.1	2.9%	99.6	99.6	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F08	37.5	36.5	1	2.7%	99.4	99.4	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F08	37.5	36.5	1	2.7%	98.5	98.5	0.0	0.0%	67	22	67	22	0.0%	0.0%

SEMLEY HOUSE																			
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	20.8	20.8	0	0.0%	92.9	92.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F02	34	34	0	0.0%					21	1	21	1	0.0%	0.0%
			UNKNOWN		W3/F02	15.4	15.4	0	0.0%					30	1	30	1	0.0%	0.0%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	21.9	21.9	0	0.0%	93.9	93.9	0.0	0.0%					0.0%	0.0%
			UNKNOWN		W2/F03	35.1	35.1	0	0.0%					24	1	24	1	0.0%	0.0%
			UNKNOWN		W3/F03	17.7	17.7	0	0.0%					33	2	33	2	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W4/F03	33.5	30.8	2.7	8.1%	99.6	99.6	0.0	0.0%	72	24	69	21	4.2%	12.5%
	R3	RESIDENTIAL	UNKNOWN		W5/F03	33.4	30.6	2.8	8.4%	100	100	0.0	0.0%	72	24	69	21	4.2%	12.5%
F04	R1	RESIDENTIAL	UNKNOWN		W1/F04	22.9	22.9	0	0.0%	95.8	95.8	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F04	36.2	36.2	0	0.0%					24		24		0.0%	0.0%
			UNKNOWN		W3/F04	20.7	20.5	0.2	1.0%					38	4	38	4	0.0%	0.0%
	R2	RESIDENTIAL	LKD		W4/F04	27.4	26.9	0.5	1.8%	94.9	85.7	2.8	9.6%	61	15	61	15	0.0%	0.0%
			LKD		W5/F04	27.3	26.6	0.7	2.6%					60	15	60	15	0.0%	0.0%
			LKD		W6/F04	28.2	27.1	1.1	3.9%					63	18	62	17	1.6%	5.6%
	R3	RESIDENTIAL	LKD		W7/F04	10.9	9.3	1.6	14.7%	99.9	99.8	0.1	0.2%	23	15	22	14	4.3%	6.7%
			LKD		W8/F04	29.3	27.6	1.7	5.8%					66	20	65	19	1.5%	5.0%
			LKD		W9/F04	30.5	28.7	1.8	5.9%					64	20	63	19	1.6%	5.0%
	R4	RESIDENTIAL	LKD		W10/F04	31.2	29.4	1.8	5.8%	100	100	0.0	0.0%	67	21	65	19	3.0%	9.5%
			LKD		W11/F04	31.2	29.3	1.9	6.1%					68	21	66	19	2.9%	9.5%
			LKD		W12/F04	31.8	29.8	2	6.3%					67	23	65	21	3.0%	8.7%
	R5	RESIDENTIAL	LKD		W13/F04	13.6	11.5	2.1	15.4%	99.9	99.8	0.0	0.1%	27	19	26	18	3.7%	5.3%
			LKD		W14/F04	31.6	29.4	2.2	7.0%					69	24	67	22	2.9%	8.3%
			LKD		W15/F04	32.6	30.4	2.2	6.7%					68	24	66	22	2.9%	8.3%
	R6	RESIDENTIAL	LKD		W16/F04	33.1	30.8	2.3	6.9%	99.9	99.3	0.2	0.6%	69	23	67	21	2.9%	8.7%
			LKD		W17/F04	33.1	30.7	2.4	7.3%					68	23	66	21	2.9%	8.7%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
			LKD		W18/F04	33.4	31	2.4	7.2%					67	23	65	21	3.0%	8.7%
	R7	RESIDENTIAL	LKD		W19/F04	14.3	11.8	2.5	17.5%	100	96	11	4.0%	25	16	24	15	4.0%	6.3%
			LKD		W20/F04	25.3	22.7	2.6	10.3%					45	12	44	11	2.2%	8.3%
			LKD		W21/F04	20.5	18.2	2.3	11.2%					33	7	32	6	3.0%	14.3%
	R10	RESIDENTIAL	LKD		W24/F04	22.3	20.2	2.1	9.4%	99.9	96	11	3.9%	46	20	44	18	4.3%	10.0%
			LKD		W25/F04	27.3	24.7	2.6	9.5%					50	22	47	19	6.0%	13.6%
			LKD		W26/F04	15.5	12.9	2.6	16.8%					25	20	22	17	12.0%	15.0%
	R11	RESIDENTIAL	LKD		W27/F04	35.1	32.5	2.6	7.4%	100	97.8	0.6	2.2%	71	25	69	23	2.8%	8.0%
			LKD		W28/F04	35.2	32.7	2.5	7.1%					71	25	68	22	4.2%	12.0%
			LKD		W29/F04	35.4	32.9	2.5	7.1%					71	25	68	22	4.2%	12.0%
	R12	RESIDENTIAL	LKD		W30/F04	35.1	32.6	2.5	7.1%	100	98.6	0.4	1.4%	67	23	64	20	4.5%	13.0%
			LKD		W31/F04	34.3	31.8	2.5	7.3%					60	22	58	20	3.3%	9.1%
			LKD		W32/F04	16.6	14.2	2.4	14.5%					30	20	28	18	6.7%	10.0%
	R13	RESIDENTIAL	LKD		W33/F04	35.6	33.3	2.3	6.5%	100	99.7	0.1	0.3%	75	26	72	23	4.0%	11.5%
			LKD		W34/F04	35.7	33.4	2.3	6.4%					73	25	70	22	4.1%	12.0%
			LKD		W35/F04	35.8	33.5	2.3	6.4%					74	26	70	22	5.4%	15.4%
	R14	RESIDENTIAL	LKD		W36/F04	35.4	33.2	2.2	6.2%	100	100	0.0	0.0%	69	24	65	20	5.8%	16.7%
			LKD		W37/F04	34.6	32.3	2.3	6.6%					64	24	60	20	6.3%	16.7%
			LKD		W38/F04	16.9	14.7	2.2	13.0%					33	22	29	18	12.1%	18.2%
	R15	RESIDENTIAL	LKD		W39/F04	35.9	33.8	2.1	5.8%	100	100	0.0	0.0%	77	27	73	23	5.2%	14.8%
			LKD		W40/F04	36	33.9	2.1	5.8%					77	27	74	24	3.9%	11.1%
			LKD		W41/F04	36.2	34.2	2	5.5%					77	27	74	24	3.9%	11.1%
	R16	RESIDENTIAL	LKD		W42/F04	36.3	34.2	2.1	5.8%	100	100	0.0	0.0%	78	27	75	24	3.8%	11.1%
			LKD		W43/F04	36.1	34	2.1	5.8%					78	27	75	24	3.8%	11.1%
			LKD		W44/F04	36.3	34.3	2	5.5%					78	27	76	25	2.6%	7.4%
F05	R1	RESIDENTIAL	UNKNOWN		W1/F05	23.6	23.6	0	0.0%	96.3	96.3	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F05	37.3	37.3	0	0.0%					0		0		0.0%	0.0%
			UNKNOWN		W3/F05	23.2	22.9	0.3	1.3%					42	6	42	6	0.0%	0.0%
	R2	RESIDENTIAL	KITCHEN		W4/F05	29.9	29.2	0.7	2.3%	87.2	82	0.7	6.0%	65	18	65	18	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W5/F05	30.3	29.1	1.2	4.0%	84.9	69.9	3.3	17.7%	68	19	67	18	1.5%	5.3%
	R4	RESIDENTIAL	LKD		W6/F05	31.5	30	1.5	4.8%	99	99	0.0	0.0%	69	20	68	19	1.4%	5.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA

UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
			LKD		W7/F05	31.3	29.9	1.4	4.5%					67	20	66	19	1.5%	5.0%
			LKD		W8/F05	32.6	30.9	1.7	5.2%					67	20	66	19	1.5%	5.0%
	R5	RESIDENTIAL	KITCHEN		W9/F05	33	31.2	1.8	5.5%	98.2	98.2	0.0	0.0%	70	23	68	21	2.9%	8.7%
	R6	RESIDENTIAL	LIVING ROOM		W10/F05	33	31.1	1.9	5.8%	93.8	91.2	0.6	2.8%	72	24	70	22	2.8%	8.3%
	R7	RESIDENTIAL	LKD		W11/F05	33.8	31.8	2	5.9%	99	99	0.0	0.0%	72	24	71	23	1.4%	4.2%
			LKD		W12/F05	33.6	31.6	2	6.0%					71	24	70	23	1.4%	4.2%
			LKD		W13/F05	34.4	32.3	2.1	6.1%					71	24	70	23	1.4%	4.2%
	R8	RESIDENTIAL	KITCHEN		W14/F05	34.4	32.2	2.2	6.4%	98.3	96.3	0.2	1.9%	67	23	65	21	3.0%	8.7%
	R9	RESIDENTIAL	LIVING ROOM		W15/F05	34	31.7	2.3	6.8%	93.9	90.3	0.8	3.8%	68	23	66	21	2.9%	8.7%
	R10	RESIDENTIAL	LKD		W16/F05	34	31.6	2.4	7.1%	99	98.8	0.0	0.1%	65	22	63	20	3.1%	9.1%
			LKD		W17/F05	33	30.7	2.3	7.0%					62	22	60	20	3.2%	9.1%
			LKD		W18/F05	29.6	27.1	2.5	8.4%					50	16	48	14	4.0%	12.5%
	R13	RESIDENTIAL	LKD		W21/F05	31	28.5	2.5	8.1%	98.9	98.8	0.0	0.1%	65	26	63	24	3.1%	7.7%
			LKD		W22/F05	34.1	31.7	2.4	7.0%					67	26	65	24	3.0%	7.7%
			LKD		W23/F05	35	32.5	2.5	7.1%					69	26	67	24	2.9%	7.7%
	R14	RESIDENTIAL	LIVING ROOM		W24/F05	35.4	32.9	2.5	7.1%	94.2	87.5	1.5	7.2%	73	26	71	24	2.7%	7.7%
	R15	RESIDENTIAL	KITCHEN (1)		W25/F05	36.1	33.7	2.4	6.6%	98.2	94.9	0.4	3.4%	74	26	72	24	2.7%	7.7%
	R16	RESIDENTIAL	LKD		W26/F05	36.6	34.2	2.4	6.6%	99	98.9	0.0	0.1%	74	26	72	24	2.7%	7.7%
			LKD		W27/F05	36.2	33.9	2.3	6.4%					72	26	70	24	2.8%	7.7%
			LKD		W28/F05	36.5	34.2	2.3	6.3%					73	26	71	24	2.7%	7.7%
	R17	RESIDENTIAL	LIVING ROOM		W29/F05	36.2	33.9	2.3	6.4%	94.3	88.6	1.3	6.0%	77	27	74	24	3.9%	11.1%
	R18	RESIDENTIAL	KITCHEN (1)		W30/F05	36.6	34.4	2.2	6.0%	98.1	96.7	0.2	1.4%	77	26	75	24	2.6%	7.7%
	R19	RESIDENTIAL	LKD		W31/F05	36.9	34.7	2.2	6.0%	99	99	0.0	0.0%	76	27	73	24	3.9%	11.1%
			LKD		W32/F05	36.6	34.5	2.1	5.7%					74	27	71	24	4.1%	11.1%
			LKD		W33/F05	36.8	34.7	2.1	5.7%					74	27	71	24	4.1%	11.1%
	R20	RESIDENTIAL	LIVING ROOM		W34/F05	36.4	34.4	2	5.5%	94.3	90.3	0.9	4.2%	78	27	75	24	3.8%	11.1%
	R21	RESIDENTIAL	KITCHEN (1)		W35/F05	36.8	34.8	2	5.4%	98.1	98.1	0.0	0.0%	79	27	77	25	2.5%	7.4%
	R22	RESIDENTIAL	KITCHEN		W36/F05	37.1	35.2	1.9	5.1%	98.3	98.3	0.0	0.0%	79	27	77	25	2.5%	7.4%
	R23	RESIDENTIAL	LIVING ROOM		W37/F05	37.1	35.2	1.9	5.1%	94.1	93.9	0.0	0.1%	79	27	77	25	2.5%	7.4%
F06	R1	RESIDENTIAL	UNKNOWN		W1/F06	23.9	23.9	0	0.0%	97.1	97.1	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F06	38.1	38.1	0	0.0%					28	3	28	3	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA

UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
			UNKNOWN		W3/F06	25.4	25.1	0.3	1.2%					48	12	48	12	0.0%	0.0%
	R2	RESIDENTIAL	LIVING ROOM		W4/F06	30.3	29.4	0.9	3.0%	80.6	80.4	0.0	0.2%	55	17	55	17	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN (1)		W5/F06	17	15.8	1.2	7.1%	95.9	95.6	0.0	0.3%	39	20	39	20	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W6/F06	33.3	31.8	1.5	4.5%	98.2	98.2	0.0	0.0%	68	21	68	21	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/F06	34.2	32.6	1.6	4.7%	94.1	92.1	0.4	2.1%	68	21	67	20	1.5%	4.8%
	R6	RESIDENTIAL	LIVING ROOM		W8/F06	32.4	30.6	1.8	5.6%	90.2	89.6	0.1	0.6%	57	19	56	18	1.8%	5.3%
	R7	RESIDENTIAL	KITCHEN (1)		W9/F06	18.7	16.9	1.8	9.6%	98.2	98.2	0.0	0.0%	41	23	41	23	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN (1)		W10/F06	34.8	32.9	1.9	5.5%	98.2	98.2	0.0	0.0%	70	24	70	24	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W11/F06	35.5	33.5	2	5.6%	94.3	92.9	0.3	1.5%	70	23	70	23	0.0%	0.0%
	R10	RESIDENTIAL	LIVING ROOM		W12/F06	33.6	31.4	2.2	6.5%	93.8	93	0.2	0.9%	57	19	56	18	1.8%	5.3%
	R11	RESIDENTIAL	KITCHEN (1)		W13/F06	19.3	17.2	2.1	10.9%	98	97.5	0.1	0.5%	39	23	37	21	5.1%	8.7%
	R12	RESIDENTIAL	KITCHEN (1)		W14/F06	34.4	32.2	2.2	6.4%	98.2	97.7	0.1	0.5%	62	22	60	20	3.2%	9.1%
	R13	RESIDENTIAL	LIVING ROOM		W15/F06	30	27.7	2.3	7.7%	93	87.2	1.2	6.2%	50	16	48	14	4.0%	12.5%
	R16	RESIDENTIAL	LIVING ROOM		W18/F06	31.2	28.9	2.3	7.4%	93.5	90.7	0.6	3.0%	66	26	64	24	3.0%	7.7%
	R17	RESIDENTIAL	KITCHEN (1)		W19/F06	35.2	32.9	2.3	6.5%	98.1	97.5	0.1	0.6%	66	23	64	21	3.0%	8.7%
	R18	RESIDENTIAL	KITCHEN (1)		W20/F06	20.4	18.1	2.3	11.3%	98.2	97.2	0.1	1.0%	33	19	31	17	6.1%	10.5%
	R19	RESIDENTIAL	LIVING ROOM		W21/F06	34.8	32.6	2.2	6.3%	94.3	92.8	0.3	1.6%	69	26	67	24	2.9%	7.7%
	R20	RESIDENTIAL	LIVING ROOM		W22/F06	37.2	35	2.2	5.9%	94.3	90	1.0	4.5%	76	26	74	24	2.6%	7.7%
	R21	RESIDENTIAL	KITCHEN (1)		W23/F06	36.8	34.6	2.2	6.0%	98.3	97.7	0.1	0.6%	69	23	67	21	2.9%	8.7%
	R22	RESIDENTIAL	KITCHEN (1)		W24/F06	21	18.9	2.1	10.0%	98.2	97.9	0.0	0.3%	34	19	32	17	5.9%	10.5%
	R23	RESIDENTIAL	LIVING ROOM		W25/F06	35.2	33.1	2.1	6.0%	94.2	93.6	0.2	0.7%	73	26	71	24	2.7%	7.7%
	R24	RESIDENTIAL	LIVING ROOM		W26/F06	37.5	35.5	2	5.3%	94.3	91.2	0.7	3.3%	78	27	75	24	3.8%	11.1%
	R25	RESIDENTIAL	KITCHEN (1)		W27/F06	37.1	35.1	2	5.4%	98.1	98.1	0.0	0.0%	72	24	69	21	4.2%	12.5%
	R26	RESIDENTIAL	KITCHEN (1)		W28/F06	21.4	19.5	1.9	8.9%	98.2	98.2	0.0	0.0%	36	20	33	17	8.3%	15.0%
	R27	RESIDENTIAL	LIVING ROOM		W29/F06	35.3	33.4	1.9	5.4%	94.1	93.9	0.0	0.2%	75	27	73	25	2.7%	7.4%
	R28	RESIDENTIAL	LIVING ROOM		W30/F06	37.7	35.9	1.8	4.8%	94.2	92.4	0.4	2.0%	78	27	76	25	2.6%	7.4%
	R29	RESIDENTIAL	KITCHEN		W31/F06	37.9	36.1	1.8	4.7%	98.1	98.1	0.0	0.0%	79	27	77	25	2.5%	7.4%
F07	R1	RESIDENTIAL	UNKNOWN		W1/F07	24	24	0	0.0%	97.4	97.3	0.0	0.1%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F07	38.7	38.7	0	0.0%					0	0	0	0	0.0%	0.0%
			UNKNOWN		W3/F07	27.6	27	0.6	2.2%					49	13	49	13	0.0%	0.0%
	R2	RESIDENTIAL	LKD		W4/F07	35.2	34.1	1.1	3.1%	98.9	98.9	0.0	0.0%	71	22	71	22	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA

UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
			LKD		W5/F07	34.8	33.7	11	3.2%					69	22	69	22	0.0%	0.0%
			LKD		W6/F07	35.4	34.1	13	3.7%					69	22	69	22	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W7/F07	35.1	33.7	14	4.0%	89.6	89.5	0.0	0.2%	73	23	72	22	1.4%	4.3%
	R4	RESIDENTIAL	KITCHEN (1)		W8/F07	35.8	34.3	15	4.2%	98.1	98.1	0.0	0.0%	74	24	73	23	1.4%	4.2%
	R5	RESIDENTIAL	LKD		W9/F07	36.3	34.7	16	4.4%	99.1	99.1	0.0	0.0%	74	24	74	24	0.0%	0.0%
			LKD		W10/F07	36	34.3	17	4.7%					71	24	71	24	0.0%	0.0%
			LKD		W11/F07	36.4	34.6	18	4.9%					70	24	70	24	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W12/F07	36.1	34.3	18	5.0%	94.1	93.8	0.1	0.4%	73	24	73	24	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (1)		W13/F07	36.6	34.7	19	5.2%	98.2	98.2	0.0	0.0%	73	24	73	24	0.0%	0.0%
	R8	RESIDENTIAL	LKD		W14/F07	36.9	35	19	5.1%	99	99	0.0	0.0%	71	24	70	23	1.4%	4.2%
			LKD		W15/F07	36.5	34.5	2	5.5%					70	24	69	23	1.4%	4.2%
			LKD		W16/F07	36.7	34.7	2	5.4%					69	24	67	22	2.9%	8.3%
	R9	RESIDENTIAL	LIVING ROOM		W17/F07	35.2	33.1	21	6.0%	94.2	93.4	0.2	0.8%	65	23	63	21	3.1%	8.7%
	R10	RESIDENTIAL	KITCHEN (1)		W18/F07	29.2	27.1	21	7.2%	98.2	98.2	0.0	0.0%	49	14	47	12	41%	14.3%
	R13	RESIDENTIAL	KITCHEN (1)		W21/F07	30	27.9	21	7.0%	98.2	98.2	0.0	0.0%	60	25	58	23	3.3%	8.0%
	R14	RESIDENTIAL	LIVING ROOM		W22/F07	35.7	33.6	21	5.9%	94.3	93.4	0.2	1.0%	73	26	71	24	2.7%	7.7%
	R15	RESIDENTIAL	LKD		W23/F07	37.3	35.2	21	5.6%	99	99	0.0	0.0%	75	26	73	24	2.7%	7.7%
			LKD		W24/F07	37.3	35.3	2	5.4%					74	26	72	24	2.7%	7.7%
			LKD		W25/F07	37.8	35.7	21	5.6%					74	27	72	25	2.7%	7.4%
	R16	RESIDENTIAL	KITCHEN (1)		W26/F07	37.7	35.7	2	5.3%	98.2	98.2	0.0	0.0%	76	28	74	26	2.6%	7.1%
	R17	RESIDENTIAL	LIVING ROOM		W27/F07	37.4	35.5	19	5.1%	94.3	93.7	0.1	0.6%	79	28	77	26	2.5%	7.1%
	R18	RESIDENTIAL	LKD		W28/F07	37.9	36	19	5.0%	99.1	99.1	0.0	0.0%	79	28	77	26	2.5%	7.1%
			LKD		W29/F07	37.9	35.9	2	5.3%					79	28	77	26	2.5%	7.1%
			LKD		W30/F07	38.2	36.3	19	5.0%					77	28	75	26	2.6%	7.1%
	R19	RESIDENTIAL	KITCHEN (1)		W31/F07	38	36.1	19	5.0%	98.3	98.3	0.0	0.0%	77	28	74	25	3.9%	10.7%
	R20	RESIDENTIAL	LIVING ROOM		W32/F07	37.7	35.9	18	4.8%	94.3	94	0.1	0.3%	80	28	77	25	3.8%	10.7%
	R21	RESIDENTIAL	LKD		W33/F07	38.1	36.3	18	4.7%	99	99	0.0	0.0%	80	28	78	26	2.5%	7.1%
			LKD		W34/F07	38	36.3	17	4.5%					79	27	77	25	2.5%	7.4%
			LKD		W35/F07	38.4	36.7	17	4.4%					79	27	77	25	2.5%	7.4%
	R22	RESIDENTIAL	KITCHEN (1)		W36/F07	38.4	36.8	16	4.2%	98.3	98.3	0.0	0.0%	79	27	77	25	2.5%	7.4%
	R23	RESIDENTIAL	LIVING ROOM		W37/F07	38.4	36.8	16	4.2%	94.3	94.3	0.0	0.0%	79	27	77	25	2.5%	7.4%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA

UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
F08	R1	RESIDENTIAL	UNKNOWN		W1/F08	24.1	24.1	0	0.0%	99.4	99.4	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F08	39.1	39.1	0	0.0%					31	8	31	8	0.0%	0.0%
			UNKNOWN		W3/F08	29.7	28.9	0.8	2.7%					51	15	51	15	0.0%	0.0%
	R2	RESIDENTIAL	LIVING ROOM		W4/F08	36.9	35.9	1	2.7%	94.5	94.5	0.0	0.0%	74	24	74	24	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN (1)		W5/F08	36.6	35.5	1.1	3.0%	98.2	98.2	0.0	0.0%	68	21	68	21	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W6/F08	21.7	20.4	1.3	6.0%	98.2	98.2	0.0	0.0%	37	20	37	20	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/F08	35.1	33.7	1.4	4.0%	94.2	94.2	0.0	0.0%	70	25	70	25	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W8/F08	37.5	36	1.5	4.0%	94.3	94.2	0.0	0.1%	75	25	75	25	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (1)		W9/F08	37.2	35.7	1.5	4.0%	98.2	98.2	0.0	0.0%	70	22	70	22	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN (1)		W10/F08	22.3	20.7	1.6	7.2%	98.2	98.2	0.0	0.0%	37	20	37	20	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W11/F08	35.5	33.9	1.6	4.5%	94.3	94.2	0.0	0.0%	70	26	70	26	0.0%	0.0%
	R10	RESIDENTIAL	LIVING ROOM		W12/F08	37.7	36	1.7	4.5%	94.3	94.2	0.0	0.1%	71	25	70	24	1.4%	4.0%
	R11	RESIDENTIAL	KITCHEN (1)		W13/F08	37.4	35.6	1.8	4.8%	98.1	98.1	0.0	0.0%	68	23	66	21	2.9%	8.7%
	R12	RESIDENTIAL	KITCHEN (1)		W14/F08	22.2	20.4	1.8	8.1%	98.2	98.2	0.0	0.0%	37	20	35	18	5.4%	10.0%
	R13	RESIDENTIAL	LIVING ROOM		W15/F08	29.1	27.3	1.8	6.2%	93.2	93.1	0.0	0.1%	49	17	47	15	4.1%	11.8%
	R16	RESIDENTIAL	LIVING ROOM		W18/F08	29.7	27.9	1.8	6.1%	93.3	93.1	0.0	0.2%	52	23	50	21	3.8%	8.7%
	R17	RESIDENTIAL	KITCHEN (1)		W19/F08	22.4	20.6	1.8	8.0%	98.1	98.1	0.0	0.0%	47	27	45	25	4.3%	7.4%
	R18	RESIDENTIAL	KITCHEN (1)		W20/F08	37.8	35.9	1.9	5.0%	98.2	98.2	0.0	0.0%	75	27	73	25	2.7%	7.4%
	R19	RESIDENTIAL	LIVING ROOM		W21/F08	38.2	36.4	1.8	4.7%	94.3	94.1	0.0	0.2%	74	26	72	24	2.7%	7.7%
	R20	RESIDENTIAL	LIVING ROOM		W22/F08	36.3	34.5	1.8	5.0%	94.3	94.3	0.0	0.0%	62	24	60	22	3.2%	8.3%
	R21	RESIDENTIAL	KITCHEN (1)		W23/F08	23	21.2	1.8	7.8%	98.2	98.2	0.0	0.0%	51	28	49	26	3.9%	7.1%
	R22	RESIDENTIAL	KITCHEN (1)		W24/F08	38.1	36.4	1.7	4.5%	98.2	98.2	0.0	0.0%	77	27	75	25	2.6%	7.4%
	R23	RESIDENTIAL	LIVING ROOM		W25/F08	38.6	37	1.6	4.1%	94.3	94.2	0.0	0.1%	77	27	75	25	2.6%	7.4%
	R24	RESIDENTIAL	LIVING ROOM		W26/F08	36.4	34.8	1.6	4.4%	94.3	94.3	0.0	0.0%	62	23	59	20	4.8%	13.0%
	R25	RESIDENTIAL	KITCHEN (1)		W27/F08	22.8	21.2	1.6	7.0%	98.1	98.1	0.0	0.0%	51	28	48	25	5.9%	10.7%
	R26	RESIDENTIAL	KITCHEN (1)		W28/F08	38.2	36.7	1.5	3.9%	98.2	98.2	0.0	0.0%	78	28	76	26	2.6%	7.1%
	R27	RESIDENTIAL	LIVING ROOM		W29/F08	38.8	37.3	1.5	3.9%	94.3	94.2	0.0	0.1%	79	28	77	26	2.5%	7.1%
	R28	RESIDENTIAL	LIVING ROOM		W30/F08	38.9	37.4	1.5	3.9%	94.3	94.3	0.0	0.0%	80	28	78	26	2.5%	7.1%
	R29	RESIDENTIAL	KITCHEN (1)		W31/F08	39	37.6	1.4	3.6%	98.1	98.1	0.0	0.0%	80	28	78	26	2.5%	7.1%
F09	R1	RESIDENTIAL	UNKNOWN		W1/F09	24.2	24.2	0	0.0%	99.9	99.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F09	39.4	39.4	0	0.0%					31	8	31	8	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
			UNKNOWN		W3/F09	31.2	30.5	0.7	2.2%					52	16	52	16	0.0%	0.0%
	R2	RESIDENTIAL	KITCHEN		W4/F09	38.2	37.2	1	2.6%	98.3	98.3	0.0	0.0%	75	27	75	27	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W5/F09	37.9	36.9	1	2.6%	93.9	93.9	0.0	0.0%	77	27	77	27	0.0%	0.0%
	R4	RESIDENTIAL	LKD		W6/F09	38.4	37.3	1.1	2.9%	99	99	0.0	0.0%	77	27	77	27	0.0%	0.0%
			LKD		W7/F09	37.8	36.9	0.9	2.4%					75	26	75	26	0.0%	0.0%
			LKD		W8/F09	38.6	37.4	1.2	3.1%					75	27	75	27	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN		W9/F09	38.5	37.2	1.3	3.4%	98.3	98.3	0.0	0.0%	75	27	75	27	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W10/F09	38.2	36.8	1.4	3.7%	93.9	93.8	0.0	0.0%	78	27	78	27	0.0%	0.0%
	R7	RESIDENTIAL	LKD		W11/F09	38.6	37.3	1.3	3.4%	99	99	0.0	0.0%	77	27	77	27	0.0%	0.0%
			LKD		W12/F09	38.1	36.9	1.2	3.1%					77	27	77	27	0.0%	0.0%
			LKD		W13/F09	38.8	37.4	1.4	3.6%					75	27	75	27	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN		W14/F09	38.4	37	1.4	3.6%	98.2	98.2	0.0	0.0%	72	26	71	25	1.4%	3.8%
	R9	RESIDENTIAL	LIVING ROOM		W15/F09	37.8	36.3	1.5	4.0%	93.9	93.9	0.0	0.0%	73	26	72	25	1.4%	3.8%
	R10	RESIDENTIAL	LKD		W16/F09	37.6	36.1	1.5	4.0%	99	99	0.0	0.0%	68	24	67	23	1.5%	4.2%
			LKD		W17/F09	36.3	35	1.3	3.6%					66	24	65	23	1.5%	4.2%
			LKD		W18/F09	32.6	31.1	1.5	4.6%					54	18	53	17	1.9%	5.6%
	R13	RESIDENTIAL	LKD		W21/F09	32.8	31.2	1.6	4.9%	98.9	98.9	0.0	0.0%	66	27	65	26	1.5%	3.7%
			LKD		W22/F09	36.4	35.1	1.3	3.6%					70	27	69	26	1.4%	3.7%
			LKD		W23/F09	37.6	36.1	1.5	4.0%					72	27	72	27	0.0%	0.0%
	R14	RESIDENTIAL	LIVING ROOM		W24/F09	37.9	36.4	1.5	4.0%	94.3	94.2	0.0	0.0%	76	27	75	26	1.3%	3.7%
	R15	RESIDENTIAL	KITCHEN (1)		W25/F09	38.6	37.1	1.5	3.9%	98.1	98.1	0.0	0.0%	76	27	75	26	1.3%	3.7%
	R16	RESIDENTIAL	LKD		W26/F09	39	37.6	1.4	3.6%	99	99	0.0	0.0%	77	28	76	27	1.3%	3.6%
			LKD		W27/F09	38.4	37.2	1.2	3.1%					75	28	74	27	1.3%	3.6%
			LKD		W28/F09	38.9	37.5	1.4	3.6%					76	28	75	27	1.3%	3.6%
	R17	RESIDENTIAL	LIVING ROOM		W29/F09	38.5	37.2	1.3	3.4%	94.3	94.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R18	RESIDENTIAL	KITCHEN (1)		W30/F09	38.9	37.5	1.4	3.6%	98.1	98.1	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R19	RESIDENTIAL	LKD		W31/F09	39.1	37.8	1.3	3.3%	99	99	0.0	0.0%	78	28	77	27	1.3%	3.6%
			LKD		W32/F09	38.9	37.6	1.3	3.3%					76	28	75	27	1.3%	3.6%
			LKD		W33/F09	39	37.7	1.3	3.3%					76	28	75	27	1.3%	3.6%
	R20	RESIDENTIAL	LIVING ROOM		W34/F09	38.6	37.4	1.2	3.1%	94.3	94.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R21	RESIDENTIAL	KITCHEN (1)		W35/F09	38.9	37.7	1.2	3.1%	98.2	98.2	0.0	0.0%	80	28	79	27	1.3%	3.6%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
	R22	RESIDENTIAL	KITCHEN (1)		W36/F09	39.2	38	1.2	3.1%	98.3	98.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R23	RESIDENTIAL	LIVING ROOM		W37/F09	39.3	38.1	1.2	3.1%	94.3	94.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
F10	R1	RESIDENTIAL	UNKNOWN		W1/F10	24.6	24.6	0	0.0%	99.9	99.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F10	39.6	39.6	0	0.0%					32	7	32	7	0.0%	0.0%
			UNKNOWN		W3/F10	32.6	31.8	0.8	2.5%					53	17	53	17	0.0%	0.0%
	R2	RESIDENTIAL	LIVING ROOM		W4/F10	37.1	36.2	0.9	2.4%	94.5	94.5	0.0	0.0%	62	22	62	22	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN (1)		W5/F10	22.7	21.7	1	4.4%	98.2	98.2	0.0	0.0%	45	26	45	26	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W6/F10	38.9	37.9	1	2.6%	98.2	98.2	0.0	0.0%	75	27	75	27	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/F10	39.3	38.3	1	2.5%	94.3	94.3	0.0	0.0%	75	26	75	26	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W8/F10	37.1	36	1.1	3.0%	94.3	94.3	0.0	0.0%	61	22	61	22	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (1)		W9/F10	22.6	21.6	1	4.4%	98.2	98.2	0.0	0.0%	46	26	46	26	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN (1)		W10/F10	38.9	37.8	1.1	2.8%	98.2	98.2	0.0	0.0%	76	27	76	27	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W11/F10	39.3	38.2	1.1	2.8%	94.3	94.3	0.0	0.0%	75	26	75	26	0.0%	0.0%
	R10	RESIDENTIAL	LIVING ROOM		W12/F10	37	35.9	1.1	3.0%	94.3	94.3	0.0	0.0%	61	22	61	22	0.0%	0.0%
	R11	RESIDENTIAL	KITCHEN (1)		W13/F10	22.1	20.9	1.2	5.4%	98.1	98.1	0.0	0.0%	41	25	41	25	0.0%	0.0%
	R12	RESIDENTIAL	KITCHEN (1)		W14/F10	37.5	36.3	1.2	3.2%	98.2	98.2	0.0	0.0%	65	24	65	24	0.0%	0.0%
	R13	RESIDENTIAL	LIVING ROOM		W15/F10	32.6	31.4	1.2	3.7%	93.2	93.2	0.0	0.0%	52	17	52	17	0.0%	0.0%
	R16	RESIDENTIAL	LIVING ROOM		W18/F10	32.6	31.4	1.2	3.7%	93.3	93.3	0.0	0.0%	67	27	67	27	0.0%	0.0%
	R17	RESIDENTIAL	KITCHEN (1)		W19/F10	37.4	36.3	1.1	2.9%	98.1	98.1	0.0	0.0%	68	24	68	24	0.0%	0.0%
	R18	RESIDENTIAL	KITCHEN (1)		W20/F10	22.1	21	1.1	5.0%	98.2	98.2	0.0	0.0%	34	20	34	20	0.0%	0.0%
	R19	RESIDENTIAL	LIVING ROOM		W21/F10	37	35.8	1.2	3.2%	94.3	94.2	0.0	0.0%	72	27	72	27	0.0%	0.0%
	R20	RESIDENTIAL	LIVING ROOM		W22/F10	39.3	38.2	1.1	2.8%	94.3	94.3	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R21	RESIDENTIAL	KITCHEN (1)		W23/F10	38.9	37.8	1.1	2.8%	98.2	98.2	0.0	0.0%	72	25	71	24	1.4%	4.0%
	R22	RESIDENTIAL	KITCHEN (1)		W24/F10	22.6	21.5	1.1	4.9%	98.2	98.2	0.0	0.0%	36	21	35	20	2.8%	4.8%
	R23	RESIDENTIAL	LIVING ROOM		W25/F10	37.1	36.1	1	2.7%	94.3	94.2	0.0	0.0%	76	28	75	27	1.3%	3.6%
	R24	RESIDENTIAL	LIVING ROOM		W26/F10	39.4	38.4	1	2.5%	94.3	94.3	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R25	RESIDENTIAL	KITCHEN (1)		W27/F10	39	38	1	2.6%	98.1	98.1	0.0	0.0%	73	25	72	24	1.4%	4.0%
	R26	RESIDENTIAL	KITCHEN (1)		W28/F10	22.9	21.9	1	4.4%	98.2	98.2	0.0	0.0%	37	21	36	20	2.7%	4.8%
	R27	RESIDENTIAL	LIVING ROOM		W29/F10	37.1	36.1	1	2.7%	94.3	94.3	0.0	0.0%	76	28	75	27	1.3%	3.6%
	R28	RESIDENTIAL	LIVING ROOM		W30/F10	39.5	38.5	1	2.5%	94.3	94.3	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R29	RESIDENTIAL	KITCHEN (1)		W31/F10	39.6	38.7	0.9	2.3%	98.1	98.1	0.0	0.0%	80	28	79	27	1.3%	3.6%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
F11	R1	RESIDENTIAL	UNKNOWN		W1/F11	25.7	25.7	0	0.0%	99.9	99.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F11	39.6	39.6	0	0.0%					35	7	35	7	0.0%	0.0%
			UNKNOWN		W3/F11	34.2	33.4	0.8	2.3%					57	17	57	17	0.0%	0.0%
	R2	RESIDENTIAL	LKD		W4/F11	39.5	38.8	0.7	1.8%	99	99	0.0	0.0%	77	27	77	27	0.0%	0.0%
			LKD		W5/F11	39.4	38.7	0.7	1.8%					77	27	77	27	0.0%	0.0%
			LKD		W6/F11	39.5	38.8	0.7	1.8%					77	27	77	27	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W7/F11	39.5	38.8	0.7	1.8%	94.3	94.3	0.0	0.0%	77	27	77	27	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W8/F11	39.5	38.7	0.8	2.0%	98.1	98.1	0.0	0.0%	77	27	77	27	0.0%	0.0%
	R5	RESIDENTIAL	LKD		W9/F11	39.6	38.8	0.8	2.0%	99	99	0.0	0.0%	79	27	79	27	0.0%	0.0%
			LKD		W10/F11	39.4	38.7	0.7	1.8%					79	27	79	27	0.0%	0.0%
			LKD		W11/F11	39.6	38.8	0.8	2.0%					79	27	79	27	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W12/F11	39.5	38.7	0.8	2.0%	94.3	94.3	0.0	0.0%	79	27	79	27	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (1)		W13/F11	39.5	38.7	0.8	2.0%	98.2	98.2	0.0	0.0%	78	27	78	27	0.0%	0.0%
	R8	RESIDENTIAL	LKD		W14/F11	39.4	38.5	0.9	2.3%	99	99	0.0	0.0%	76	26	76	26	0.0%	0.0%
			LKD		W15/F11	39.1	38.2	0.9	2.3%					74	26	74	26	0.0%	0.0%
			LKD		W16/F11	39	38.2	0.8	2.1%					72	25	72	25	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W17/F11	37.9	37.1	0.8	2.1%	94.3	94.3	0.0	0.0%	67	24	67	24	0.0%	0.0%
	R10	RESIDENTIAL	KITCHEN (1)		W18/F11	31.2	30.3	0.9	2.9%	98.2	98.2	0.0	0.0%	50	15	50	15	0.0%	0.0%
	R13	RESIDENTIAL	KITCHEN (1)		W22/F11	31.1	30.2	0.9	2.9%	98.2	98.2	0.0	0.0%	62	25	62	25	0.0%	0.0%
	R14	RESIDENTIAL	LIVING ROOM		W23/F11	37.9	37	0.9	2.4%	94.3	94.3	0.0	0.0%	74	27	74	27	0.0%	0.0%
	R15	RESIDENTIAL	LKD		W24/F11	38.9	38.1	0.8	2.1%	99	99	0.0	0.0%	76	27	76	27	0.0%	0.0%
			LKD		W25/F11	39	38.1	0.9	2.3%					76	27	76	27	0.0%	0.0%
			LKD		W26/F11	39.3	38.4	0.9	2.3%					76	27	76	27	0.0%	0.0%
	R16	RESIDENTIAL	KITCHEN (1)		W27/F11	39.5	38.6	0.9	2.3%	98.2	98.2	0.0	0.0%	79	28	79	28	0.0%	0.0%
	R17	RESIDENTIAL	LIVING ROOM		W28/F11	39.5	38.7	0.8	2.0%	94.3	94.3	0.0	0.0%	79	28	79	28	0.0%	0.0%
	R18	RESIDENTIAL	LKD		W29/F11	39.6	38.8	0.8	2.0%	99.1	99.1	0.0	0.0%	80	28	80	28	0.0%	0.0%
			LKD		W30/F11	39.4	38.6	0.8	2.0%					80	28	79	27	1.3%	3.6%
			LKD		W31/F11	39.6	38.8	0.8	2.0%					80	28	80	28	0.0%	0.0%
	R19	RESIDENTIAL	KITCHEN (1)		W32/F11	39.6	38.8	0.8	2.0%	98.3	98.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R20	RESIDENTIAL	LIVING ROOM		W33/F11	39.6	38.8	0.8	2.0%	94.3	94.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R21	RESIDENTIAL	LKD		W34/F11	39.6	38.9	0.7	1.8%	99	99	0.0	0.0%	80	28	80	28	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
			LKD		W35/F11	39.5	38.7	0.8	2.0%					80	28	79	27	1.3%	3.6%
			LKD		W36/F11	39.6	38.9	0.7	1.8%					80	28	80	28	0.0%	0.0%
	R22	RESIDENTIAL	KITCHEN (1)		W37/F11	39.6	38.9	0.7	1.8%	98.3	98.3	0.0	0.0%	80	28	80	28	0.0%	0.0%
	R23	RESIDENTIAL	LIVING ROOM		W38/F11	39.6	38.9	0.7	1.8%	94.3	94.3	0.0	0.0%	80	28	80	28	0.0%	0.0%
F12	R1	RESIDENTIAL	UNKNOWN		W1/F12	31.5	31.5	0	0.0%	100	100	0.0	0.0%	8	8	8	8	0.0%	0.0%
			UNKNOWN		W2/F12	39.6	39.6	0	0.0%					32	7	32	7	0.0%	0.0%
			UNKNOWN		W3/F12	37.4	36.9	0.5	1.3%					74	22	74	22	0.0%	0.0%

FOUNTAIN COURT																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	26.6	20	6.6	24.8%	85.6	54.9	4.7	35.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	25.8	19.1	6.7	26.0%	96.3	77.7	3.0	19.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F00	24.9	18.2	6.7	26.9%	97.6	88.9	1.7	8.9%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F00	24.2	17.5	6.7	27.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F00	23	16.5	6.5	28.3%	88.3	76.8	1.7	13.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F00	21.3	14.3	7	32.9%	75.9	61.2	2.0	19.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F00	19.5	12.5	7	35.9%	60.1	43	2.5	28.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F00	18.6	11.4	7.2	38.7%	98.9	96.9	0.3	2.0%	18	4	18	4	22.2%	0.0%
			UNKNOWN		W9/F00	22.1	16.1	6	27.1%					41	12	39	12	4.9%	0.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F00	23.4	17.2	6.2	26.5%	98.5	87.9	0.9	10.7%	43	13	40	12	7.0%	7.7%
	R9	RESIDENTIAL	UNKNOWN		W11/F00	24.5	18.3	6.2	25.3%	98.6	81.5	2.0	17.4%	44	13	42	13	4.5%	0.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	28.4	20.9	7.5	26.4%	88.3	53.9	5.3	39.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.5	19.7	7.8	28.4%	97.2	77.2	3.2	20.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F01	26.9	18.9	8	29.7%	98.1	88.5	1.9	9.7%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F01	26.3	18.2	8.1	30.8%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F01	24.9	16.8	8.1	32.5%	89.8	76.7	1.9	14.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F01	23.8	15	8.8	37.0%	77.5	60.9	2.3	21.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F01	22.4	13.2	9.2	41.1%	61.9	42.3	2.8	31.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F01	21.6	12.1	9.5	44.0%	99	96.9	0.3	2.1%	18	4	14	4	22.2%	0.0%
			UNKNOWN		W9/F01	24.9	17.1	7.8	31.3%					43	13	40	13	7.0%	0.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F01	26.1	18.3	7.8	29.9%	98.8	87.2	1.0	11.7%	45	13	40	12	11.1%	7.7%
	R9	RESIDENTIAL	UNKNOWN		W11/F01	27	19.5	7.5	27.8%	98.6	80.7	2.1	18.1%	47	14	42	14	10.6%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: BSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

FOUNTAIN COURT (CONTINUED)																			
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.7	21.6	8.1	27.3%	95.1	54.1	6.3	43.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	18	11.4	6.6	36.7%	99.1	76.2	3.7	23.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F02	28.7	19.3	9.4	32.8%	99.4	88.6	2.2	10.8%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F02	28	18.6	9.4	33.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F02	14.4	8.5	5.9	41.0%	92.2	76.1	2.3	17.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F02	26.4	15.2	11.2	42.4%	86.7	60.8	3.5	29.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F02	26	14	12	46.2%	76.5	43.2	4.8	43.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F02	25.3	12.9	12.4	49.0%	99.5	96.9	0.4	2.5%	21	4	13	4	38.1%	0.0%
			UNKNOWN		W9/F02	28	18.2	9.8	35.0%					47	13	39	13	17.0%	0.0%
F03	R8	RESIDENTIAL	UNKNOWN		W10/F02	29	19.5	9.5	32.8%	99.5	88.1	1.0	11.5%	49	14	41	13	16.3%	7.1%
	R9	RESIDENTIAL	UNKNOWN		W11/F02	29.7	20.6	9.1	30.6%	98.7	81.6	2.0	17.4%	51	16	45	16	11.8%	0.0%
	R1	RESIDENTIAL	UNKNOWN		W1/F03	32.8	23.7	9.1	27.7%	95.9	56.9	6.0	40.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F03	32.7	22.7	10	30.6%	99.2	78.8	3.3	20.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F03	32.4	21.5	10.9	33.6%	99.4	89.5	2.0	10.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F03	32.1	20.8	11.3	35.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F03	31.6	19.6	12	38.0%	99.5	77.2	3.2	22.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F03	30.8	17.2	13.6	44.2%	98.3	62	4.9	36.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F03	30	15	15	50.0%	98.3	44	7.9	55.2%	N/A	N/A	N/A	N/A	N/A	N/A
F04	R7	RESIDENTIAL	UNKNOWN		W8/F03	29.6	13.8	15.8	53.4%	99.5	97	0.4	2.5%	24	5	14	5	41.7%	0.0%
			UNKNOWN		W9/F03	31.5	19.4	12.1	38.4%					51	16	43	16	15.7%	0.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F03	32.1	20.7	11.4	35.5%	99.5	88.8	0.9	10.8%	54	17	44	16	18.5%	5.9%
	R9	RESIDENTIAL	UNKNOWN		W11/F03	32.6	21.9	10.7	32.8%	98.7	82.5	1.9	16.4%	53	16	46	16	13.2%	0.0%
	R1	RESIDENTIAL	UNKNOWN		W1/F04	34.5	25	9.5	27.5%	95.9	60	5.5	37.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F04	34.5	24	10.5	30.4%	99.2	80.2	3.1	19.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F04	34.5	22.8	11.7	33.9%	99.4	90.3	1.8	9.2%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F04	34.5	22	12.5	36.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F04	34.4	20.7	13.7	39.8%	99.5	78.1	3.1	21.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F04	34	18.3	15.7	46.2%	98.3	62.7	4.8	36.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F04	33.8	16.1	17.7	52.4%	98.3	44.9	7.7	54.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F04	33.6	14.8	18.8	56.0%	99.6	97.1	0.4	2.5%	29	5	14	5	51.7%	16.2%
			UNKNOWN		W9/F04	34.7	20.6	14.1	40.6%					56	18	43	17	23.2%	5.6%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

FOUNTAIN COURT (CONTINUED)																			
	R8	RESIDENTIAL	UNKNOWN		W10/F04	35	22	13	37.1%	99.5	90.1	0.8	9.5%	57	18	46	17	19.3%	5.6%
	R9	RESIDENTIAL	UNKNOWN		W11/F04	35.1	23.3	11.8	33.6%	98.7	83.7	1.7	15.2%	59	19	50	19	15.3%	0.0%
F05	R1	RESIDENTIAL	UNKNOWN		W1/F05	35.8	26.4	9.4	26.3%	95.9	62.7	5.1	34.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F05	35.8	25.3	10.5	29.3%	99.2	82.1	2.8	17.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F05	35.9	24.1	11.8	32.9%	99.4	90.9	1.7	8.5%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F05	35.9	23.2	12.7	35.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F05	35.9	21.8	14.1	39.3%	99.5	79	3.0	20.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F05	35.9	19.4	16.5	46.0%	98.3	63.6	4.7	35.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F05	36	17.2	18.8	52.2%	98.3	46.5	7.5	52.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F05	36	15.9	20.1	55.8%	99.6	97.1	0.4	2.5%	32	7	16	5	50.0%	28.6%
			UNKNOWN		W9/F05	36.7	21.9	14.8	40.3%					59	20	44	18	25.4%	10.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F05	36.6	23.2	13.4	36.6%	99.5	91.4	0.7	8.2%	60	20	46	18	23.3%	10.0%
	R9	RESIDENTIAL	UNKNOWN		W11/F05	36.6	24.5	12.1	33.1%	98.7	85.6	1.5	13.3%	60	19	50	19	16.7%	0.0%
F06	R1	RESIDENTIAL	UNKNOWN		W1/F06	36.7	27.7	9	24.5%	95.9	66.5	4.5	30.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F06	36.7	26.6	10.1	27.5%	99.2	84.8	2.3	14.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F06	36.7	25.3	11.4	31.1%	99.4	92	1.5	7.5%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F06	36.8	24.4	12.4	33.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F06	36.8	22.9	13.9	37.8%	99.5	80.2	2.8	19.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F06	36.8	20.6	16.2	44.0%	98.3	65	4.5	33.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F06	36.8	18.3	18.5	50.3%	98.3	48.2	7.3	50.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F06	36.9	17	19.9	53.9%	99.6	97.3	0.4	2.3%	32	7	16	5	50.0%	28.6%
			UNKNOWN		W9/F06	37.5	23	14.5	38.7%					59	21	45	19	23.7%	9.5%
	R8	RESIDENTIAL	UNKNOWN		W10/F06	37.4	24.4	13	34.8%	99.5	93.5	0.5	6.0%	59	21	46	19	22.0%	9.5%
	R9	RESIDENTIAL	UNKNOWN		W11/F06	37.4	25.7	11.7	31.3%	98.7	88.8	1.2	10.1%	60	21	50	21	16.7%	0.0%
F07	R1	RESIDENTIAL	UNKNOWN		W1/F07	35.3	27	8.3	23.5%	95.8	69.4	4.1	27.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F07	34.9	25.5	9.4	26.9%	99.1	86.8	2.0	12.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F07	34.5	23.8	10.7	31.0%	99.4	93	1.3	6.4%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F07	34.2	22.6	11.6	33.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F07	33.7	20.6	13.1	38.9%	99.5	80.5	2.7	19.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F07	33.2	17.8	15.4	46.4%	98.3	64.6	4.6	34.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F07	32.6	15	17.6	54.0%	98.2	47.4	7.4	51.8%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

FOUNTAIN COURT (CONTINUED)																			
	R7	RESIDENTIAL	UNKNOWN		W8/F07	32.3	13.2	19.1	59.1%	99.5	97.9	0.3	1.7%	24	7	9	5	62.5%	28.6%
			UNKNOWN		W9/F07	35.1	21.5	13.6	38.7%					53	20	39	18	26.4%	10.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F07	35	22.8	12.2	34.9%	99.5	95.6	0.3	4.0%	53	20	40	18	24.5%	10.0%
	R9	RESIDENTIAL	UNKNOWN		W11/F07	35	24.1	10.9	31.1%	98.7	90.8	0.9	7.9%	54	21	44	21	18.5%	0.0%
F08	R1	RESIDENTIAL	UNKNOWN		W1/F08	37.9	30.5	7.4	19.5%	83.5	56	3.9	32.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F08	38.1	29.6	8.5	22.3%	96.4	77.6	2.8	19.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F08	38	28.3	9.7	25.5%	97.6	88.1	1.8	9.7%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F08	38	27.5	10.5	27.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F08	38.2	26.2	12	31.4%	97.6	77.4	2.7	20.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F08	38.1	24	14.1	37.0%	93.8	62.7	3.9	33.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F08	38.1	21.8	16.3	42.8%	93.7	39.2	7.3	58.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F08	38.2	20.5	17.7	46.3%	98	96.6	0.2	1.4%	61	6	17	4	45.2%	11.5%
			UNKNOWN		W9/F08	39.2	26.8	12.4	31.6%					62	21	49	19	21.0%	9.5%
	R8	RESIDENTIAL	UNKNOWN		W10/F08	39.2	28.1	11.1	28.3%	99.9	97.5	0.2	2.4%	62	21	49	19	21.0%	9.5%
	R9	RESIDENTIAL	UNKNOWN		W11/F08	39.2	29.4	9.8	25.0%	99.8	89.8	1.1	10.0%	62	21	54	21	12.9%	0.0%

89-110 COLLESHILL FLATS																			
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	11.2	5.1	6.1	54.5%	83.1	34.2	4.6	58.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F01	5.5	4	1.5	27.3%	40.6	37.4	0.3	7.8%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F01	8.8	7	1.8	20.5%	99.4	61.5	1.6	38.1%	0	0	0	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F01	27.7	11.8	15.9	57.4%					6	6	4	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F01	12.1	3.1	9	74.4%	81.7	16.1	6.5	80.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F01	12	3.2	8.8	73.3%	85	20.4	6.4	76.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F01	25.6	10.1	15.5	60.5%	99.5	60.9	1.7	38.8%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F01	16.9	6.2	10.7	63.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F01	10.7	4.2	6.5	60.7%	50.4	35.2	1.5	30.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	13	4.8	8.2	63.1%	92.6	23	6.5	75.2%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	12.4	6.3	6.1	49.2%	89.7	39.9	4.7	55.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F02	6.3	4.9	1.4	22.2%	42.1	40	0.2	5.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F02	10	8.3	1.7	17.0%	99.4	68.5	1.3	31.0%	1	0	1	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F02	29.8	13.6	16.2	54.4%					6	6	4	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: BSDHA

UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

89-110 COLLESHILL FLATS (CONTINUED)																			
	R6	RESIDENTIAL	BEDROOM		W7/F02	12.9	3.9	9	69.8%	85.4	20.5	6.5	76.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F02	12.8	4	8.8	68.8%	87.1	24.8	6.2	71.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F02	27.6	11.8	15.8	57.2%	99.5	72.9	1.2	26.8%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F02	19.1	7.9	11.2	58.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F02	12.6	5.3	7.3	57.9%	60	39.3	2.0	34.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	14.5	6	8.5	58.6%	95.1	28.7	6.2	69.8%	N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	14.1	8.3	5.8	41.1%	92.8	48.1	4.2	48.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F03	8.1	6.8	1.3	16.0%	47.9	47	0.1	1.9%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F03	12.2	10.6	1.6	13.1%	99.4	84.9	0.6	14.6%	1	0	1	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F03	31.9	15.9	16	50.2%					6	0	6	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F03	13.1	4.4	8.7	66.4%	87	26.7	6.0	69.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F03	13.2	4.6	8.6	65.2%	87.3	29.9	5.7	65.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F03	29.9	13.9	16	53.5%	99.5	92	0.3	7.5%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F03	21.9	10.7	11.2	51.1%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F03	15.1	7.5	7.6	50.3%	69	46.4	2.2	32.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	16.5	7.9	8.6	52.1%	95.7	37.3	5.5	61.0%	N/A	N/A	N/A	N/A	N/A	N/A
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	17.2	11.8	5.4	31.4%	95.8	61.3	3.2	36.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F04	11.9	10.8	1.1	9.2%	69.3	69.1	0.0	0.4%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F04	16.9	15.6	1.3	7.7%	99.4	99.4	0.0	0.0%	6	0	6	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F04	34	18.7	15.3	45.0%					8	0	8	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F04	8.6	0.6	8	93.0%	86.8	10.2	7.6	88.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F04	8.8	0.9	7.9	89.8%	87.1	19.1	6.8	78.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F04	32.4	16.6	15.8	48.8%	99.6	98.9	0.0	0.6%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F04	25.9	16.3	9.6	37.1%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F04	18.9	12.5	6.4	33.9%	82.1	69.8	1.2	15.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	19.4	11.1	8.3	42.8%	96.8	50.7	4.3	47.7%	N/A	N/A	N/A	N/A	N/A	N/A
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	25.7	19.6	6.1	23.7%	98.9	94.8	0.3	4.2%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W2/F05	31.8	24.6	7.2	22.6%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W3/F05	29.5	16.4	13.1	44.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	32.3	20.7	11.6	35.9%	100	92.4	0.6	7.6%	8	0	8	0	0.0%	0.0%
			UNKNOWN-RESI		W5/F05	28.6	27.4	1.2	4.2%					39	2	39	2	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

89-110 COLLESHILL FLATS (CONTINUED)																			
			UNKNOWN-RESI		W6/F05	20.4	19.4	1	4.9%					10	0	10	0	0.0%	0.0%

176 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	19.5	12.9	6.6	33.8%	76.5	31.3	27.8	59.1%	34	8	21	3	38.2%	62.5%
			UNKNOWN		W2/B01	0	0	0	-					0	0	0	0	0.0%	0.0%
			UNKNOWN		W3/B01	17.3	11.5	5.8	33.5%					33	7	21	3	36.4%	57.1%
			UNKNOWN		W4/B01	14.7	10.3	4.4	29.9%					35	9	25	4	28.6%	55.6%
			UNKNOWN		W5/B01	8.5	8.5	0	0.0%					6	1	6	1	0.0%	0.0%
F00	R1	RESIDENTIAL	BEDROOM		W1/F00	22.4	16.1	6.3	28.1%	95.3	73	3.4	23.4%	39	9	27	4	30.8%	55.6%
	R2	RESIDENTIAL	LIVING ROOM		W2/F00	16.6	12.5	4.1	24.7%	88.4	69.5	3.6	21.3%	41	10	31	5	24.4%	50.0%
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	23.8	17.8	6	25.2%	93.1	69	3.8	25.9%	35	6	23	2	34.3%	66.7%
	R2	RESIDENTIAL	BEDROOM		W2/F01	26.1	20.4	5.7	21.8%	93.3	70.2	3.6	24.7%	47	11	38	7	19.1%	36.4%
	R3	RESIDENTIAL	LIVING ROOM		W3/F01	19.8	16.1	3.7	18.7%	77.6	59.1	3.5	23.9%	48	15	42	11	12.5%	26.7%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	28.2	22.7	5.5	19.5%	86.8	54.8	6.1	36.8%	46	8	36	4	21.7%	50.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	30.3	25	5.3	17.5%	89.5	67.4	3.4	24.8%	59	17	48	12	18.6%	29.4%
	R3	RESIDENTIAL	LKD		W3/F02	26.9	23.1	3.8	14.1%	70.5	43.6	7.8	38.2%	56	18	51	14	8.9%	22.2%

174 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	17.6	12.1	5.5	31.3%	58.8	17.2	7.2	70.7%	26	1	17	0	34.6%	100.0%
	R2	RESIDENTIAL	UNKNOWN		W2/B01	12	9.8	2.2	18.3%	55	14.6	6.3	73.5%	27	6	22	5	18.5%	16.7%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.4	15.2	8.2	35.0%	96.6	38.4	12.8	60.2%	48	14	27	6	43.8%	57.1%
			UNKNOWN		W2/F00	23.4	15.1	8.3	35.5%					46	12	28	6	39.1%	50.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.6	17.9	7.7	30.1%	73.7	44.7	3.5	39.4%	48	14	30	7	37.5%	50.0%
	R3	RESIDENTIAL	UNKNOWN		W2/F01	25.7	17.9	7.8	30.4%	95.5	43.3	10.8	54.6%	51	15	31	7	39.2%	53.3%
			UNKNOWN		W3/F01	25.8	17.8	8	31.0%					51	13	30	7	41.2%	46.2%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28	21	7	25.0%	74.3	46.8	3.3	37.0%	56	16	38	9	32.1%	43.8%
	R3	RESIDENTIAL	UNKNOWN		W2/F02	28.1	21	7.1	25.3%	95	47.6	9.8	49.9%	53	16	39	9	26.4%	43.8%
			UNKNOWN		W3/F02	28.2	21	7.2	25.5%					53	15	39	9	26.4%	40.0%

172 MOZART TERRACE																			
B01	R1	RESIDENTIAL	DINING ROOM		W1/B01	18.2	12.3	5.9	32.4%	74.7	20	8.7	73.2%	30	1	17	0	43.3%	100.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

172 MOZART TERRACE (CONTINUED)																			
			DINING ROOM		W2/B01	16	8.5	7.5	46.9%					29	6	13	2	55.2%	66.7%
	R2	RESIDENTIAL	LIVING ROOM		W3/B01	20.2	12.9	7.3	36.1%	83.5	21	13.1	74.8%	39	7	24	5	38.5%	28.6%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.7	15	8.7	36.7%	96.6	92.3	1.3	4.5%	45	11	22	4	51.1%	63.6%
			UNKNOWN		W2/F00	24	15.1	8.9	37.1%					44	10	23	4	47.7%	60.0%
			UNKNOWN		W5/F00	22.7	22.7	0	0.0%					6			0	0.0%	0.0%
			UNKNOWN		W6/F00	27.4	27.4	0	0.0%					8	0	8	0	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W3/F00	24.4	15.3	9.1	37.3%	93.1	29.2	10.6	68.6%	46	13	27	6	41.3%	53.8%
			BEDROOM		W4/F00	24.5	15.4	9.1	37.1%					46	12	27	6	41.3%	50.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.5	17.2	8.3	32.5%	97	32.6	8.3	66.4%	48	12	26	5	45.8%	58.3%
			UNKNOWN		W2/F01	25.8	17.3	8.5	32.9%					47	11	28	5	40.4%	54.5%
	R2	RESIDENTIAL	UNKNOWN		W3/F01	26	17.4	8.6	33.1%	85.4	30	5.1	64.9%	50	13	32	7	36.0%	46.2%
	R3	RESIDENTIAL	UNKNOWN		W4/F01	26.1	17.4	8.7	33.3%	92.7	28.7	10.6	69.1%	50	14	31	7	38.0%	50.0%
			UNKNOWN		W5/F01	26.2	17.5	8.7	33.2%					49	13	30	7	38.8%	46.2%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.5	19.8	7.7	28.0%	90.4	36.5	9.9	59.6%	52	15	33	7	36.5%	53.3%
			UNKNOWN		W2/F02	27.8	19.9	7.9	28.4%					50	13	32	7	36.0%	46.2%
	R2	RESIDENTIAL	UNKNOWN		W3/F02	28.1	20	8.1	28.8%	93.5	34.6	12.2	63.0%	55	16	37	9	32.7%	43.8%
			UNKNOWN		W4/F02	28.2	20.1	8.1	28.7%					53	15	37	9	30.2%	40.0%

170 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18	12.2	5.8	32.2%	98.9	31.8	8.4	67.8%	21	1	10	0	52.4%	100.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	21.8	14.7	7.1	32.6%	99.1	37.4	7.7	62.3%	27	4	10	0	63.0%	100.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	20.4	14.4	6	29.4%	98.5	48.4	9.1	50.8%	21	2	12	0	42.9%	100.0%
			UNKNOWN		W2/F01	24.6	17.9	6.7	27.2%					34	5	19	0	44.1%	100.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	23.5	18.1	5.4	23.0%	98.7	49.4	9.0	49.9%	25	3	19	1	24.0%	66.7%
			UNKNOWN		W2/F02	28.1	22	6.1	21.7%					44	8	35	4	20.5%	50.0%

168 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	16	11.8	4.2	26.2%	92.3	32.3	11.1	65.0%	16	0	8	0	50.0%	0.0%
			UNKNOWN		W2/B01	17.8	13.1	4.7	26.4%					31	4	21	3	32.3%	25.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	24.7	17.1	7.6	30.8%	95.4	34.3	10.4	64.0%	39	8	25	4	35.9%	50.0%
			UNKNOWN		W3/F00	24.8	17.4	7.4	29.8%					40	10	26	4	35.0%	60.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS	LOSS %	EX.		PR.		LOSS %	
												SQM		ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

168 MOZART TERRACE (CONTINUED)																			
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	26.7	19.5	7.2	27.0%	93.3	50.3	3.8	46.1%	45	9	29	2	35.6%	77.8%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.1	20	7.1	26.2%	98.7	50.8	7.8	48.5%	49	12	31	4	36.7%	66.7%
			UNKNOWN		W3/F01	27.2	20.3	6.9	25.4%					52	14	33	5	36.5%	64.3%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.6	23	6.6	22.3%	94.7	54.1	3.6	42.9%	55	15	44	10	20.0%	33.3%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	29.6	23.2	6.4	21.6%	98.4	54.4	7.1	44.7%	58	17	46	12	20.7%	29.4%
			UNKNOWN		W3/F02	29.6	23.3	6.3	21.3%					58	17	45	11	22.4%	35.3%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	31.7	26.3	5.4	17.0%	93.2	57.2	3.1	38.6%	59	18	52	14	11.9%	22.2%
	R2	RESIDENTIAL	UNKNOWN		W2/F03	31.7	26.4	5.3	16.7%	97.5	57.8	6.4	40.7%	60	19	51	14	15.0%	26.3%
			UNKNOWN		W3/F03	31.6	26.4	5.2	16.5%					62	20	51	14	17.7%	30.0%

166 MOZART TERRACE																			
B01	R1	RESIDENTIAL	LIVING ROOM		W1/B01	14.6	11.1	3.5	24.0%	67.2	24.9	11.2	62.9%	16	1	8	0	50.0%	100.0%
			LIVING ROOM		W2/B01	17.8	13.1	4.7	26.4%					33	4	22	2	33.3%	50.0%
			LIVING ROOM		W3/B01	16.4	11.9	4.5	27.4%					36	6	24	3	33.3%	50.0%
F00	R2	RESIDENTIAL	DINING ROOM		W2/F00	24.8	18	6.8	27.4%	87.7	41.2	10.3	53.0%	46	12	27	4	41.3%	66.7%
			DINING ROOM		W3/F00	24.7	18.1	6.6	26.7%					45	11	27	5	40.0%	54.5%
F01	R2	RESIDENTIAL	DRAWING ROOM		W1/F01	27.3	20.7	6.6	24.2%	98.4	59.7	10.9	39.3%	52	16	37	8	28.8%	50.0%
			DRAWING ROOM		W2/F01	27.2	20.8	6.4	23.5%					52	17	38	9	26.9%	47.1%
			DRAWING ROOM		W3/F01	27.1	21	6.1	22.5%					53	16	38	9	28.3%	43.8%
F02	R2	RESIDENTIAL	BEDROOM		W1/F02	29.7	23.9	5.8	19.5%	99.1	93.1	1.0	6.0%	58	17	48	13	17.2%	23.5%
			BEDROOM		W2/F02	29.6	24	5.6	18.9%					58	17	48	13	17.2%	23.5%
			BEDROOM		W3/F02	29.5	24.1	5.4	18.3%					59	18	48	13	18.6%	27.8%
F03	R1	RESIDENTIAL	DRESSING ROOM		W1/F03	31.4	26.7	4.7	15.0%	89	87.9	0.1	1.2%	60	19	53	14	11.7%	26.3%

164 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	14.3	9.6	4.7	32.9%	64.9	30	8.6	53.8%	25	2	11	0	56.0%	100.0%
			UNKNOWN		W2/B01	10.5	10.5	0	0.0%					22	3	22	3	0.0%	0.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	24.7	18.4	6.3	25.5%	95.6	50.6	8.1	47.1%	48	13	31	8	35.4%	38.5%
			UNKNOWN		W3/F00	24.7	18.5	6.2	25.1%					47	13	33	8	29.8%	38.5%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	27	21.1	5.9	21.9%	91.1	65.2	1.9	28.5%	52	15	38	9	26.9%	40.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27	21.2	5.8	21.5%	99.2	69	5.1	30.4%	54	16	39	9	27.8%	43.8%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

164 MOZART TERRACE (CONTINUED)																			
			UNKNOWN		W3/F01	27	21.4	5.6	20.7%					54	15	39	9	27.8%	40.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.4	24.2	5.2	17.7%	88.8	63.8	1.8	28.1%	57	16	51	14	10.5%	12.5%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	29.4	24.4	5	17.0%	99.2	68.3	5.2	31.1%	57	16	50	14	12.3%	12.5%
			UNKNOWN		W3/F02	29.4	24.5	4.9	16.7%					59	17	51	14	13.6%	17.6%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	29.8	25.5	4.3	14.4%	86.1	59.8	3.2	30.5%	53	17	47	12	11.3%	29.4%
	R2	RESIDENTIAL	UNKNOWN		W2/F03	29.8	25.7	4.1	13.8%	85.6	55.8	3.6	34.8%	54	18	47	12	13.0%	33.3%

162 MOZART TERRACE																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	17	14.3	2.7	15.9%	71.3	37.6	8.8	47.2%	28	2	19	0	32.1%	100.0%
			BEDROOM		W2/B01	14.9	12.5	2.4	16.1%					33	6	27	5	18.2%	16.7%
F00	R2	RESIDENTIAL	DINING ROOM		W2/F00	24.7	18.8	5.9	23.9%	94.4	53.1	8.6	43.7%	51	14	32	8	37.3%	42.9%
			DINING ROOM		W3/F00	24.8	18.9	5.9	23.8%					52	15	32	8	38.5%	46.7%
F01	R1	RESIDENTIAL	DRAWING ROOM		W1/F01	27.1	21.6	5.5	20.3%	99	79.6	5.1	19.6%	53	15	39	9	26.4%	40.0%
			DRAWING ROOM		W2/F01	27.2	21.8	5.4	19.9%					53	15	39	9	26.4%	40.0%
			DRAWING ROOM		W3/F01	27.3	22	5.3	19.4%					54	16	41	9	24.1%	43.8%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	29.5	24.7	4.8	16.3%	98.5	83.8	3.8	14.9%	60	17	52	14	13.3%	17.6%
			BEDROOM		W2/F02	29.6	24.9	4.7	15.9%					59	17	51	14	13.6%	17.6%
			BEDROOM		W3/F02	29.8	25.2	4.6	15.4%					59	17	52	14	11.9%	17.6%

102 EATON TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	4.7	4.7	0	0.0%	56.6	35.5	4.1	37.3%	1	0	1	0	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/B01	9	9	0	0.0%	56.5	56.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/B01	9.1	9.1	0	0.0%	57	57	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	14.3	11	3.3	23.1%	86.7	60.9	3.9	29.7%	24	3	17	0	29.2%	100.0%
	R3	RESIDENTIAL	UNKNOWN		W3/F00	14.4	12.8	1.6	11.1%	99.1	99	0.0	0.1%	38	13	31	8	18.4%	38.5%
			UNKNOWN		W4/F00	22.5	18.5	4	17.8%					50	14	41	10	18.0%	28.6%
			UNKNOWN		W5/F00	25	20.2	4.8	19.2%					50	14	41	10	18.0%	28.6%
			UNKNOWN		W6/F00	24.7	20.6	4.1	16.6%					48	13	38	7	20.8%	46.2%
			UNKNOWN		W7/F00	24.6	21.7	2.9	11.8%					39	10	29	4	25.6%	60.0%
			UNKNOWN		W8/F00	23.1	21.9	1.2	5.2%					24		19	0	25.0%	100.0%
			UNKNOWN		W9/F00	15.5	15.4	0.1	0.6%					10	0	10	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: BSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

102 EATON TERRACE (CONTINUED)																			
			UNKNOWN		W10/F00	24.3	24.3	0	0.0%					10	0	10	0	0.0%	0.0%
	R5	RESIDENTIAL	UNKNOWN		W12/F00	23.1	23.1	0	0.0%	89.2	89.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	15.1	12.3	2.8	18.5%	91	61.5	5.7	32.4%	22	2	17	0	22.7%	100.0%
			UNKNOWN		W2/F01	16.7	12.4	4.3	25.7%					34	10	26	4	23.5%	60.0%
	R2	RESIDENTIAL	UNKNOWN		W3/F01	11.8	10.3	1.5	12.7%	69	66.8	0.3	3.1%	33	12	27	6	18.2%	50.0%
	R3	RESIDENTIAL	UNKNOWN		W4/F01	27.3	23.7	3.6	13.2%	99.2	97.4	0.3	1.8%	55	16	47	10	14.5%	37.5%
			UNKNOWN		W5/F01	27.2	27.1	0.1	0.4%					13	0	13	0	0.0%	0.0%
	R4	RESIDENTIAL	UNKNOWN		W6/F01	26.9	26.9	0	0.0%	97.7	97.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F01	26.2	26.1	0.1	0.4%					N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	17.8	15.7	2.1	11.8%	85.6	57.1	5.6	33.3%	26	3	21	0	19.2%	100.0%
			UNKNOWN		W2/F02	19.3	16	3.3	17.1%					38	10	32	5	15.8%	50.0%
	R2	RESIDENTIAL	UNKNOWN		W3/F02	20.9	19.5	1.4	6.7%	88.3	87.3	0.1	1.1%	45	14	42	11	6.7%	21.4%
	R3	RESIDENTIAL	UNKNOWN		W4/F02	29.7	26.4	3.3	11.1%	99.2	97.7	0.2	1.5%	59	18	56	15	5.1%	16.7%
			UNKNOWN		W5/F02	29.4	29.4	0	0.0%					15	0	15	0	0.0%	0.0%
	R4	RESIDENTIAL	UNKNOWN		W6/F02	29.1	29.1	0	0.0%	97.8	97.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F02	28.4	28.4	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	31.8	30.7	1.1	3.5%	91.3	90.3	0.1	1.1%	69	20	64	15	7.2%	25.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F03	32.1	29.5	2.6	8.1%	96.2	95.9	0.0	0.3%	65	21	61	17	6.2%	19.0%
			UNKNOWN		W3/F03	31.8	31.8	0	0.0%					20	1	20	1	0.0%	0.0%
	R3	RESIDENTIAL	UNKNOWN		W4/F03	31.5	31.4	0.1	0.3%	97	97	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F03	30.8	30.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A

180 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	15.1	9.1	6	39.7%	67	23.8	2.9	64.4%	14	1	3	0	78.6%	100.0%
	R2	RESIDENTIAL	UNKNOWN		W2/B01	20.8	13.8	7	33.7%	95.7	31.2	10.3	67.4%	36	4	22	2	38.9%	50.0%
			UNKNOWN		W3/B01	19.2	13.2	6	31.2%					40	10	29	8	27.5%	20.0%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	24.7	17.2	7.5	30.4%	96	47.7	8.5	50.3%	48	12	32	9	33.3%	25.0%
			UNKNOWN		W2/F00	24.8	17	7.8	31.5%					47	12	32	9	31.9%	25.0%
F01	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.2	20.3	6.9	25.4%	96.3	65	5.5	32.5%	52	12	37	9	28.8%	25.0%
			UNKNOWN		W3/F01	27.3	20.1	7.2	26.4%					53	13	37	9	30.2%	30.8%
F02	R2	RESIDENTIAL	UNKNOWN		W2/F02	30	23.7	6.3	21.0%	97.2	74.2	4.2	23.7%	59	18	49	15	16.9%	16.7%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

180 MOZART TERRACE (CONTINUED)																			
			UNKNOWN		W3/F02	30	23.5	6.5	21.7%					60	19	49	15	18.3%	21.1%

182 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18.5	14	4.5	24.3%	95.5	32.6	10.1	65.9%	30	1	21	1	30.0%	0.0%
			UNKNOWN		W2/B01	18.3	14.2	4.1	22.4%					36	5	26	5	27.8%	0.0%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.9	18.3	5.6	23.4%	95.9	54.2	7.1	43.5%	44	11	34	9	22.7%	18.2%
			UNKNOWN		W2/F00	24.1	17.9	6.2	25.7%					43	10	32	8	25.6%	20.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	26.6	21.5	5.1	19.2%	96.5	88.7	1.4	8.1%	51	14	42	12	17.6%	14.3%
			UNKNOWN		W2/F01	26.8	21.3	5.5	20.5%					51	14	40	11	21.6%	21.4%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.6	25.1	4.5	15.2%	96.4	92.4	0.7	4.2%	57	16	50	14	12.3%	12.5%
			UNKNOWN		W2/F02	29.7	24.8	4.9	16.5%					58	18	49	15	15.5%	16.7%

184 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18	14.4	3.6	20.0%	67.2	22	11.1	67.2%	34	3	25	2	26.5%	33.3%
			UNKNOWN		W2/B01	16	13.2	2.8	17.5%					34	7	27	6	20.6%	14.3%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	22.3	18.5	3.8	17.0%	81.3	49.3	7.5	39.4%	45	11	35	10	22.2%	9.1%
			UNKNOWN		W3/F00	22.9	18.4	4.5	19.7%					47	12	35	10	25.5%	16.7%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24.4	21.6	2.8	11.5%	81.1	62.8	2.0	22.6%	46	10	40	10	13.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	25	21.5	3.5	14.0%	84.1	65.2	4.1	22.4%	50	12	42	11	16.0%	8.3%
			UNKNOWN		W3/F01	25.5	21.4	4.1	16.1%					52	13	41	11	21.2%	15.4%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.1	24.5	2.6	9.6%	100	100	0.0	0.0%	52	12	46	12	11.5%	0.0%
			UNKNOWN		W3/F02 / HZ (2)	78.5	77.8	0.7	0.9%					37	4	33	4	10.8%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	27.6	24.4	3.2	11.6%	82.8	61.7	4.6	25.5%	54	15	47	14	13.0%	6.7%
			UNKNOWN		W4/F02	28	24.3	3.7	13.2%					56	16	48	14	14.3%	12.5%

186 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	15.7	14.2	1.5	9.6%	45	26	4.6	42.3%	25	1	23	1	8.0%	0.0%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	20.4	18.7	1.7	8.3%	71.4	45.4	5.1	36.4%	34	8	33	8	2.9%	0.0%
			UNKNOWN		W2/F00	20.9	18.7	2.2	10.5%					38	9	33	9	13.2%	0.0%
F01	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.4	21.7	1.7	7.3%	80.6	63.3	2.9	21.4%	46	12	43	12	6.5%	0.0%
			UNKNOWN		W3/F01	23.7	21.6	2.1	8.9%					43	10	39	10	9.3%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

186 MOZART TERRACE (CONTINUED)																			
F02	R2	RESIDENTIAL	UNKNOWN		W2/F02	26.3	24.6	1.7	6.5%	75.6	56.7	3.2	25.0%	51	14	49	14	3.9%	0.0%
			UNKNOWN		W3/F02	26.5	24.5	2	7.5%					51	14	47	14	7.8%	0.0%

188 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	13.4	12.8	0.6	4.5%	34.3	33.2	0.2	3.0%	13	0	13	0	0.0%	0.0%
			UNKNOWN		W2/B01	11.6	11.6	0	0.0%					21	1	21	1	0.0%	0.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	18.4	17.6	0.8	4.3%	61.5	51.5	2.0	16.3%	29	3	29	3	0.0%	0.0%
			UNKNOWN		W3/F00	19.3	18.2	1.1	5.7%					34	8	34	8	0.0%	0.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	23.5	22.9	0.6	2.6%	62.1	62.1	0.0	0.0%	47	14	46	14	2.1%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.4	22.5	0.9	3.8%	71.8	64.6	1.3	10.0%	47	14	46	14	2.1%	0.0%
			UNKNOWN		W3/F01	23.2	22.2	1	4.3%					43	12	42	12	2.3%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	26.5	25.8	0.7	2.6%	59.5	59.5	0.0	0.0%	52	15	51	15	1.9%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	26.4	25.5	0.9	3.4%	68.4	62.2	1.1	9.1%	53	15	51	15	3.8%	0.0%
			UNKNOWN		W3/F02	26.2	25.1	1.1	4.2%					51	13	49	13	3.9%	0.0%

190 EBURY STREET																			
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24.4	24	0.4	1.6%	48.7	48.7	0.0	0.0%	46	15	46	15	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	24	23.5	0.5	2.1%	48.1	48.1	0.0	0.0%	46	14	46	14	0.0%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.2	26.8	0.4	1.5%	61.7	61.7	0.0	0.0%	51	16	51	16	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	26.8	26.3	0.5	1.9%	60.3	60.3	0.0	0.0%	51	15	51	15	0.0%	0.0%

192 EBURY STREET																			
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.6	25.3	0.3	1.2%	80.9	80.5	0.1	0.5%	44	15	44	15	0.0%	0.0%
			UNKNOWN		W2/F01	24.9	24.6	0.3	1.2%					44	14	44	14	0.0%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28.1	27.8	0.3	1.1%	95.5	95.4	0.0	0.1%	53	17	53	17	0.0%	0.0%
			UNKNOWN		W2/F02	27.6	27.3	0.3	1.1%					51	16	51	16	0.0%	0.0%
			UNKNOWN		W3/F02 / INC (2)	63	63	0	0.0%					53	15	53	15	0.0%	0.0%

194 EBURY STREET																			
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.9	25.7	0.2	0.8%	94.4	94.4	0.0	0.0%	36	12	36	12	0.0%	0.0%
			UNKNOWN		W2/F01	25.9	25.7	0.2	0.8%					42	13	42	13	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

194 EBURY STREET (CONTINUED)																			
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28.3	28.1	0.2	0.7%	95.4	95.4	0.0	0.0%	44	12	44	12	0.0%	0.0%
			UNKNOWN		W2/F02	28.4	28.1	0.3	1.1%					50	14	50	14	0.0%	0.0%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	31.5	31.2	0.3	1.0%	85.8	85.8	0.0	0.0%	58	18	57	18	1.7%	0.0%

17A PIMLICO ROAD																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	18.1	13.1	5	27.6%	96.7	57.3	4.3	40.8%	N/A	N/A	N/A	N/A	N/A	N/A
F00	R1	RESIDENTIAL	KITCHEN		W1/F00	21.3	16.2	5.1	23.9%	81.1	58.6	3.6	27.7%	N/A	N/A	N/A	N/A	N/A	N/A

17 PIMLICO ROAD																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	13.8	11.9	1.9	13.8%	51.8	36.1	2.6	30.4%	N/A	N/A	N/A	N/A	N/A	N/A
F00	R2	RESIDENTIAL	UNKNOWN		W3/F00	17.8	15.3	2.5	14.0%	71.9	54.5	2.9	24.2%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24.3	19.7	4.6	18.9%	92.8	73.3	3.6	21.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.4	20.1	3.3	14.1%	80.9	69.2	1.3	14.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F01	22.6	20.2	2.4	10.6%	87	74	2.1	14.9%	7	0	7	0	0.0%	0.0%
			UNKNOWN		W4/F01	0	0	0	-					0	0	0	0	0.0%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.8	23.6	4.2	15.1%	77.4	66.7	2.0	13.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	27	23.9	3.1	11.5%	89.1	77.5	1.2	13.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F02	26.4	24.1	2.3	8.7%	80.4	72	1.4	10.4%	8	0	8	0	0.0%	0.0%
			UNKNOWN		W4/F02	0	0	0	-					0	0	0	0	0.0%	0.0%

15 PIMLICO ROAD																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	17.3	12.3	5	28.9%	91.8	32.1	8.8	65.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/B01	19.5	13.2	6.3	32.3%					N/A	N/A	N/A	N/A	N/A	N/A
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	22.3	15.8	6.5	29.1%	96.9	51.3	6.8	47.1%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R2	RESIDENTIAL	UNKNOWN		W2/F01	25.4	19.3	6.1	24.0%	99.1	69.5	4.4	29.9%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28.3	22.9	5.4	19.1%	74.4	59.7	2.2	19.7%	N/A	N/A	N/A	N/A	N/A	N/A

13 PIMLICO ROAD																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18.5	9.9	8.6	46.5%	70.2	31	5.8	55.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/B01	18	11.6	6.4	35.6%	86.9	29.4	9.4	66.1%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W3/B01	19.4	11.2	8.2	42.3%					N/A	N/A	N/A	N/A	N/A	N/A

- (1) KITCHEN SMALLER THAN 13m2
- (2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
- (3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: BSDHA
UPD

PROJECT NAME: BELGRAVIA 03/04/2020						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
13 PIMLICO ROAD (CONTINUED)																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.1	14.4	8.7	37.7%	97	83.5	2.0	13.9%	5	0	4	0	0.0%	0.0%
			UNKNOWN		W4/F00	11.5	11.4	0.1	0.9%					19	2	19	2	0.0%	0.0%
	R3	RESIDENTIAL	UNKNOWN		W3/F00	23.4	15.3	8.1	34.6%	94.7	50	7.3	47.2%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	26.5	18	8.5	32.1%	98.5	95.5	0.5	3.1%	4	0	4	0	0.0%	0.0%
			UNKNOWN		W4/F01	19.4	19.3	0.1	0.5%					39	7	39	7	0.0%	0.0%
	R3	RESIDENTIAL	UNKNOWN		W3/F01	26.1	18.5	7.6	29.1%	98.8	67.6	5.1	31.5%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.4	21.6	7.8	26.5%	99.4	98.6	0.1	0.8%	7	0	7	0	0.0%	0.0%
			UNKNOWN		W3/F02	28.9	28.8	0.1	0.3%					60	18	60	18	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	29	22.3	6.7	23.1%	67	48.9	3.0	27.0%	N/A	N/A	N/A	N/A	N/A	N/A
2 RANELAGH GROVE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	12.9	11.4	1.5	11.6%	89.3	82.1	0.8	8.1%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	23.5	18.6	4.9	20.9%	98	89.6	1.4	8.5%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F01	24	18.8	5.2	21.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W3/F01	16.2	15.1	1.1	6.8%	88.3	86.7	0.2	1.7%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.6	22.8	4.8	17.4%	98.2	96.9	0.2	1.3%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F02	28.3	23	5.3	18.7%					N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	30.3	25.5	4.8	15.8%	72.3	43.1	3.7	40.4%	N/A	N/A	N/A	N/A	N/A	N/A
4 RANELAGH GROVE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	12.9	9.5	3.4	26.4%	59.8	57	0.4	4.7%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	15.7	12.4	3.3	21.0%	65.3	65.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	16.6	13.7	2.9	17.5%	52.7	50.7	0.2	3.7%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	23.7	20	3.7	15.6%	95.7	95.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	22.9	19.8	3.1	13.5%	71.6	71.5	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	28.1	25.6	2.5	8.9%	69.7	65.6	0.4	5.9%	N/A	N/A	N/A	N/A	N/A	N/A
67-88 COLLESHILL FLATS																			
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	12.1	9	3.1	25.6%	91.4	72.3	1.8	21.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F01	4.6	4.4	0.2	4.3%	36.7	36.7	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F01	7.5	7.2	0.3	4.0%	98.9	98.9	0.0	0.0%	0	0	0	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS %	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

67-88 COLLESHILL FLATS (CONTINUED)																			
			KITCHEN-RESI (1)		W4/F01	28	17.7	10.3	36.8%					5	0	5	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F01	11.8	5	6.8	57.6%	83.8	32	5.2	61.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F01	13	8.1	4.9	37.7%	86.1	59.3	2.7	31.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F01	28.2	14	14.2	50.4%	99.1	76	1.0	23.3%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F01	8.6	3.5	5.1	59.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F01	5.2	2.1	3.1	59.6%	40.4	10.6	2.9	73.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	10.6	3.7	6.9	65.1%	89.3	20.8	6.4	76.7%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	13.2	10.3	2.9	22.0%	91.9	77.6	1.3	15.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F02	5.6	5.5	0.1	1.8%	41.4	41.4	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F02	8.9	8.7	0.2	2.2%	98.9	98.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F02	30.2	20.2	10	33.1%					5	0	5	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F02	12.6	5.9	6.7	53.2%	86.3	38.9	4.7	54.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F02	13.7	9	4.7	34.3%	86.9	64.9	2.2	25.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F02	30.3	16.1	14.2	46.9%	99.1	82.2	0.7	17.1%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F02	9.7	4.8	4.9	50.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F02	6.1	3.1	3	49.2%	42.2	15.3	2.7	63.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	11.8	4.9	6.9	58.5%	91.8	27.2	6.0	70.4%	N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	14.8	12.2	2.6	17.6%	93	85.3	0.7	8.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F03	7.5	7.3	0.2	2.7%	47.3	47.3	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F03	11.4	11.2	0.2	1.8%	98.9	98.9	0.0	0.0%	1	0	1	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F03	32.4	23.1	9.3	28.7%					5	0	5	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F03	12.9	6.5	6.4	49.6%	87.2	49.2	3.8	43.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F03	13.9	9.6	4.3	30.9%	87.1	71.5	1.6	18.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F03	32.4	18.6	13.8	42.6%	99.1	89.4	0.4	9.8%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F03	11.9	7.2	4.7	39.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F03	7.8	5	2.8	35.9%	47.9	25.2	2.2	47.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	13.5	6.9	6.6	48.9%	93.1	37.9	5.2	59.3%	N/A	N/A	N/A	N/A	N/A	N/A
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	17.9	15.7	2.2	12.3%	95.8	94.6	0.1	1.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F04	11.5	11.4	0.1	0.9%	67.5	67.5	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F04	16.4	16.2	0.2	1.2%	98.9	98.9	0.0	0.0%	4	0	4	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F04	34.5	26.2	8.3	24.1%					5	0	5	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT
EXISTING VS. PROPOSED

ITERATION NO.: IR39(06.03.20)
ARCHITECT: BSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

67-88 COLLESHILL FLATS (CONTINUED)

	R6	RESIDENTIAL	BEDROOM		W7/F04	8.4	2.5	5.9	70.2%	87.1	51.8	3.5	40.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F04	9.2	5.4	3.8	41.3%	86.9	77.6	0.9	10.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F04	34.4	21.5	12.9	37.5%	99.1	98.9	0.0	0.3%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F04	16.7	12.5	4.2	25.1%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F04	11.6	8.9	2.7	23.3%	69.1	47.6	2.1	31.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	16.8	10.5	6.3	37.5%	96	54.6	3.9	43.2%	N/A	N/A	N/A	N/A	N/A	N/A
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	19.7	16.8	2.9	14.7%	98.9	98	0.1	0.9%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W2/F05	27.1	22.9	4.2	15.5%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W3/F05	30.2	19.7	10.5	34.8%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	31.4	26.4	5	15.9%	98.8	98.3	0.0	0.5%	3	0	3	0	0.0%	0.0%
			UNKNOWN-RESI		W5/F05	27.4	27.2	0.2	0.7%					34	1	34	1	0.0%	0.0%
			UNKNOWN-RESI		W6/F05	19.8	19.7	0.1	0.5%					10	0	10	0	0.0%	0.0%

45-66 COLLESHILL FLATS

F01	R1	RESIDENTIAL	BEDROOM		W1/F01	12	7.9	4.1	34.2%	91.5	70.4	2.0	23.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F01	4.7	3	1.7	36.2%	39.5	14.4	2.5	63.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F01	8.3	4.6	3.7	44.6%	99.3	98.9	0.0	0.4%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W4/F01	27.1	19.8	7.3	26.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W7/F01	11.2	9.5	1.7	15.2%	77.8	70.9	0.7	8.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F01	12.2	9.4	2.8	23.0%	83.9	67.4	1.6	19.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F01	23.6	19.7	3.9	16.5%	99.6	99.6	0.0	0.0%	5	0	5	0	0.0%	0.0%
			KITCHEN-RESI (1)		W12/F01	26.8	26.8	0	0.0%					29	6	29	6	0.0%	0.0%
	R11	RESIDENTIAL	LIVING ROOM		W13/F01	19.6	19.6	0	0.0%	71.9	71.9	0.0	0.0%	16	2	16	2	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W14/F01	14.1	14.1	0	0.0%	74.5	74.4	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	13.1	9.2	3.9	29.8%	91.6	79.9	11	12.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F02	5.7	4	1.7	29.8%	41.4	19.8	2.1	52.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F02	9.4	6	3.4	36.2%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W4/F02	29.6	22.7	6.9	23.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W7/F02	12.4	10.8	1.6	12.9%	86.5	84.3	0.2	2.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F02	13.1	10.5	2.6	19.8%	86.7	77.5	0.9	10.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F02	26.5	22.9	3.6	13.6%	99.6	99.6	0.0	0.0%	5	0	5	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

PROJECT NAME: BELGRAVIA 03/04/2020						EXISTING VS. PROPOSED				NSL				APSH (WINDOW)						ARCHITECT: P	
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %			
		TYPE	USE	NOTES	%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER			
45-66 COLLESHILL FLATS (CONTINUED)																					
			KITCHEN-RESI (1)		W12/F02	28.5	28.5	0	0.0%					30	7	30	7	0.0%	0.0%		
	R11	RESIDENTIAL	LIVING ROOM		W13/F02	20.9	20.9	0	0.0%	81.1	81.1	0.0	0.0%	16	2	16	2	0.0%	0.0%		
	R12	RESIDENTIAL	BEDROOM		W14/F02	16.3	16.3	0	0.0%	93	92.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A		
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	14.6	11	3.6	24.7%	93.1	89	0.4	4.4%	N/A	N/A	N/A	N/A	N/A	N/A		
	R2	RESIDENTIAL	LIVING ROOM		W2/F03	7.4	5.9	1.5	20.3%	47.5	30.3	1.7	36.2%	N/A	N/A	N/A	N/A	N/A	N/A		
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F03	11.6	8.5	3.1	26.7%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A		
			KITCHEN-RESI (1)		W4/F03	32.1	25.9	6.2	19.3%					N/A	N/A	N/A	N/A	N/A	N/A		
	R6	RESIDENTIAL	BEDROOM		W7/F03	13	11.6	1.4	10.8%	87.2	86.4	0.1	0.9%	N/A	N/A	N/A	N/A	N/A	N/A		
	R7	RESIDENTIAL	BEDROOM		W8/F03	13.4	11.1	2.3	17.2%	86.9	82.7	0.4	4.8%	N/A	N/A	N/A	N/A	N/A	N/A		
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F03	29.7	26.4	3.3	11.1%	99.8	99.8	0.0	0.0%	5	0	5	0	0.0%	0.0%		
			KITCHEN-RESI (1)		W12/F03	30.5	30.5	0	0.0%					31	7	31	7	0.0%	0.0%		
	R11	RESIDENTIAL	LIVING ROOM		W13/F03	22.4	22.4	0	0.0%	86.2	86.2	0.0	0.0%	16	2	16	2	0.0%	0.0%		
	R12	RESIDENTIAL	BEDROOM		W14/F03	18.7	18.7	0	0.0%	96.4	96.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A		
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	17.7	14.4	3.3	18.6%	96	96	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A		
	R2	RESIDENTIAL	LIVING ROOM		W2/F04	11.4	9.8	1.6	14.0%	67.6	58.5	0.9	13.4%	N/A	N/A	N/A	N/A	N/A	N/A		
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F04	16.3	13.6	2.7	16.6%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A		
			KITCHEN-RESI (1)		W4/F04	34.5	29	5.5	15.9%					N/A	N/A	N/A	N/A	N/A	N/A		
	R6	RESIDENTIAL	BEDROOM		W7/F04	8.9	7.7	1.2	13.5%	86.9	86.7	0.0	0.2%	N/A	N/A	N/A	N/A	N/A	N/A		
	R7	RESIDENTIAL	BEDROOM		W8/F04	9	7	2	22.2%	86.7	86.2	0.1	0.6%	N/A	N/A	N/A	N/A	N/A	N/A		
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F04	32.9	30	2.9	8.8%	99.6	99.6	0.0	0.0%	7	0	8	0	14.3%	0.0%		
			KITCHEN-RESI (1)		W12/F04	33	33	0	0.0%					36	8	36	8	0.0%	0.0%		
	R11	RESIDENTIAL	LIVING ROOM		W13/F04	24.7	24.7	0	0.0%	87.3	87.3	0.0	0.0%	18	2	18	2	0.0%	0.0%		
	R12	RESIDENTIAL	BEDROOM		W14/F04	21.9	21.8	0.1	0.5%	97.5	97.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A		
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	19.1	17.2	1.9	9.9%	98.9	98.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A		
			UNKNOWN-RESI		W2/F05	26.2	23.1	3.1	11.8%					N/A	N/A	N/A	N/A	N/A	N/A		
			UNKNOWN-RESI		W3/F05	30.5	26	4.5	14.8%					N/A	N/A	N/A	N/A	N/A	N/A		
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	27.4	26.1	1.3	4.7%	98	97.6	0.0	0.4%	13	5	13	5	0.0%	0.0%		
			UNKNOWN-RESI		W5/F05	36.3	36.3	0	0.0%					45	10	45	10	0.0%	0.0%		
			UNKNOWN-RESI		W6/F05	28.4	28.4	0	0.0%					23	3	23	3	0.0%	0.0%		

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA

UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

23-44 COLLESHILL FLATS																			
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	18.1	18.1	0	0.0%	85.5	85.5	0.0	0.0%	44	17	44	17	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F01	22.4	22.4	0	0.0%	91.7	91.7	0.0	0.0%	52	22	52	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F01	26.8	25.6	1.2	4.5%	99.5	99.5	0.0	0.0%	51	17	49	17	3.9%	0.0%
			KITCHEN-RESI (1)		W6/F01	6.7	5.9	0.8	11.9%					15		15	0	100%	100%
	R6	RESIDENTIAL	LIVING ROOM		W7/F01	10.1	10	0.1	1.0%	71.7	71.7	0.0	0.0%	14	0	14	0	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F01	10.5	10.5	0	0.0%	70.9	70.9	0.0	0.0%	21	4	21	4	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F01	7	7	0	0.0%	99.3	99.3	0.0	0.0%	23	9	23	9	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F01	26.9	25.2	1.7	6.3%					52	15	51	15	1.9%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F01	5.3	4.7	0.6	11.3%	35.3	29.7	0.4	15.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	10.7	10.5	0.2	1.9%	87.6	87.6	0.0	0.0%	18	1	18	1	0.0%	0.0%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	19.5	19.5	0	0.0%	91.7	91.7	0.0	0.0%	46	17	46	17	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	23.4	23.4	0	0.0%	91.7	91.7	0.0	0.0%	52	22	52	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F02	29.6	28.4	1.2	4.1%	99.8	99.8	0.0	0.0%	59	18	58	18	1.7%	0.0%
			KITCHEN-RESI (1)		W6/F02	6.9	6.2	0.7	10.1%					15		14	0	67%	100%
	R6	RESIDENTIAL	LIVING ROOM		W7/F02	11.3	11.2	0.1	0.9%	84.2	84.2	0.0	0.0%	17	0	17	0	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F02	11.5	11.5	0	0.0%	85.2	85.2	0.0	0.0%	22	4	22	4	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F02	7.4	7.4	0	0.0%	99.3	99.3	0.0	0.0%	23	9	23	9	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F02	29.7	28	1.7	5.7%					59	17	57	17	3.4%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F02	6.2	5.6	0.6	9.7%	38	35.2	0.2	7.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	12	11.9	0.1	0.8%	90.6	90.6	0.0	0.0%	19	1	19	1	0.0%	0.0%
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	20.9	20.9	0	0.0%	93.9	93.9	0.0	0.0%	45	17	45	17	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F03	24.3	24.3	0	0.0%	91.9	91.9	0.0	0.0%	52	22	52	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F03	31.9	30.7	1.2	3.8%	99.5	99.5	0.0	0.0%	59	17	57	17	3.4%	0.0%
			KITCHEN-RESI (1)		W6/F03	7.6	6.9	0.7	9.2%					15		15	0	67%	100%
	R6	RESIDENTIAL	LIVING ROOM		W7/F03	12	11.9	0.1	0.8%	88.1	88.1	0.0	0.0%	19	1	19	1	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F03	12	12	0	0.0%	87.9	87.9	0.0	0.0%	24	6	24	6	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F03	7.7	7.7	0	0.0%	99.3	99.3	0.0	0.0%	25	10	25	10	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F03	32	30.4	1.6	5.0%					58	16	56	16	3.4%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F03	7.9	7.3	0.6	7.6%	46.1	45	0.1	2.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	13.9	13.8	0.1	0.7%	91.8	91.8	0.0	0.0%	20	2	20	2	0.0%	0.0%
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	22.8	22.8	0	0.0%	94.8	94.8	0.0	0.0%	48	18	48	18	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

23-44 COLLESHILL FLATS (CONTINUED)																			
	R2	RESIDENTIAL	BEDROOM		W2/F04	25.2	25.2	0	0.0%	92.3	92.3	0.0	0.0%	49	22	49	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F04	34.2	33	1.2	3.5%	99.5	99.5	0.0	0.0%	62	19	61	19	1.6%	0.0%
			KITCHEN-RESI (1)		W6/F04	5.6	4.9	0.7	12.5%									0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F04	6	5.8	0.2	3.3%	87.7	87.6	0.0	0.1%	9	2	9	2	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F04	5.8	5.8	0	0.0%	87.5	87.5	0.0	0.0%	8	6	8	6	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F04	5.7	5.7	0	0.0%	99.3	99.3	0.0	0.0%	19	11	19	11	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F04	34.1	32.6	1.5	4.4%					60	19	58	19	3.3%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F04	12.1	11.6	0.5	4.1%	73.3	73.2	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	17.2	17.1	0.1	0.6%	94.7	94.7	0.0	0.0%	23	2	23	2	0.0%	0.0%
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	30.4	30.4	0	0.0%	99.6	99.6	0.0	0.0%	60	24	60	24	0.0%	0.0%
			UNKNOWN-RESI		W2/F05	37.9	37.9	0	0.0%					70	26	70	26	0.0%	0.0%
			UNKNOWN-RESI		W3/F05	33.4	33	0.4	1.2%					66	22	66	22	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	30.9	29.3	1.6	5.2%	98.8	98.8	0.0	0.0%	41	9	41	9	0.0%	0.0%
			UNKNOWN-RESI		W5/F05	27.9	25.7	2.2	7.9%					21	2	20	2	4.8%	0.0%
			UNKNOWN-RESI		W6/F05	21.5	20.4	1.1	5.1%					31	3	29	3	3.5%	0.0%

01-22 COLLESHILL FLATS																			
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	9.5	9.5	0	0.0%	82.3	82.3	0.0	0.0%	18	3	18	3	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F01	4.9	4.9	0	0.0%	36.6	36.6	0.0	0.0%	18	5	18	5	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F01	27.3	23.5	3.8	13.9%	99.6	99.6	0.0	0.0%	52	12	49	12	5.8%	0.0%
			KITCHEN-RESI (1)		W6/F01	6.9	4.2	2.7	39.1%									0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F01	12.4	10.8	1.6	12.9%	87.5	84.7	0.3	3.2%	19	1	17	1	10.5%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F01	11	11	0	0.0%	84.3	84.3	0.0	0.0%	21	3	21	3	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F01	5.7	5.7	0	0.0%	99.7	99.7	0.0	0.0%	20	6	20	6	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F01	27.4	21.7	5.7	20.8%					54	13	45	13	16.7%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F01	13.9	2	11.9	85.6%	79.3	4.4	5.8	94.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	16.3	8.3	8	49.1%	93.8	78.7	1.4	16.1%	19	1	10	1	47.4%	0.0%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	11	11	0	0.0%	90.7	90.7	0.0	0.0%	22	5	22	5	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	5.9	5.9	0	0.0%	38.4	38.4	0.0	0.0%	21	7	21	7	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F02	29.9	26.2	3.7	12.4%	99.6	99.6	0.0	0.0%	55	13	51	13	7.3%	0.0%
			KITCHEN-RESI (1)		W6/F02	7.3	4.7	2.6	35.6%					17		15	1	29.4%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS	LOSS %	EX.		PR.		LOSS %	
												SQM		ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

01-22 COLLESHILL FLATS (CONTINUED)																			
	R6	RESIDENTIAL	LIVING ROOM		W7/F02	13.2	11.7	1.5	11.4%	87.9	871	0.1	1.0%	20	2	18	2	10.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F02	12.2	12.2	0	0.0%	87.4	87.4	0.0	0.0%	23	5	23	5	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F02	6.4	6.4	0	0.0%	99.7	99.7	0.0	0.0%	22	8	22	8	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F02	29.9	24.2	5.7	19.1%					58	16	49	16	15.5%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F02	15.8	2.8	13	82.3%	91.6	8.5	6.4	90.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	17.7	9.4	8.3	46.9%	94	80.7	1.3	14.2%	20	2	14	2	30.0%	0.0%
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	13	13	0	0.0%	91.6	91.6	0.0	0.0%	23	5	23	5	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F03	7.7	7.7	0	0.0%	46.4	46.4	0.0	0.0%	24	8	24	8	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F03	32.3	28.9	3.4	10.5%	99.6	99.6	0.0	0.0%	59	17	55	17	6.8%	0.0%
			KITCHEN-RESI (1)		W6/F03	7.7	5.4	2.3	29.9%									29.9%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F03	13.5	12.1	1.4	10.4%	88.1	88	0.0	0.2%	20	2	20	2	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F03	12.7	12.7	0	0.0%	87.6	87.6	0.0	0.0%	25	7	25	7	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F03	7.1	7.1	0	0.0%	99.7	99.7	0.0	0.0%	25	10	25	10	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F03	32.3	26.8	5.5	17.0%					60	18	52	18	13.3%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F03	17.9	3.8	14.1	78.8%	92.2	15.8	5.9	82.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	19.4	10.9	8.5	43.8%	94.3	83.1	11	11.8%	21	3	15	3	28.6%	0.0%
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	16.5	16.5	0	0.0%	94.1	94.1	0.0	0.0%	32	7	32	7	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F04	11.6	11.6	0	0.0%	73.1	73.1	0.0	0.0%	33	11	33	11	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F04	34.3	31.2	3.1	9.0%	99.6	99.6	0.0	0.0%	61	20	57	20	6.6%	0.0%
			KITCHEN-RESI (1)		W6/F04	5.7	3.6	2.1	36.8%					19		14	8	29.8%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F04	7	5.8	1.2	17.1%	87.7	84.1	0.4	4.2%	10	3	10	3	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F04	6.5	6.5	0	0.0%	87.1	87.1	0.0	0.0%	11	8	11	8	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F04	5.3	5.3	0	0.0%	99.7	99.7	0.0	0.0%	20	12	20	12	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F04	34.2	29.1	5.1	14.9%					61	20	56	20	8.2%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F04	21	6.2	14.8	70.5%	92.5	29.5	4.8	68.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	21.6	13.2	8.4	38.9%	95.2	88.9	0.6	6.6%	26	3	16	3	38.5%	0.0%
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	21.4	21.4	0	0.0%	99.8	99.8	0.0	0.0%	48	17	48	17	0.0%	0.0%
			UNKNOWN-RESI		W2/F05	29.1	29.1	0	0.0%					61	20	61	20	0.0%	0.0%
			UNKNOWN-RESI		W3/F05	33.2	32	1.2	3.6%					67	23	63	23	6.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	30.6	24.7	5.9	19.3%	99.8	98.2	0.1	1.5%	42	10	37	10	11.9%	0.0%
			UNKNOWN-RESI		W5/F05	34.3	13.8	20.5	59.8%					21	8	15	8	28.6%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NO: 13752
PROJECT NAME: BELGRAVIA
03/04/2020

DAYLIGHT AND SUNLIGHT

ITERATION NO.: IR39(06.03.20)

ARCHITECT: PSDHA
UPD

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

01-22 COLLESHILL FLATS (CONTINUED)																			
			UNKNOWN-RESI		W6/F05	27.2	11.2	16	58.8%					21	3	14	2	33.3%	0.0%

8 RANELAGH GROVE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	8.9	8.3	0.6	6.7%	43.4	43.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	19.2	18.6	0.6	3.1%	61.9	61.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	14.4	13.7	0.7	4.9%	83.1	83.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.8	26.8	1	3.6%	98.7	98.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	23.9	22	1.9	7.9%	99.8	99.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F02 / INC (2)	83.2	82.2	1	1.2%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W3/F02 / INC (2)	84.4	83	1.4	1.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W4/F02	26.2	25.9	0.3	1.1%	98	98	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F02	34.5	32.1	2.4	7.0%					N/A	N/A	N/A	N/A	N/A	N/A

6 RANELAGH GROVE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	10	10	0	0.0%	43	43	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	15.6	13.4	2.2	14.1%	40.4	40.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	15.3	15.3	0	0.0%	80.6	80.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.1	20.9	2.2	9.5%	88.4	88.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	24.8	24.7	0.1	0.4%	98.6	98.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	28.3	26.7	1.6	5.7%	72.4	72.1	0.0	0.5%	N/A	N/A	N/A	N/A	N/A	N/A

1 EBURY BRIDGE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	24.4	22	2.4	9.8%	92	92	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	24	21.7	2.3	9.6%	92.7	92.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W3/F00	23.6	21.4	2.2	9.3%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F00	23.8	21.8	2	8.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W5/F00	22.4	20.7	1.7	7.6%	78.8	77.7	0.7	1.4%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W6/F00	21.8	20.4	1.4	6.4%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F00	21.2	20	1.2	5.7%					N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24	23.8	0.2	0.8%	95.2	95.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F01	27	24.6	2.4	8.9%					N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

PROJECT NAME: BELGRAVIA 03/04/2020						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY BRIDGE (CONTINUED)																			
	R2	RESIDENTIAL	UNKNOWN		W3/F01	26.4	24.1	2.3	8.7%	97.9	86.7	4.3	11.4%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F01	26.2	24.1	2.1	8.0%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F01	25.5	23.6	1.9	7.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W6/F01	25.2	23.5	1.7	6.7%	74.9	64.5	6.8	13.9%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F01	24.4	23.1	1.3	5.3%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W8/F01	24.1	23	1.1	4.6%					N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	25.2	25	0.2	0.8%	95.2	95.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F02	28.3	26.1	2.2	7.8%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W3/F02	28.1	25.9	2.2	7.8%	97.4	67.6	11.3	30.6%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F02	27.7	25.7	2	7.2%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F02	27.2	25.4	1.8	6.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W6/F02	26.7	25.2	1.5	5.6%	69.4	50.1	12.6	27.8%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F02	26.3	25	1.3	4.9%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W8/F02	25.9	24.8	1.1	4.2%					N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	24.6	24.4	0.2	0.8%	95.2	95.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F03	27.6	25.5	2.1	7.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W3/F03	27.8	25.8	2	7.2%	97.4	88.7	3.3	8.9%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F03	27.4	25.4	2	7.3%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F03	26.8	25.1	1.7	6.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W6/F03	26.4	24.9	1.5	5.7%	78.2	69.2	5.9	11.5%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F03	26	24.8	1.2	4.6%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W8/F03	25.7	24.6	1.1	4.3%					N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

COMMITTEE SCHEME

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK A																			
F00	R1	RESIDENTIAL	LIVING ROOM		W1/F00	22.6	22.6	0	0.0%	98.8	98.4	0.2	0.4%	12	1	11	0	9.3%	100.0%
			LIVING ROOM		W2/F00	15.8	15.8	0	0.0%					11	2	18	1	9.1%	50.0%
			LIVING ROOM		W3/F00	16.6	16.6	0	0.0%					22	4	20	3	9.1%	25.0%
			LIVING ROOM		W4/F00	24.5	12.7	11.8	48.2%					49	6	25	0	49.0%	100.0%
	R2	RESIDENTIAL	KITCHEN-DINING		W5/F00	21.4	9.3	12.1	56.5%	90.1	59.7	14.0	33.8%	49	8	17	0	65.3%	100.0%
			KITCHEN-DINING		W6/F00	15.6	9.7	5.9	37.8%					30	8	10	0	66.7%	100.0%
			KITCHEN-DINING		W7/F00	13.6	9.3	4.3	31.6%					26	7	10	0	61.5%	100.0%
	R3	RESIDENTIAL	BEDROOM		W8/F00	10.3	9.1	1.2	11.7%	44.1	44.1	0.0	0.0%	21	6	15	0	28.6%	100.0%
	R4	RESIDENTIAL	BEDROOM		W9/F00	10	9.2	0.8	8.0%	31.5	30.7	0.2	2.3%	19	5	15	1	21.1%	80.0%
	R5	RESIDENTIAL	BEDROOM		W10/F00	10.1	9.9	0.2	2.0%	43.8	43.8	0.0	0.0%	20	5	18	3	10.0%	40.0%
	R6	RESIDENTIAL	BEDROOM		W11/F00	10.3	10.1	0.2	1.9%	35.7	35.7	0.0	0.0%	19	5	17	3	10.5%	40.0%
			BEDROOM		W12/F00	10.5	10.4	0.1	1.0%					18	4	17	3	5.6%	25.0%
	R7	RESIDENTIAL	BEDROOM		W13/F00	13.2	13.1	0.1	0.8%	63.5	63.5	0.0	0.0%	21	4	20	3	4.8%	25.0%
	R8	RESIDENTIAL	BEDROOM		W14/F00	15.1	15.1	0	0.0%	69.4	69.4	0.0	0.0%	25	4	25	4	0.0%	0.0%
F01	R1	RESIDENTIAL	LKD		W1/F01	29.2	29.2	0	0.0%	99.2	99.2	0.0	0.0%	29	5	28	4	3.4%	20.0%
			LKD		W2/F01	29.9	29.9	0	0.0%					30	5	29	5	3.3%	15.7%
			LKD		W3/F01	30.5	30.4	0.1	0.3%					28	5	27	4	3.6%	20.0%
			LKD		W4/F01	27.2	16.1	11.1	40.8%					63	13	37	1	41.3%	92.3%
	R2	RESIDENTIAL	BEDROOM		W5/F01	24.3	12.7	11.6	47.7%	94.3	70.8	6.2	24.9%	57	9	29	0	49.1%	100.0%
			BEDROOM		W6/F01	17.8	11.8	6	33.7%					32	8	15	0	53.1%	100.0%
	R3	RESIDENTIAL	BEDROOM		W7/F01	15.8	11.4	4.4	27.8%	71.1	44.5	4.1	37.4%	29	8	17	0	41.4%	100.0%
	R4	RESIDENTIAL	BEDROOM		W8/F01	12.7	11.1	1.6	12.6%	30.3	30.3	0.0	0.0%	24	7	19	2	20.8%	71.4%
	R5	RESIDENTIAL	BEDROOM		W9/F01	12.3	11.2	1.1	8.9%	23.2	23.2	0.0	0.0%	22	6	18	2	18.2%	66.7%
	R6	RESIDENTIAL	BEDROOM		W10/F01	12	11.3	0.7	5.8%	23.5	23.5	0.0	0.0%	23	6	20	3	13.0%	50.0%
	R7	RESIDENTIAL	BEDROOM		W11/F01	11.9	11.4	0.5	4.2%	31.6	31.6	0.0	0.0%	21	6	19	4	9.5%	33.3%
	R8	RESIDENTIAL	BEDROOM		W12/F01	12.1	11.9	0.2	1.7%	31.4	31.4	0.0	0.0%	22	7	20	5	9.1%	28.6%
	R9	RESIDENTIAL	BEDROOM		W13/F01	12.2	12.1	0.1	0.8%	23.9	23.9	0.0	0.0%	23	7	21	5	8.7%	28.6%
	R10	RESIDENTIAL	BEDROOM		W14/F01	12.5	12.3	0.2	1.6%	23.7	23.7	0.0	0.0%	21	6	20	5	4.8%	16.7%
	R11	RESIDENTIAL	BEDROOM		W15/F01	12.7	12.6	0.1	0.8%	31.9	31.9	0.0	0.0%	22	6	21	5	4.5%	16.7%
	R12	RESIDENTIAL	BEDROOM		W16/F01	15.1	15	0.1	0.7%	59	59	0.0	0.0%	25	6	25	6	0.0%	0.0%
	R13	RESIDENTIAL	BEDROOM		W17/F01	17	16.9	0.1	0.6%	59.6	59.6	0.0	0.0%	28	6	28	6	0.0%	0.0%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK A (CONTINUED)																			
F02	R1	RESIDENTIAL	LKD		W1/F02	31.7	31.6	0.1	0.3%	99.2	99.2	0.0	0.0%	31	6	30	5	3.2%	16.7%
			LKD		W2/F02	32.4	32.3	0.1	0.3%					31	6	30	5	3.2%	16.7%
			LKD		W3/F02	33	32.9	0.1	0.3%					31	6	30	5	3.2%	16.7%
			LKD		W4/F02	29.9	20.2	9.7	32.4%					67	15	50	2	25.4%	86.7%
	R2	RESIDENTIAL	BEDROOM		W5/F02	27.3	16.9	10.4	38.1%	94.9	78.5	4.3	17.3%	65	14	44	1	32.3%	92.9%
			BEDROOM		W6/F02	20.4	14.4	6	29.4%					37	12	21	0	43.2%	100.0%
	R3	RESIDENTIAL	BEDROOM		W7/F02	18.4	14	4.4	23.9%	73.2	50.9	3.4	30.4%	35	13	22	1	37.1%	92.3%
	R4	RESIDENTIAL	BEDROOM		W8/F02	15.2	13.6	1.6	10.5%	34.7	34.7	0.0	0.0%	27	8	23	4	14.8%	50.0%
	R5	RESIDENTIAL	BEDROOM		W9/F02	14.8	13.7	1.1	7.4%	26.5	26.5	0.0	0.0%	28	8	25	5	10.7%	37.5%
	R6	RESIDENTIAL	BEDROOM		W10/F02	14.5	13.7	0.8	5.5%	26.7	26.7	0.0	0.0%	27	8	25	6	7.4%	25.0%
	R7	RESIDENTIAL	BEDROOM		W11/F02	14.4	13.8	0.6	4.2%	36.3	36.3	0.0	0.0%	26	7	24	5	7.7%	28.6%
	R8	RESIDENTIAL	BEDROOM		W12/F02	14.5	14.2	0.3	2.1%	36.3	36.3	0.0	0.0%	26	7	24	5	7.7%	28.6%
	R9	RESIDENTIAL	BEDROOM		W13/F02	14.6	14.4	0.2	1.4%	27.6	27.6	0.0	0.0%	26	7	25	6	3.8%	14.3%
	R10	RESIDENTIAL	BEDROOM		W14/F02	14.9	14.7	0.2	1.3%	27.4	27.4	0.0	0.0%	27	6	27	6	0.0%	0.0%
	R11	RESIDENTIAL	BEDROOM		W15/F02	15.2	15	0.2	1.3%	37.1	37.1	0.0	0.0%	26	6	26	6	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W16/F02	17.4	17.4	0	0.0%	65.8	65.8	0.0	0.0%	31	6	31	6	0.0%	0.0%
	R13	RESIDENTIAL	BEDROOM		W17/F02	19.2	19.2	0	0.0%	66.2	66.2	0.0	0.0%	33	6	33	6	0.0%	0.0%
F03	R1	RESIDENTIAL	LKD		W1/F03	34	34	0	0.0%	99.4	99.2	0.1	0.2%	32	7	31	6	3.1%	14.3%
			LKD		W2/F03	34.7	34.7	0	0.0%							31		3.1%	14.3%
			LKD		W3/F03	35.3	35.3	0	0.0%					32	7	31	6	3.1%	14.3%
			LKD		W4/F03	32.8	25.7	7.1	21.6%					72	20	60	8	16.7%	60.0%
	R2	RESIDENTIAL	BEDROOM		W5/F03	30.7	22.5	8.2	26.7%	96.1	92	1.1	4.2%	68	17	52	3	23.5%	82.4%
			BEDROOM		W6/F03	23.6	17.7	5.9	25.0%					43	16	28	1	34.9%	93.8%
	R3	RESIDENTIAL	BEDROOM		W7/F03	21.6	17.4	4.2	19.4%	78.9	61.1	2.7	22.6%	39	14	28	3	28.2%	78.6%
	R4	RESIDENTIAL	BEDROOM		W8/F03	18.4	16.9	1.5	8.2%	42.9	42.9	0.0	0.0%	34	11	30	7	11.8%	36.4%
	R5	RESIDENTIAL	BEDROOM		W9/F03	17.9	16.8	1.1	6.1%	32.5	32.5	0.0	0.0%	33	10	30	7	9.1%	30.0%
	R6	RESIDENTIAL	BEDROOM		W10/F03	17.6	16.8	0.8	4.5%	32.4	32.4	0.0	0.0%	32	10	29	7	9.4%	30.0%
	R7	RESIDENTIAL	BEDROOM		W11/F03	17.5	16.8	0.7	4.0%	43.9	43.9	0.0	0.0%	32	10	30	8	6.3%	20.0%
	R8	RESIDENTIAL	BEDROOM		W12/F03	17.5	17.2	0.3	1.7%	45.1	45.1	0.0	0.0%	31	8	30	7	3.2%	12.5%
	R9	RESIDENTIAL	BEDROOM		W13/F03	17.7	17.4	0.3	1.7%	34.1	34.1	0.0	0.0%	32	8	31	7	3.1%	12.5%
	R10	RESIDENTIAL	BEDROOM		W14/F03	17.9	17.7	0.2	1.1%	35	35	0.0	0.0%	32	8	31	7	3.1%	12.5%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK A (CONTINUED)

	R11	RESIDENTIAL	BEDROOM		W15/F03	18.2	18.1	0.1	0.5%	46.5	46.5	0.0	0.0%	31	8	30	7	3.2%	12.5%
	R12	RESIDENTIAL	BEDROOM		W16/F03	20.4	20.3	0.1	0.5%	76.4	76.4	0.0	0.0%	39	8	38	7	2.6%	12.5%
	R13	RESIDENTIAL	BEDROOM		W17/F03	22	21.9	0.1	0.5%	71.1	71.1	0.0	0.0%	41	8	40	7	2.4%	12.5%
F04	R1	RESIDENTIAL	LKD		W3/F04	36.3	33.2	3.1	8.5%	99	99	0.0	0.0%	78	26	73	21	6.4%	19.2%
			LKD		W4/F04	35.7	32	3.7	10.4%					77	25	68	16	11.7%	36.0%
			LKD		W5/F04	34.8	30.1	4.7	13.5%					76	24	65	13	14.5%	45.8%
			LKD		W6/F04	28.8	23.6	5.2	18.1%					55	20	45	10	18.2%	50.0%
			LKD		W7/F04	26.7	22.5	4.2	15.7%					54	20	45	11	16.7%	45.0%
	R2	RESIDENTIAL	BEDROOM		W8/F04	24.3	22.6	1.7	7.0%	83.1	82	0.2	1.2%	45	13	40	8	11.1%	38.5%
			BEDROOM		W9/F04	24.4	22.8	1.6	6.6%					46	13	43	10	6.5%	23.1%
	R3	RESIDENTIAL	LKD		W1/F04	33.6	33.6	0	0.0%	99.6	99.6	0.0	0.0%	30	7	30	7	0.0%	0.0%
			LKD		W2/F04	34	34	0	0.0%					30	7	30	7	0.0%	0.0%
			LKD		W10/F04	23.9	22.8	1.1	4.6%					48	15	45	12	6.3%	20.0%
			LKD		W11/F04	23	22.1	0.9	3.9%					47	14	44	11	6.4%	21.4%
	R4	RESIDENTIAL	BEDROOM		W12/F04	22.8	22.4	0.4	1.8%	74.1	74.1	0.0	0.0%	39	9	38	8	2.6%	11.1%
			BEDROOM		W13/F04	22.9	22.5	0.4	1.7%					44	10	43	9	2.3%	10.0%
	R5	RESIDENTIAL	BEDROOM		W14/F04	23.6	23.5	0.1	0.4%	84.6	84.6	0.0	0.0%	47	12	46	11	2.1%	8.3%
			BEDROOM		W15/F04	23.4	23.2	0.2	0.9%					48	13	46	11	4.2%	15.4%
	R6	RESIDENTIAL	LKD		W16/F04	25.1	25.1	0	0.0%	98.9	98.9	0.0	0.0%	43	8	43	8	0.0%	0.0%
			LKD		W17/F04	26.9	26.8	0.1	0.4%					53	12	52	11	1.9%	8.3%
			LKD		W18/F04	37.4	37.4	0	0.0%					17	2	17	2	0.0%	0.0%
			LKD		W19/F04	37.8	37.8	0	0.0%					18	2	18	2	0.0%	0.0%
			LKD		W20/F04	38.1	38.1	0	0.0%					20	2	20	2	0.0%	0.0%

1 EBURY SQUARE-BLOCK B

F00	R1	RESIDENTIAL	RECEPTION		W1/F00	0.4	0.4	0	0.0%	43.3	41.4	6.4	4.3%	0	0	0	0	0.0%	0.0%
			RECEPTION		W2/F00	0.5	0.5	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W3/F00	0.6	0.6	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W4/F00	0.7	0.7	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W5/F00	0.7	0.7	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W15/F00	9.9	9.8	0.1	1.0%					19	7	19	7	0.0%	0.0%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			RECEPTION		W16/F00	11	9.7	1.3	11.8%					24	12	19	7	20.8%	41.7%
	R2	RESIDENTIAL	BEDROOM		W6/F00	0.3	0	0.3	100.0%	29.3	20.4	1.5	30.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W7/F00	0	0	0	-	12.3	12.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4 (3)	RESIDENTIAL	LIVING ROOM		W8/F00	1.3	0.2	1.1	84.6%	33.8	20	6.3	40.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R7 (3)	RESIDENTIAL	LIVING ROOM		W12/F00	12.4	10	2.4	19.4%	85.4	84.7	0.5	0.9%	28	6	24	3	14.3%	50.0%
	R8 (3)	RESIDENTIAL	LIVING ROOM		W13/F00	13.5	11.1	2.4	17.8%	97.6	96.1	0.8	1.5%	29	7	25	4	13.8%	42.9%
	R9 (3)	RESIDENTIAL	LIVING ROOM		W14/F00	14.1	12	2.1	14.9%	97.5	97.4	0.0	0.1%	28	9	24	5	14.3%	44.4%
	R10 (3)	RESIDENTIAL	LIVING ROOM		W17/F00	14.1	13.2	0.9	6.4%	99.9	99.9	0.0	0.0%	31	12	27	8	12.9%	33.3%
	R11 (3)	RESIDENTIAL	LIVING ROOM		W18/F00	13.6	13	0.6	4.4%	98.4	98.4	0.0	0.1%	30	12	29	11	3.3%	8.3%
	R12 (3)	RESIDENTIAL	LIVING ROOM		W19/F00	12.9	12.5	0.4	3.1%	96.4	96.3	0.0	0.1%	27	13	26	12	3.7%	7.7%
F01	R1	RESIDENTIAL	LKD		W1/F01	25.3	25.3	0	0.0%	91	91	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F01	22	22	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F01	20.3	20.3	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F01	19.4	19.4	0	0.0%	35.6	35.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F01	18.4	18.3	0.1	0.5%	28.6	28.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F01	17.5	17.5	0	0.0%	35.2	35.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F01	17.2	17.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F01	1.4	1.4	0	0.0%	3.6	3.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F01	1.3	1.3	0	0.0%	3.7	3.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F01	16.8	16.7	0.1	0.6%	34.7	33.7	0.2	2.8%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F01	16.9	16.7	0.2	1.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F01	17.5	16.9	0.6	3.4%	26.9	26.3	0.2	2.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F01	18	16.8	1.2	6.7%	28.6	27.5	0.3	4.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F01	18.4	16.5	1.9	10.3%	75.1	60.2	3.5	19.9%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F01	19.4	16.8	2.6	13.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F01	21.5	17.8	3.7	17.2%	95.4	72	10.2	24.6%	17	1	3	1	32.4%	6.0%
			BEDROOM		W17/F01	23.5	6.8	16.7	71.1%					55	14	12	0	78.2%	100.0%
			BEDROOM		W18/F01	24.7	6.4	18.3	74.1%					60	16	11	0	81.7%	100.0%
	R14	RESIDENTIAL	BEDROOM		W21/F01	24.2	5.9	18.3	75.6%	73.7	7.1	12.9	90.4%	55	11	10	0	81.8%	100.0%
	R15	RESIDENTIAL	LKD		W22/F01	22.7	5.8	16.9	74.4%	77.7	77	0.9	0.8%	52	9	11	1	78.8%	88.9%
			LKD		W23/F01	11.3	8.7	2.6	23.0%					24	6	18	2	25.0%	66.7%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 4

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			LKD		W24/F01	4.8	0.8	4	83.3%					20	8	10	1	50.0%	87.5%
			LKD		W25/F01	30.2	24.2	6	19.9%					55	11	39	5	29.1%	54.5%
			LKD		W26/F01	30	24.7	5.3	17.7%					54	13	40	5	25.9%	61.5%
			LKD		W27/F01	30.9	26.1	4.8	15.5%					54	13	42	5	22.2%	61.5%
	R16	RESIDENTIAL	BEDROOM		W28/F01	12.6	11.2	1.4	11.1%	57.9	54.9	1.0	5.2%	26	8	23	5	11.5%	37.5%
	R17	RESIDENTIAL	LKD		W29/F01	31.3	27.4	3.9	12.5%	85.2	85	0.2	0.2%	59	19	46	8	22.0%	57.9%
			LKD		W30/F01	31.3	27.8	3.5	11.2%					59	19	49	10	16.9%	47.4%
			LKD		W31/F01	5.1	5.1	0	0.0%					14	1	14	1	0.0%	0.0%
			LKD		W32/F01	13.2	12.5	0.7	5.3%					26	8	25	7	3.8%	12.5%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F01	12.9	12.7	0.2	1.6%	97.2	97.2	0.0	0.0%	27	9	26	8	3.7%	11.1%
	R19	RESIDENTIAL	BEDROOM		W34/F01	30.7	28.4	2.3	7.5%	99.1	99.1	0.0	0.0%	62	22	52	12	16.1%	45.5%
	R21	RESIDENTIAL	LKD		W35/F01	30.4	28.4	2	6.6%	84.5	84.5	0.0	0.0%	62	22	54	14	12.9%	36.4%
			LKD		W36/F01	12.7	12.7	0	0.0%					27	9	27	9	0.0%	0.0%
	R22 (3)	RESIDENTIAL	LKD		W37/F01	29.3	27.8	1.5	5.1%	85.1	85.1	0.0	0.0%	61	21	55	15	9.8%	28.6%
			LKD		W38/F01	27.5	26.4	1.1	4.0%					51	17	49	15	3.9%	11.8%
	R23	RESIDENTIAL	BEDROOM		W39/F01	27.6	26.4	1.2	4.3%	92.9	92.9	0.0	0.0%	55	20	50	15	9.1%	25.0%
			BEDROOM		W40/F01	19	19	0	0.0%					11	3	11	3	0.0%	0.0%
			BEDROOM		W41/F01	11.4	11.4	0	0.0%					22	9	22	9	0.0%	0.0%
F02	R1	RESIDENTIAL	LKD		W1/F02	28.1	28.1	0	0.0%	92.8	92.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F02	25.4	25.4	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F02	24	24	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F02	23.3	23.3	0	0.0%	43.4	43.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F02	22.4	22.4	0	0.0%	36.9	36.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F02	21.7	21.7	0	0.0%	49.1	49.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F02	21.5	21.5	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F02	4.1	4.1	0	0.0%	12	12	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F02	4	4	0	0.0%	11.1	11.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F02	21.2	21.1	0.1	0.5%	48.6	48.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F02	21.3	21.1	0.2	0.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F02	21.7	21.3	0.4	1.8%	35.2	35.2	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F02	22.1	21.2	0.9	4.1%	35.8	35.8	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R10	RESIDENTIAL	BEDROOM		W14/F02	22.5	20.9	1.6	7.1%	84	75.8	1.9	9.8%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F02	23.4	21.2	2.2	9.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F02	25.1	21.8	3.3	13.1%	96.6	75.7	9.1	21.6%	18	0	8	0	55.6%	0.0%
			BEDROOM		W17/F02	26.4	9	17.4	65.9%					62	16	19	1	69.4%	93.8%
			BEDROOM		W18/F02	27.5	8.4	19.1	69.5%					66	17	18	1	72.7%	94.1%
	R14	RESIDENTIAL	BEDROOM		W21/F02	27.2	7.5	19.7	72.4%	77.7	10.2	13.1	86.9%	64	15	12	1	81.3%	93.3%
	R15	RESIDENTIAL	LKD		W22/F02	26	7.3	18.7	71.9%	84.4	83.3	1.6	1.4%	64	14	13	1	79.7%	92.9%
			LKD		W23/F02	12.6	9.4	3.2	25.4%					26	8	20	3	23.1%	62.5%
			LKD		W24/F02	6	0.9	5.1	85.0%					23	11	10	1	56.5%	90.9%
			LKD		W25/F02	32.3	25.6	6.7	20.7%					60	16	41	6	31.7%	62.5%
			LKD		W26/F02	31.2	25.3	5.9	18.9%					57	18	41	6	28.1%	66.7%
			LKD		W27/F02	32.8	27.5	5.3	16.2%					61	19	46	7	24.6%	63.2%
	R16	RESIDENTIAL	BEDROOM		W28/F02	13.6	12.1	1.5	11.0%	63.5	60.7	1.0	4.4%	27	9	24	6	11.1%	33.3%
	R17	RESIDENTIAL	LKD		W29/F02	33	28.9	4.1	12.4%	91.8	91.3	0.4	0.5%	63	21	51	10	19.0%	52.4%
			LKD		W30/F02	32.9	29.3	3.6	10.9%					63	22	51	11	19.0%	50.0%
			LKD		W31/F02	5.6	5.6	0	0.0%					15	5	15	5	0.0%	8.0%
			LKD		W32/F02	14.1	13.4	0.7	5.0%					27	9	26	8	3.7%	11.1%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F02	13.8	13.6	0.2	1.4%	97.4	97.4	0.0	0.0%	27	9	26	8	3.7%	11.1%
	R19	RESIDENTIAL	BEDROOM		W34/F02	32.2	29.9	2.3	7.1%	99.2	99.2	0.0	0.0%	62	22	54	14	12.9%	36.4%
	R20	RESIDENTIAL	LKD		W35/F02	31.9	29.9	2	6.3%	87.3	87.2	0.0	0.0%	62	22	55	15	11.3%	31.8%
			LKD		W36/F02	13.6	13.6	0	0.0%					27	9	27	9	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F02	30.8	29.2	1.6	5.2%	92.9	92.7	0.1	0.2%	62	22	57	17	8.1%	22.7%
			LKD		W38/F02	27.6	26.5	1.1	4.0%					51	17	49	15	3.9%	11.8%
	R22	RESIDENTIAL	BEDROOM		W39/F02	29.1	27.9	1.2	4.1%	93.2	93.2	0.0	0.0%	57	20	52	15	8.8%	25.0%
			BEDROOM		W40/F02	2.3	2.3	0	0.0%					12	2	12	2	0.0%	0.0%
			BEDROOM		W41/F02	12.1	12.1	0	0.0%					22	9	22	9	0.0%	0.0%
F03	R1	RESIDENTIAL	LKD		W1/F03	31.6	31.6	0	0.0%	97	97	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F03	29.5	29.5	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F03	28.5	28.5	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F03	28.1	28.1	0	0.0%	64.9	64.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F03	27.5	27.5	0	0.0%	56.5	56.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R4	RESIDENTIAL	BEDROOM		W6/F03	26.8	26.8	0	0.0%	78.4	78.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F03	26.6	26.6	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F03	7.2	7.2	0	0.0%	29.5	29.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F03	7.2	7.2	0	0.0%	28.7	28.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F03	26.4	26.3	0.1	0.4%	79.1	79.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F03	26.5	26.3	0.2	0.8%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F03	27	26.6	0.4	1.5%	55.5	55.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F03	27.3	26.6	0.7	2.6%	54.6	54.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F03	27.4	26.2	1.2	4.4%	94.2	94.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F03	28.1	26.4	1.7	6.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F03	29.6	26.8	2.8	9.5%	96.7	79.1	7.7	18.2%	63	15	15	4	34.6%	100.0%
			BEDROOM		W17/F03	29.6	12.2	17.4	58.8%					66	17	28	1	57.6%	94.1%
			BEDROOM		W18/F03	30.6	11.4	19.2	62.7%					69	19	26	1	62.3%	94.7%
	R14	RESIDENTIAL	BEDROOM		W21/F03	30.5	9.8	20.7	67.9%	82.5	14.4	13.2	82.5%	68	18	20	1	70.6%	94.4%
	R15	RESIDENTIAL	LKD		W22/F03	29.5	9.5	20	67.8%	90.6	89.8	1.0	0.8%	69	18	18	1	73.9%	94.4%
			LKD		W23/F03	13.8	10.1	3.7	26.8%					27	9	20	3	25.9%	66.7%
			LKD		W24/F03	7.2	11	6.1	84.7%					25	13	10	1	60.0%	92.3%
			LKD		W25/F03	34.3	27.1	7.2	21.0%					64	20	45	6	29.7%	70.0%
			LKD		W26/F03	33.7	27.5	6.2	18.4%					60	18	45	6	25.0%	66.7%
			LKD		W27/F03	34.5	29	5.5	15.9%					61	19	47	7	23.0%	63.2%
	R16	RESIDENTIAL	BEDROOM		W28/F03	14.4	13	1.4	9.7%	69.4	66.7	0.9	3.8%	27	9	25	7	7.4%	22.2%
	R17	RESIDENTIAL	LKD		W29/F03	34.5	30.4	4.1	11.9%	93.4	92.1	1.2	1.4%	66	23	54	11	18.2%	52.2%
			LKD		W30/F03	34.4	30.8	3.6	10.5%					65	23	55	13	15.4%	43.5%
			LKD		W31/F03	6.2	6.2	0	0.0%					17	2	17	2	0.0%	0.0%
			LKD		W32/F03	14.9	14.2	0.7	4.7%					28	10	27	9	3.6%	10.0%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F03	14.6	14.4	0.2	1.4%	97.5	97.5	0.0	0.0%	28	10	27	9	3.6%	10.0%
	R19	RESIDENTIAL	BEDROOM		W34/F03	33.6	31.4	2.2	6.5%	99.2	99.2	0.0	0.0%	63	23	56	16	11.1%	30.4%
	R20	RESIDENTIAL	LKD		W35/F03	33.3	31.4	1.9	5.7%	88.4	88.4	0.0	0.0%	63	23	57	17	9.5%	26.1%
			LKD		W36/F03	14.4	14.4	0	0.0%					28	10	28	10	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F03	32.1	30.6	1.5	4.7%	95.5	95.5	0.0	0.0%	63	23	58	18	7.9%	21.7%
			LKD		W38/F03	30.2	29.2	1	3.3%					53	18	51	16	3.8%	11.1%

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R22	RESIDENTIAL	BEDROOM		W39/F03	30.4	29.3	1.1	3.6%	93.3	93.3	0.0	0.0%	58	21	55	18	5.2%	14.3%
			BEDROOM		W40/F03	2.7	2.7	0	0.0%					14	2	14	2	0.0%	0.0%
			BEDROOM		W41/F03	12.8	12.8	0	0.0%					25	10	25	10	0.0%	0.0%
F04	R1	RESIDENTIAL	LKD		W1/F04	35.1	35.1	0	0.0%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F04	33.9	33.9	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F04	33.3	33.3	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F04	33.2	33.3	-0.1	-0.3%	99.6	99.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F04	32.8	32.8	0	0.0%	82.1	82.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F04	32.2	32.3	-0.1	-0.3%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F04	32.1	32.1	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F04	10.5	10.5	0	0.0%	66.1	66.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F04	10.5	10.5	0	0.0%	65.6	65.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F04	32	31.9	0.1	0.3%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F04	32	31.9	0.1	0.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F04	32.5	32.2	0.3	0.9%	89.4	89.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F04	32.7	32.2	0.5	1.5%	90.2	90.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F04	32.6	31.8	0.8	2.5%	99	98.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F04	33	31.9	1.1	3.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F04	33.9	32	1.9	5.6%	98	87.2	4.7	11.0%	26	2	21	0	18.2%	100.0%
			BEDROOM		W17/F04	33	16.7	16.3	49.4%					72	21	40	1	44.4%	95.2%
			BEDROOM		W18/F04	33.7	15.5	18.2	54.0%					75	23	39	1	48.0%	95.7%
	R14	RESIDENTIAL	BEDROOM		W21/F04	33.6	12.7	20.9	62.2%	95.8	20	14.7	79.2%	73	22	29	1	60.3%	95.5%
	R15	RESIDENTIAL	LKD		W22/F04	33	12.4	20.6	62.4%	92.7	90.8	2.5	2.0%	72	21	29	1	59.7%	95.2%
			LKD		W23/F04	14.7	10.9	3.8	25.9%					27	9	20	3	25.9%	66.7%
			LKD		W24/F04	8.1	1.4	6.7	82.7%					26	14	12	2	53.8%	85.7%
			LKD		W25/F04	36	28.7	7.3	20.3%					65	21	48	7	26.2%	66.7%
			LKD		W26/F04	34.4	28.2	6.2	18.0%					59	20	44	7	25.4%	65.0%
			LKD		W27/F04	36	30.6	5.4	15.0%					66	22	52	9	21.2%	59.1%
	R16	RESIDENTIAL	BEDROOM		W28/F04	15.2	13.8	1.4	9.2%	72.7	70.4	0.8	3.1%	28	10	26	8	7.1%	20.0%
	R17	RESIDENTIAL	LKD		W29/F04	35.9	32	3.9	10.9%	94.4	92.4	1.8	2.1%	66	23	55	12	16.7%	47.8%
			LKD		W30/F04	35.8	32.3	3.5	9.8%					66	23	57	14	13.6%	39.1%

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES	%	%		%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			LKD		W31/F04	6.7	6.7	0	0.0%					18	8	18	8	0.0%	0.0%
			LKD		W32/F04	15.7	15	0.7	4.5%					28	10	27	9	3.6%	10.0%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F04	15.3	15.2	0.1	0.7%	97.6	97.6	0.0	0.0%	28	10	27	9	3.6%	10.0%
	R19	RESIDENTIAL	BEDROOM		W34/F04	35	32.9	2.1	6.0%	99.2	99.2	0.0	0.0%	65	23	59	17	9.2%	26.1%
	R20	RESIDENTIAL	LKD		W35/F04	34.7	32.8	1.9	5.5%	90.2	90.2	0.0	0.0%	64	23	58	17	9.4%	26.1%
			LKD		W36/F04	15.2	15.2	0	0.0%					28	10	28	10	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F04	33.7	32.3	1.4	4.2%	96	95.9	0.0	0.0%	63	23	60	20	4.8%	13.0%
			LKD		W38/F04	30.2	29.3	0.9	3.0%					52	18	51	17	1.9%	5.6%
	R22	RESIDENTIAL	BEDROOM		W39/F04	32	30.9	1.1	3.4%	93.4	93.4	0.0	0.0%	62	22	59	19	4.8%	13.6%
			BEDROOM		W40/F04	3.3	3.3	0	0.0%					15	2	15	2	0.0%	0.0%
			BEDROOM		W41/F04	13.6	13.6	0	0.0%					26	10	26	10	0.0%	0.0%
F05	R1	RESIDENTIAL	LKD		W1/F05	37.1	37.1	0	0.0%	99.5	99.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F05	36	36	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F05	35.8	35.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F05	36.5	36.5	0	0.0%	99.8	99.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F05	36.3	36.4	-0.1	-0.3%	89.4	89.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F05	35.4	35.4	0	0.0%	99.6	99.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F05	35.2	35.3	-0.1	-0.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F05	12.6	12.6	0	0.0%	87.4	87.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F05	12.6	12.6	0	0.0%	86.6	86.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F05	35.4	35.4	0	0.0%	99.5	99.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F05	35.2	35.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F05	36.3	36.2	0.1	0.3%	95.6	95.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F05	36.2	36	0.2	0.6%	96.8	96.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F05	35.6	35.4	0.2	0.6%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F05	35.7	35.2	0.5	1.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F05	36.7	35.9	0.8	2.2%	98	92.3	2.5	5.8%	54	8	25	1	9.3%	66.7%
			BEDROOM		W17/F05	36.2	22.7	13.5	37.3%					77	26	56	7	27.3%	73.1%
			BEDROOM		W18/F05	36.5	20.9	15.6	42.7%					78	26	51	3	34.6%	88.5%
	R14	RESIDENTIAL	BEDROOM		W21/F05	36.5	16.1	20.4	55.9%	96.4	26.7	13.6	72.3%	79	27	41	2	48.1%	92.6%
	R15	RESIDENTIAL	LKD		W22/F05	36.1	16	20.1	55.7%	94.5	91.6	3.8	3.1%	79	27	38	4	51.9%	85.2%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			LKD		W23/F05	18.1	14.2	3.9	21.5%					32	10	25	4	21.9%	60.0%
			LKD		W24/F05	8.8	1.9	6.9	78.4%					31	16	17	3	45.2%	81.3%
			LKD		W25/F05	35.6	28.6	7	19.7%					63	22	47	8	25.4%	63.6%
			LKD		W26/F05	36.4	30.6	5.8	15.9%					62	21	49	8	21.0%	61.9%
			LKD		W27/F05	35.5	30.5	5	14.1%					63	22	51	10	19.0%	54.5%
	R16	RESIDENTIAL	BEDROOM		W28/F05	18.6	17.3	1.3	7.0%	73.5	72.1	0.5	1.9%	32	10	30	8	6.3%	20.0%
	R17	RESIDENTIAL	LKD		W29/F05	35.3	31.7	3.6	10.2%	95	93.3	1.6	1.8%	63	22	54	13	14.3%	40.9%
			LKD		W30/F05	35	32.2	2.8	8.0%					57	18	51	12	10.5%	33.3%
			LKD		W31/F05	7.6	7.6	0	0.0%					19	2	19	2	0.0%	0.0%
			LKD		W32/F05	19.2	18.3	0.9	4.7%					33	12	31	10	6.1%	16.7%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F05	18.7	18.6	0.1	0.5%	97.8	97.8	0.0	0.0%	33	10	32	9	3.0%	10.0%
	R19	RESIDENTIAL	BEDROOM		W34/F05	34.5	32.6	1.9	5.5%	98.6	98.6	0.0	0.0%	62	22	56	16	9.7%	27.3%
	R20	RESIDENTIAL	LKD		W35/F05	33.9	32.6	1.3	3.8%	90.4	90.4	0.0	0.0%	56	18	54	16	3.6%	11.1%
			LKD		W36/F05	18.9	18.8	0.1	0.5%					34	12	34	12	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F05	32.9	32	0.9	2.7%	96.6	96.6	0.0	0.0%	53	18	52	17	1.9%	5.6%
			LKD		W38/F05	33.6	32.4	1.2	3.6%					59	22	56	19	5.1%	13.6%
	R22	RESIDENTIAL	BEDROOM		W39/F05	31.5	30.8	0.7	2.2%	93.3	93.3	0.0	0.0%	53	18	52	17	1.9%	5.6%
			BEDROOM		W40/F05	4.4	4.4	0	0.0%					15	2	15	2	0.0%	0.0%
			BEDROOM		W41/F05	17.4	17.4	0	0.0%					32	12	32	12	0.0%	0.0%
F06	R1	RESIDENTIAL	BEDROOM		W1/F06	34.6	34.6	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W2/F06	38.8	38.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W3/F06	38.7	38.7	0	0.0%	97.6	97.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W5/F06	25.7	25.7	0	0.0%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W6/F06	30.8	30.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F06	25	25	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5 (3)	RESIDENTIAL	BEDROOM		W8/F06	38	38	0	0.0%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6 (3)	RESIDENTIAL	BEDROOM		W9/F06	38	38	0	0.0%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F06	24.2	24.2	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F06	31.2	31.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W12/F06	25.9	25.9	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R9 (3)	RESIDENTIAL	BEDROOM		W14/F06	38.7	38.6	0.1	0.3%	98	98	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 10

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R10	RESIDENTIAL	BEDROOM		W15/F06	38.9	38.7	0.2	0.5%	100	100	0.0	0.0%	75	7	31	3	1.1%	14.2%
			BEDROOM		W16/F06	38.9	29.5	9.4	24.2%					79	28	66	15	16.5%	46.4%
	R11	RESIDENTIAL	LKD		W17/F06	37.5	25.4	12.1	32.3%	100	100	0.0	0.0%	67	25	49	7	26.9%	72.0%
			LKD		W18/F06	38.9	23.9	15	38.6%					80	28	58	8	27.5%	71.4%
			LKD		W19/F06	38	32.4	5.6	14.7%					67	23	58	14	13.4%	39.1%
	R12	RESIDENTIAL	BEDROOM		W20/F06	37.9	33.2	4.7	12.4%	85.3	85.2	0.0	0.1%	67	23	60	16	10.4%	30.4%
			BEDROOM		W21/F06	37.8	34	3.8	10.1%					67	23	60	16	10.4%	30.4%
	R13	RESIDENTIAL	BEDROOM		W22/F06	28.7	28.1	0.6	2.1%	100	100	0.0	0.0%	37	9	36	8	2.7%	11.1%
			BEDROOM		W23/F06	33.8	30.9	2.9	8.6%					52	16	47	11	9.6%	31.3%
			BEDROOM		W24/F06	27.1	24.2	2.9	10.7%					55	20	50	15	9.1%	25.0%
	R14	RESIDENTIAL	LKD		W25/F06	36.3	35	1.3	3.6%	94.2	94.2	0.0	0.0%	64	20	61	17	4.7%	15.0%
	R15	RESIDENTIAL	LKD		W26/F06	37	35.1	1.9	5.1%	94.2	94.2	0.0	0.0%	67	23	64	20	4.5%	13.0%
	R16	RESIDENTIAL	BEDROOM		W27/F06	25.1	25.1	0	0.0%	99.2	99.2	0.0	0.0%	32	5	32	5	0.0%	0.0%
			BEDROOM		W28/F06	31.6	31.5	0.1	0.3%					48	15	47	14	2.1%	6.7%
			BEDROOM		W29/F06	27.9	27.1	0.8	2.9%					55	19	52	16	5.5%	15.8%
	R17	RESIDENTIAL	BEDROOM		W30/F06	36.1	34.9	1.2	3.3%	85.8	85.8	0.0	0.0%	64	23	62	21	3.1%	8.7%
			BEDROOM		W31/F06	35.8	34.7	1.1	3.1%					63	23	61	21	3.2%	8.7%
	R18	RESIDENTIAL	LKD		W32/F06	35	34.1	0.9	2.6%	100	100	0.0	0.0%	63	23	62	22	1.6%	4.3%
			LKD		W33/F06	29.9	29.9	0	0.0%							15		0.0%	0.0%
			LKD		W34/F06	32.1	32.1	0	0.0%					9	0	9	0	0.0%	0.0%
F07	R1	RESIDENTIAL	BEDROOM		W1/F07	34.3	34.3	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W2/F07	13.8	13.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W3/F07	7.2	7.2	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W4/F07	39.2	39.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F07	25.9	25.9	0	0.0%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W6/F07	31.8	31.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F07	26.1	26.1	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R4 (3)	RESIDENTIAL	BEDROOM		W8/F07	39.2	39.1	0.1	0.3%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R5 (3)	RESIDENTIAL	BEDROOM		W9/F07	39.2	39.2	0	0.0%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W10/F07	25	25	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F07	31.4	31.4	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 11

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)

			BEDROOM		W12/F07	26.2	26.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W13/F07	39.2	39.2	0	0.0%	100	100	0.0	0.0%	31	3	31		0.0%	0.0%
			BEDROOM		W14/F07	7.2	6.9	0.3	4.2%					14	4	14	4	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W15/F07	13.8	13.8	0	0.0%	100	100	0.0	0.0%	11	1	10		0.0%	0.0%
			BEDROOM		W16/F07	37.1	30.2	6.9	18.6%					72	26	64	18	11.1%	30.8%
	R9	RESIDENTIAL	LKD		W17/F07	37.5	28.7	8.8	23.5%	100	100	0.0	0.0%	70	25	61	16	12.9%	36.0%
			LKD		W18/F07	37.9	27	10.9	28.8%					73	27	60	14	17.8%	48.1%
			LKD		W19/F07	13.7	10.2	3.5	25.5%					19	12	15	8	21.1%	33.3%
	R10	RESIDENTIAL	BEDROOM		W20/F07	7.1	2	5.1	71.8%	87.7	86.8	0.4	1.1%	14	12	7	5	50.0%	58.3%
			BEDROOM		W21/F07	38.4	35	3.4	8.9%					67	23	62	18	7.5%	21.7%
	R11	RESIDENTIAL	BEDROOM		W22/F07	30	29.5	0.5	1.7%	100	100	0.0	0.0%	37	9	37	9	0.0%	0.0%
			BEDROOM		W23/F07	35.8	33.5	2.3	6.4%					58	16	54	12	6.9%	25.0%
			BEDROOM		W24/F07	29.7	27.3	2.4	8.1%					60	21	57	18	5.0%	14.3%
	R12	RESIDENTIAL	LKD		W25/F07	38.4	36.3	2.1	5.5%	94.4	94.4	0.0	0.0%	67	23	64	20	4.5%	13.0%
	R13	RESIDENTIAL	LKD		W26/F07	38.1	36.5	1.6	4.2%	94.4	94.4	0.0	0.0%	67	23	65	21	3.0%	8.7%
	R14	RESIDENTIAL	BEDROOM		W27/F07	27.9	27.9	0	0.0%	99.2	99.2	0.0	0.0%	33	6	33	6	0.0%	0.0%
			BEDROOM		W28/F07	34.7	34	0.7	2.0%					56	15	56	15	0.0%	0.0%
			BEDROOM		W29/F07	29.6	28.6	1	3.4%					59	20	58	19	1.7%	5.0%
	R15	RESIDENTIAL	BEDROOM		W30/F07	37.2	36.3	0.9	2.4%	86.9	86.9	0.0	0.0%	65	23	64	22	1.5%	4.3%
			BEDROOM		W31/F07	3.1	3.1	0	0.0%					3	0	3	0	0.0%	0.0%
	R16	RESIDENTIAL	LKD		W32/F07	11.7	11.7	0	0.0%	100	100	0.0	0.0%	15	8	15	8	0.0%	0.0%
			LKD		W33/F07	32.1	32.1	0	0.0%					15	3	15	3	0.0%	0.0%
			LKD		W34/F07	34.3	34.3	0	0.0%					14	0	14	0	0.0%	0.0%

11 PIMLICO ROAD

F02	R1	RESIDENTIAL	LIVING ROOM		W1/F02	29.4	22	7.4	25.2%	99.2	99	0.1	0.2%	N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W2/F02	29.6	21.8	7.8	26.4%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W3/F02	29.6	21.7	7.9	26.7%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W4/F02	29.7	21.5	8.2	27.6%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W5/F02	29.6	21.1	8.5	28.7%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W6/F02	29.9	14.3	15.6	52.2%					N/A	N/A	N/A	N/A	N/A	N/A

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

11 PIMLICO ROAD (CONTINUED)																			
			LIVING ROOM		W7/F02	30.2	14.6	15.6	51.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W8/F02	30.3	14.8	15.5	51.2%	74	28.4	5.1	61.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	BEDROOM		W9/F02	30.3	14.9	15.4	50.8%	82.1	20.3	13.0	75.3%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W10/F02	30.3	15	15.3	50.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	LIVING ROOM		W11/F02	29.9	14.9	15	50.2%	92.5	47.2	16.2	48.9%	N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W12/F02	30.3	16.1	14.2	46.9%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W13/F02	30.2	18.4	11.8	39.1%					N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN-RESI		W1/F03	32.3	23.9	8.4	26.0%	84.6	74.5	2.8	11.9%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W2/F03	32.4	23.7	8.7	26.9%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W3/F03	32.5	23.5	9	27.7%					N/A	N/A	N/A	N/A	N/A	N/A

KILMUIR HOUSE																			
F00	R2	RESIDENTIAL	BEDROOM		W7/F00	20	19.8	0.2	1.0%	38.9	38.8	0.0	0.2%	30	6	28	4	6.7%	33.3%
	R3	RESIDENTIAL	BEDROOM		W8/F00	21.3	21.2	0.1	0.5%	39.8	39.8	0.0	0.0%	37	9	36	8	2.7%	11.1%
	R4	RESIDENTIAL	LIVING ROOM		W9/F00	15	14.9	0.1	0.7%	30.2	30.2	0.0	0.0%	39	10	38	9	2.6%	10.0%
	R5 (3)	RESIDENTIAL	LIVING ROOM		W10/F00	11.2	11.1	0.1	0.9%	32.7	32.7	0.0	0.0%	21	7	20	6	4.8%	14.3%
	R6	RESIDENTIAL	BEDROOM		W11/F00	21.2	21.1	0.1	0.5%	38.6	38.4	0.0	0.5%	32	5	31	4	3.1%	20.0%
	R7	RESIDENTIAL	BEDROOM		W12/F00	23.1	23	0.1	0.4%	37.3	37.3	0.0	0.0%	40	8	39	7	2.5%	12.5%
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	29.4	28.8	0.6	2.0%	92.4	92	0.0	0.5%	66	16	65	15	1.5%	6.3%
	R2	RESIDENTIAL	BEDROOM		W2/F01	24.3	23.9	0.4	1.6%	50.5	46.6	0.5	7.8%	51	14	51	14	0.0%	0.0%
	R3 (3)	RESIDENTIAL	LIVING ROOM		W3/F01	18.1	17.8	0.3	1.7%	40	35.8	0.7	10.3%	50	14	50	14	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F01	22.3	22.1	0.2	0.9%	44.9	44.8	0.0	0.1%	35	7	35	7	0.0%	0.0%
	R5	RESIDENTIAL	BEDROOM		W5/F01	22.6	22.5	0.1	0.4%	45.5	45.5	0.0	0.0%	43	11	43	11	0.0%	0.0%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F01	13.3	13.2	0.1	0.8%	34.6	34	0.1	1.9%	30	12	30	12	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F01	17.5	17.4	0.1	0.6%	39	39	0.0	0.0%	28	9	28	9	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F01	24.4	24.4	0	0.0%	47	46.9	0.0	0.0%	42	9	42	9	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F01	25.3	25.3	0	0.0%	46.2	46.2	0.0	0.0%	48	12	48	12	0.0%	0.0%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	32.3	31.7	0.6	1.9%	86.8	80.7	0.9	7.0%	71	20	70	19	1.4%	5.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	27	26.5	0.5	1.9%	61.2	58.1	0.4	5.2%	57	17	55	15	3.5%	11.8%
	R3	RESIDENTIAL	LKD		W3/F02	20.7	20.4	0.3	1.4%	77.7	75.8	0.5	2.4%	54	14	54	14	0.0%	0.0%
			LKD		W10/F02	22.4	22.4	0	0.0%					29	5	29	5	0.0%	0.0%

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES	%	%		%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
KILMUIR HOUSE (CONTINUED)																			
	R4	RESIDENTIAL	BEDROOM		W4/F02	24.9	24.7	0.2	0.8%	57.3	57.3	0.0	0.1%	40	9	39	8	2.5%	11.1%
	R5	RESIDENTIAL	BEDROOM		W5/F02	26.1	26	0.1	0.4%	58	58	0.0	0.0%	48	13	47	12	2.1%	7.7%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F02	19.9	19.8	0.1	0.5%	43.3	42.9	0.1	0.9%	50	12	50	12	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F02	16.1	16	0.1	0.6%	45	45	0.0	0.1%	32	9	32	9	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F02	25.9	25.8	0.1	0.4%	58.4	58.4	0.0	0.0%	42	8	42	8	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F02	27.6	27.6	0	0.0%	57.7	57.7	0.0	0.0%	51	12	51	12	0.0%	0.0%
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	35	34.3	0.7	2.0%	90.8	84.5	0.9	6.9%	77	25	75	23	2.6%	8.0%
	R2	RESIDENTIAL	BEDROOM		W2/F03	29.5	28.9	0.6	2.0%	77	75.8	0.2	1.6%	62	19	59	16	4.8%	15.8%
	R3	RESIDENTIAL	LKD		W3/F03	23.2	22.7	0.5	2.2%	80.2	80.2	0.0	0.0%	60	18	58	16	3.3%	11.1%
			LKD		W10/F03	24.1	24.1	0	0.0%					31	8	31	8	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F03	27.5	27.1	0.4	1.5%	74.8	74.8	0.0	0.0%	44	10	43	9	2.3%	10.0%
	R5	RESIDENTIAL	BEDROOM		W5/F03	27.8	27.5	0.3	1.1%	75.7	75.7	0.0	0.0%	52	14	51	13	1.9%	7.1%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F03	18.4	18.2	0.2	1.1%	54.1	52.1	0.3	3.6%	38	14	38	14	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F03	22.4	22.2	0.2	0.9%	58.2	58.2	0.0	0.0%	35	11	35	11	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F03	29.3	29.2	0.1	0.3%	75.9	75.9	0.0	0.0%	50	12	49	11	2.0%	8.3%
	R9	RESIDENTIAL	BEDROOM		W9/F03	30.1	29.9	0.2	0.7%	75	75	0.0	0.0%	55	15	54	14	1.8%	6.7%
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	36.9	36.1	0.8	2.2%	91.9	87.1	0.7	5.2%	79	27	77	25	2.5%	7.4%
	R2	RESIDENTIAL	BEDROOM		W2/F04	31.7	30.8	0.9	2.8%	95.4	93.9	0.2	1.6%	64	20	61	17	4.7%	15.0%
	R3	RESIDENTIAL	LKD		W3/F04	25.7	25	0.7	2.7%	84	84	0.0	0.0%	64	20	61	17	4.7%	15.0%
			LKD		W10/F04	25.7	25.7	0	0.0%					32	7	32	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F04	29.8	29.1	0.7	2.3%	90.9	90.2	0.1	0.7%	48	13	45	10	6.3%	23.1%
	R5	RESIDENTIAL	BEDROOM		W5/F04	31	30.4	0.6	1.9%	93.1	92.7	0.0	0.4%	56	17	54	15	3.6%	11.8%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F04	24.9	24.4	0.5	2.0%	73.4	70.5	0.5	4.0%	61	18	59	16	3.3%	11.1%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F04	20.9	20.5	0.4	1.9%	72.9	72.7	0.0	0.3%	42	15	40	13	4.8%	13.3%
	R8	RESIDENTIAL	BEDROOM		W8/F04	30.6	30.1	0.5	1.6%	94.1	94	0.0	0.1%	50	13	48	11	4.0%	15.4%
	R9	RESIDENTIAL	BEDROOM		W9/F04	32.1	31.7	0.4	1.2%	92.7	92.7	0.0	0.0%	58	17	57	16	1.7%	5.9%
F05	R1	RESIDENTIAL	BEDROOM		W1/F05	38	37.1	0.9	2.4%	92.3	90.7	0.2	1.7%	79	27	79	27	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F05	33.4	32.1	1.3	3.9%	99.5	99.5	0.0	0.0%	66	21	65	20	1.5%	4.8%
	R3	RESIDENTIAL	LKD		W3/F05	27.3	26.2	1.1	4.0%	89.4	89.2	0.1	0.3%	65	21	64	20	1.5%	4.8%
			LKD		W10/F05	26.8	26.8	0	0.0%					31	7	31	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F05	31.3	30.3	1	3.2%	98.4	98.4	0.0	0.0%	50	14	49	13	2.0%	7.1%

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES	%	%		%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
KILMUIR HOUSE (CONTINUED)																			
	R5	RESIDENTIAL	BEDROOM		W5/F05	31.6	30.7	0.9	2.8%	99.2	99.2	0.0	0.0%	59	18	58	17	1.7%	5.6%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F05	22.3	21.5	0.8	3.6%	89.9	84	1.0	6.6%	46	19	45	18	2.2%	5.3%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F05	26.3	25.6	0.7	2.7%	89.3	89.3	0.0	0.0%	42	16	41	15	2.4%	6.3%
	R8	RESIDENTIAL	BEDROOM		W8/F05	33	32.3	0.7	2.1%	99.3	99.3	0.0	0.0%	55	16	55	16	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F05	33.6	32.9	0.7	2.1%	98.5	98.5	0.0	0.0%	61	19	61	19	0.0%	0.0%
F06	R1	RESIDENTIAL	BEDROOM		W1/F06	38.6	37.5	1.1	2.8%	92.2	91.5	0.1	0.7%	79	27	79	27	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F06	34.9	33.3	1.6	4.6%	99.5	99.5	0.0	0.0%	66	21	66	21	0.0%	0.0%
	R3	RESIDENTIAL	LKD		W3/F06	28.8	27.4	1.4	4.9%	92.3	92	0.1	0.4%	66	21	66	21	0.0%	0.0%
			LKD		W10/F06	27.4	27.4	0	0.0%					30	7	30	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F06	32.9	31.6	1.3	4.0%	98.6	98.6	0.0	0.0%	50	14	50	14	0.0%	0.0%
	R5	RESIDENTIAL	BEDROOM		W5/F06	34	32.8	1.2	3.5%	99.3	99.3	0.0	0.0%	61	18	61	18	0.0%	0.0%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F06	27.9	26.8	1.1	3.9%	99.3	98.8	0.1	0.5%	64	19	64	19	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F06	23.7	22.8	0.9	3.8%	99.5	99.5	0.0	0.0%	43	16	43	16	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F06	33.4	32.5	0.9	2.7%	99.3	99.3	0.0	0.0%	52	14	52	14	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F06	34.9	34	0.9	2.6%	98.5	98.5	0.0	0.0%	62	18	62	18	0.0%	0.0%
F07	R1	RESIDENTIAL	BEDROOM		W1/F07	39	37.8	1.2	3.1%	92.3	92.1	0.0	0.2%	79	27	79	27	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F07	36.2	34.6	1.6	4.4%	99.5	99.5	0.0	0.0%	66	21	66	21	0.0%	0.0%
	R3	RESIDENTIAL	LKD		W3/F07	29.9	28.3	1.6	5.4%	97.4	97.4	0.0	0.0%	66	21	66	21	0.0%	0.0%
			LKD		W10/F07	26.9	26.9	0	0.0%					27	7	27	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F07	34.4	33	1.4	4.1%	98.6	98.6	0.0	0.0%	52	14	52	14	0.0%	0.0%
	R5	RESIDENTIAL	BEDROOM		W5/F07	34.5	33.2	1.3	3.8%	99.2	99.2	0.0	0.0%	65	20	65	20	0.0%	0.0%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F07	24.9	23.7	1.2	4.8%	99.3	99.2	0.0	0.1%	50	21	50	21	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F07	29	27.9	1.1	3.8%	99.6	99.6	0.0	0.0%	42	16	42	16	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F07	35.9	34.9	1	2.8%	99.3	99.3	0.0	0.0%	62	17	62	17	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F07	36.3	35.3	1	2.8%	98.6	98.6	0.0	0.0%	67	22	67	22	0.0%	0.0%
F08	R1	RESIDENTIAL	BEDROOM		W1/F08	38.8	37.7	1.1	2.8%	92.3	92.2	0.0	0.1%	76	27	76	27	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F08	37.6	35.9	1.7	4.5%	99.5	99.5	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R3	RESIDENTIAL	LKD		W3/F08	37.5	36	1.5	4.0%	100	100	0.0	0.0%	67	22	67	22	0.0%	0.0%
			LKD		W10/F08	20.9	20.9	0	0.0%					16	3	16	3	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F08	37.6	36.2	1.4	3.7%	98.7	98.7	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R5	RESIDENTIAL	BEDROOM		W5/F08	37.5	36.3	1.2	3.2%	99.3	99.3	0.0	0.0%	67	22	67	22	0.0%	0.0%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

KILMUJR HOUSE (CONTINUED)

	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F08	37.4	36.1	1.3	3.5%	99.3	99.2	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F08	37.3	36.2	1.1	2.9%	99.6	99.6	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F08	37.4	36.4	1	2.7%	99.4	99.4	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F08	37.4	36.5	0.9	2.4%	98.5	98.5	0.0	0.0%	67	22	67	22	0.0%	0.0%

SEMLEY HOUSE

F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	20.8	20.8	0	0.0%	92.9	92.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F02	34	34	0	0.0%					3	0	31	0	0.0%	0.0%
			UNKNOWN		W3/F02	15.4	15.4	0	0.0%					30	1	30	1	0.0%	0.0%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	21.9	21.9	0	0.0%	93.9	93.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F03	35.1	35.1	0	0.0%					24	1	24	1	0.0%	0.0%
			UNKNOWN		W3/F03	17.7	17.7	0	0.0%					33	2	33	2	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W4/F03	33.5	30.7	2.8	8.4%	99.6	99.6	0.0	0.0%	73	25	70	22	4.1%	12.0%
	R3	RESIDENTIAL	UNKNOWN		W5/F03	33.3	30.5	2.8	8.4%	100	100	0.0	0.0%	73	25	70	22	4.1%	12.0%
F04	R1	RESIDENTIAL	UNKNOWN		W1/F04	22.9	22.9	0	0.0%	95.8	95.8	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F04	36.2	36.2	0	0.0%					59		59		0.0%	0.0%
			UNKNOWN		W3/F04	20.7	20.5	0.2	1.0%					38	4	38	4	0.0%	0.0%
	R2	RESIDENTIAL	LKD		W4/F04	27.4	26.8	0.6	2.2%	94.9	85.5	2.8	9.9%	62	15	62	15	0.0%	0.0%
			LKD		W5/F04	27.2	26.5	0.7	2.6%					61	15	61	15	0.0%	0.0%
			LKD		W6/F04	28.2	27	1.2	4.3%					64	18	63	17	1.6%	5.6%
	R3	RESIDENTIAL	LKD		W7/F04	10.9	9.3	1.6	14.7%	99.9	99.7	0.1	0.2%	23	15	22	14	4.3%	6.7%
			LKD		W8/F04	29.3	27.5	1.8	6.1%					66	20	65	19	1.5%	5.0%
			LKD		W9/F04	30.5	28.7	1.8	5.9%					64	20	63	19	1.6%	5.0%
	R4	RESIDENTIAL	LKD		W10/F04	31.1	29.3	1.8	5.8%	100	100	0.0	0.0%	67	21	65	19	3.0%	9.5%
			LKD		W11/F04	31.2	29.3	1.9	6.1%					68	21	66	19	2.9%	9.5%
			LKD		W12/F04	31.7	29.8	1.9	6.0%					68	23	66	21	2.9%	8.7%
	R5	RESIDENTIAL	LKD		W13/F04	13.6	11.4	2.2	16.2%	99.9	99.9	0.0	0.1%	27	19	26	18	3.7%	5.3%
			LKD		W14/F04	31.6	29.3	2.3	7.3%					69	24	68	23	1.4%	4.2%
			LKD		W15/F04	32.6	30.3	2.3	7.1%					68	24	66	22	2.9%	8.3%
	R6	RESIDENTIAL	LKD		W16/F04	33.1	30.8	2.3	6.9%	99.9	99.5	0.1	0.4%	68	23	66	21	2.9%	8.7%
			LKD		W17/F04	33	30.7	2.3	7.0%					68	23	66	21	2.9%	8.7%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
			LKD		W18/F04	33.3	30.9	2.4	7.2%					67	23	65	21	3.0%	8.7%
	R7	RESIDENTIAL	LKD		W19/F04	14.2	11.7	2.5	17.6%	100	96	11	4.0%	25	16	24	15	4.0%	6.3%
			LKD		W20/F04	25.2	22.7	2.5	9.9%					45	12	44	11	2.2%	8.3%
			LKD		W21/F04	20.5	18.2	2.3	11.2%					33	7	32	6	3.0%	14.3%
	R10	RESIDENTIAL	LKD		W24/F04	22.3	20.1	2.2	9.9%	99.9	95.9	11	4.1%	46	20	44	18	4.3%	10.0%
			LKD		W25/F04	27.2	24.6	2.6	9.6%					50	22	47	19	6.0%	13.6%
			LKD		W26/F04	15.5	12.9	2.6	16.8%					25	20	22	17	12.0%	15.0%
	R11	RESIDENTIAL	LKD		W27/F04	35	32.4	2.6	7.4%	100	97.9	0.6	2.1%	72	25	70	23	2.8%	8.0%
			LKD		W28/F04	35.2	32.6	2.6	7.4%					72	25	69	22	4.2%	12.0%
			LKD		W29/F04	35.3	32.8	2.5	7.1%					72	25	69	22	4.2%	12.0%
	R12	RESIDENTIAL	LKD		W30/F04	35.1	32.5	2.6	7.4%	100	98.6	0.4	1.4%	67	23	64	20	4.5%	13.0%
			LKD		W31/F04	34.2	31.7	2.5	7.3%					60	22	58	20	3.3%	9.1%
			LKD		W32/F04	16.6	14.1	2.5	15.1%					30	20	28	18	6.7%	10.0%
	R13	RESIDENTIAL	LKD		W33/F04	35.6	33.2	2.4	6.7%	100	99.7	0.1	0.3%	74	26	71	23	4.1%	11.5%
			LKD		W34/F04	35.7	33.3	2.4	6.7%					74	26	71	23	4.1%	11.5%
			LKD		W35/F04	35.8	33.5	2.3	6.4%					75	27	71	23	5.3%	14.8%
	R14	RESIDENTIAL	LKD		W36/F04	35.4	33.1	2.3	6.5%	100	100	0.0	0.0%	70	25	66	21	5.7%	16.0%
			LKD		W37/F04	34.6	32.3	2.3	6.6%					65	25	61	21	6.2%	16.0%
			LKD		W38/F04	16.9	14.6	2.3	13.6%					34	23	30	19	11.8%	17.4%
	R15	RESIDENTIAL	LKD		W39/F04	35.9	33.7	2.2	6.1%	100	100	0.0	0.0%	77	27	73	23	5.2%	14.8%
			LKD		W40/F04	36	33.9	2.1	5.8%					77	27	74	24	3.9%	11.1%
			LKD		W41/F04	36.2	34.1	2.1	5.8%					77	27	74	24	3.9%	11.1%
	R16	RESIDENTIAL	LKD		W42/F04	36.2	34.2	2	5.5%	100	100	0.0	0.0%	78	27	75	24	3.8%	11.1%
			LKD		W43/F04	36.1	34	2.1	5.8%					78	27	75	24	3.8%	11.1%
			LKD		W44/F04	36.3	34.3	2	5.5%					78	27	76	25	2.6%	7.4%
F05	R1	RESIDENTIAL	UNKNOWN		W1/F05	23.6	23.6	0	0.0%	96.3	96.3	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F05	37.3	37.3	0	0.0%					0	0	0	0	0.0%	0.0%
			UNKNOWN		W3/F05	23.2	22.9	0.3	1.3%					41	5	41	5	0.0%	0.0%
	R2	RESIDENTIAL	KITCHEN		W4/F05	29.9	29.2	0.7	2.3%	87.2	81.8	0.8	6.2%	65	18	65	18	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W5/F05	30.2	29.1	1.1	3.6%	84.9	68.9	3.6	18.9%	69	19	68	18	1.4%	5.3%
	R4	RESIDENTIAL	LKD		W6/F05	31.5	29.9	1.6	5.1%	99	99	0.0	0.0%	70	20	69	19	1.4%	5.0%

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
			LKD		W7/F05	31.3	29.8	1.5	4.8%					67	20	66	19	15%	5.0%
			LKD		W8/F05	32.5	30.9	1.6	4.9%					67	20	66	19	15%	5.0%
	R5	RESIDENTIAL	KITCHEN		W9/F05	33	31.1	1.9	5.8%	98.2	98.2	0.0	0.0%	71	24	69	22	2.8%	8.3%
	R6	RESIDENTIAL	LIVING ROOM		W10/F05	33	31	2	6.1%	93.8	91	0.6	3.0%	72	24	70	22	2.8%	8.3%
	R7	RESIDENTIAL	LKD		W11/F05	33.8	31.8	2	5.9%	99	99	0.0	0.0%	72	24	71	23	1.4%	4.2%
			LKD		W12/F05	33.6	31.6	2	6.0%					71	24	70	23	1.4%	4.2%
			LKD		W13/F05	34.4	32.2	2.2	6.4%					71	24	70	23	1.4%	4.2%
	R8	RESIDENTIAL	KITCHEN		W14/F05	34.4	32.1	2.3	6.7%	98.3	96.4	0.2	1.9%	67	23	65	21	3.0%	8.7%
	R9	RESIDENTIAL	LIVING ROOM		W15/F05	34	31.6	2.4	7.1%	93.9	90.3	0.8	3.9%	68	23	66	21	2.9%	8.7%
	R10	RESIDENTIAL	LKD		W16/F05	34	31.6	2.4	7.1%	99	98.8	0.0	0.1%	65	22	63	20	3.1%	9.1%
			LKD		W17/F05	33	30.6	2.4	7.3%					62	22	60	20	3.2%	9.1%
			LKD		W18/F05	29.6	27.1	2.5	8.4%					50	16	48	14	4.0%	12.5%
	R13	RESIDENTIAL	LKD		W21/F05	30.9	28.4	2.5	8.1%	98.9	98.8	0.0	0.1%	67	27	65	25	3.0%	7.4%
			LKD		W22/F05	34	31.6	2.4	7.1%					68	27	65	24	4.4%	11.1%
			LKD		W23/F05	34.9	32.4	2.5	7.2%					70	27	68	25	2.9%	7.4%
	R14	RESIDENTIAL	LIVING ROOM		W24/F05	35.3	32.9	2.4	6.8%	94.2	87.5	1.5	7.2%	74	27	71	24	4.1%	11.1%
	R15	RESIDENTIAL	KITCHEN (1)		W25/F05	36.1	33.6	2.5	6.9%	98.2	94.8	0.4	3.5%	76	27	74	25	2.6%	7.4%
	R16	RESIDENTIAL	LKD		W26/F05	36.6	34.1	2.5	6.8%	99	98.9	0.0	0.1%	75	27	73	25	2.7%	7.4%
			LKD		W27/F05	36.2	33.8	2.4	6.6%					73	27	70	24	4.1%	11.1%
			LKD		W28/F05	36.5	34.1	2.4	6.6%					74	27	72	25	2.7%	7.4%
	R17	RESIDENTIAL	LIVING ROOM		W29/F05	36.1	33.8	2.3	6.4%	94.3	88.6	1.3	6.0%	78	28	75	25	3.8%	10.7%
	R18	RESIDENTIAL	KITCHEN (1)		W30/F05	36.6	34.3	2.3	6.3%	98.1	96.7	0.2	1.4%	77	27	75	25	2.6%	7.4%
	R19	RESIDENTIAL	LKD		W31/F05	36.9	34.7	2.2	6.0%	99	99	0.0	0.0%	77	28	74	25	3.9%	10.7%
			LKD		W32/F05	36.6	34.4	2.2	6.0%					75	28	71	24	5.3%	14.3%
			LKD		W33/F05	36.7	34.6	2.1	5.7%					75	28	72	25	4.0%	10.7%
	R20	RESIDENTIAL	LIVING ROOM		W34/F05	36.4	34.3	2.1	5.8%	94.3	90.2	0.9	4.3%	78	27	75	24	3.8%	11.1%
	R21	RESIDENTIAL	KITCHEN (1)		W35/F05	36.8	34.7	2.1	5.7%	98.1	98.1	0.0	0.0%	79	27	77	25	2.5%	7.4%
	R22	RESIDENTIAL	KITCHEN		W36/F05	37.1	35.1	2	5.4%	98.3	98.3	0.0	0.0%	79	27	77	25	2.5%	7.4%
	R23	RESIDENTIAL	LIVING ROOM		W37/F05	37.1	35.2	1.9	5.1%	94.1	93.9	0.0	0.1%	79	27	77	25	2.5%	7.4%
F06	R1	RESIDENTIAL	UNKNOWN		W1/F06	23.9	23.9	0	0.0%	97.1	97.1	0.0	0.0%		0	0	0	0.0%	0.0%
			UNKNOWN		W2/F06	38.1	38.1	0	0.0%					28	3	28	3	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 18

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
			UNKNOWN		W3/F06	25.4	25	0.4	1.6%					48	12	48	12	0.0%	0.0%
	R2	RESIDENTIAL	LIVING ROOM		W4/F06	30.3	29.4	0.9	3.0%	80.6	80.3	0.1	0.4%	55	17	55	17	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN (1)		W5/F06	17	15.8	1.2	7.1%	95.9	95.6	0.0	0.4%	39	20	39	20	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W6/F06	33.2	31.8	1.4	4.2%	98.2	98.2	0.0	0.0%	69	21	69	21	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/F06	34.1	32.5	1.6	4.7%	94.1	91.8	0.5	2.4%	70	21	69	20	1.4%	4.8%
	R6	RESIDENTIAL	LIVING ROOM		W8/F06	32.3	30.6	1.7	5.3%	90.2	89.6	0.1	0.6%	57	19	56	18	1.8%	5.3%
	R7	RESIDENTIAL	KITCHEN (1)		W9/F06	18.7	16.8	1.9	10.2%	98.2	98.2	0.0	0.0%	41	23	41	23	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN (1)		W10/F06	34.8	32.8	2	5.7%	98.2	98.2	0.0	0.0%	70	24	70	24	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W11/F06	35.5	33.4	2.1	5.9%	94.3	93	0.3	1.4%	70	23	70	23	0.0%	0.0%
	R10	RESIDENTIAL	LIVING ROOM		W12/F06	33.5	31.4	2.1	6.3%	93.8	93	0.2	0.9%	57	19	56	18	1.8%	5.3%
	R11	RESIDENTIAL	KITCHEN (1)		W13/F06	19.3	17.1	2.2	11.4%	98	97.3	0.1	0.7%	40	23	38	21	5.0%	8.7%
	R12	RESIDENTIAL	KITCHEN (1)		W14/F06	34.4	32.1	2.3	6.7%	98.2	97.3	0.1	0.9%	62	22	60	20	3.2%	9.1%
	R13	RESIDENTIAL	LIVING ROOM		W15/F06	30	27.7	2.3	7.7%	93	86.7	1.3	6.8%	50	16	48	14	4.0%	12.5%
	R16	RESIDENTIAL	LIVING ROOM		W18/F06	31.2	28.8	2.4	7.7%	93.5	90.6	0.6	3.1%	68	27	66	25	2.9%	7.4%
	R17	RESIDENTIAL	KITCHEN (1)		W19/F06	35.2	32.8	2.4	6.8%	98.1	96.9	0.2	1.3%	67	23	65	21	3.0%	8.7%
	R18	RESIDENTIAL	KITCHEN (1)		W20/F06	20.4	18.1	2.3	11.3%	98.2	96.8	0.2	1.4%	33	19	31	17	6.1%	10.5%
	R19	RESIDENTIAL	LIVING ROOM		W21/F06	34.8	32.5	2.3	6.6%	94.3	92.7	0.3	1.7%	69	26	67	24	2.9%	7.7%
	R20	RESIDENTIAL	LIVING ROOM		W22/F06	37.2	34.9	2.3	6.2%	94.3	89.9	1.0	4.6%	76	27	74	25	2.6%	7.4%
	R21	RESIDENTIAL	KITCHEN (1)		W23/F06	36.8	34.6	2.2	6.0%	98.3	97	0.2	1.3%	69	23	67	21	2.9%	8.7%
	R22	RESIDENTIAL	KITCHEN (1)		W24/F06	21	18.9	2.1	10.0%	98.2	97.7	0.1	0.5%	34	19	32	17	5.9%	10.5%
	R23	RESIDENTIAL	LIVING ROOM		W25/F06	35.2	33	2.2	6.3%	94.2	93.5	0.2	0.7%	72	26	70	24	2.8%	7.7%
	R24	RESIDENTIAL	LIVING ROOM		W26/F06	37.5	35.4	2.1	5.6%	94.3	90.9	0.8	3.6%	79	28	76	25	3.8%	10.7%
	R25	RESIDENTIAL	KITCHEN (1)		W27/F06	37	35.1	1.9	5.1%	98.1	98.1	0.0	0.0%	73	25	70	22	4.1%	12.0%
	R26	RESIDENTIAL	KITCHEN (1)		W28/F06	21.4	19.5	1.9	8.9%	98.2	98.2	0.0	0.0%	37	21	34	18	8.1%	14.3%
	R27	RESIDENTIAL	LIVING ROOM		W29/F06	35.2	33.3	1.9	5.4%	94.1	93.9	0.0	0.2%	76	28	74	26	2.6%	7.1%
	R28	RESIDENTIAL	LIVING ROOM		W30/F06	37.7	35.9	1.8	4.8%	94.2	92.1	0.5	2.2%	78	27	76	25	2.6%	7.4%
	R29	RESIDENTIAL	KITCHEN		W31/F06	37.8	36	1.8	4.8%	98.1	98.1	0.0	0.0%	79	27	77	25	2.5%	7.4%
F07	R1	RESIDENTIAL	UNKNOWN		W1/F07	24	24	0	0.0%	97.4	97.3	0.0	0.1%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F07	38.7	38.7	0	0.0%									0.0%	0.0%
			UNKNOWN		W3/F07	27.6	27	0.6	2.2%					49	13	49	13	0.0%	0.0%
	R2	RESIDENTIAL	LKD		W4/F07	35.2	34	1.2	3.4%	98.9	98.9	0.0	0.0%	72	22	72	22	0.0%	0.0%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
			LKD		W5/F07	34.8	33.6	1.2	3.4%					69	22	69	22	0.0%	0.0%
			LKD		W6/F07	35.4	34.1	1.3	3.7%					69	22	69	22	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W7/F07	35.1	33.7	1.4	4.0%	89.6	89.5	0.0	0.2%	73	23	72	22	1.4%	4.3%
	R4	RESIDENTIAL	KITCHEN (1)		W8/F07	35.8	34.2	1.6	4.5%	98.1	98.1	0.0	0.0%	75	24	74	23	1.3%	4.2%
	R5	RESIDENTIAL	LKD		W9/F07	36.3	34.6	1.7	4.7%	99.1	99.1	0.0	0.0%	74	24	74	24	0.0%	0.0%
			LKD		W10/F07	36	34.3	1.7	4.7%					71	24	71	24	0.0%	0.0%
			LKD		W11/F07	36.3	34.6	1.7	4.7%					70	24	70	24	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W12/F07	36	34.2	1.8	5.0%	94.1	93.7	0.1	0.4%	73	24	73	24	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (1)		W13/F07	36.6	34.6	2	5.5%	98.2	98.2	0.0	0.0%	73	24	73	24	0.0%	0.0%
	R8	RESIDENTIAL	LKD		W14/F07	36.9	34.9	2	5.4%	99	99	0.0	0.0%	71	24	70	23	1.4%	4.2%
			LKD		W15/F07	36.5	34.5	2	5.5%					70	24	69	23	1.4%	4.2%
			LKD		W16/F07	36.7	34.6	2.1	5.7%					69	24	67	22	2.9%	8.3%
	R9	RESIDENTIAL	LIVING ROOM		W17/F07	35.2	33.1	2.1	6.0%	94.2	93.3	0.2	1.0%	66	23	64	21	3.0%	8.7%
	R10	RESIDENTIAL	KITCHEN (1)		W18/F07	29.1	27	2.1	7.2%	98.2	98.2	0.0	0.0%	49	14	47	12	4.1%	14.3%
	R13	RESIDENTIAL	KITCHEN (1)		W21/F07	29.9	27.8	2.1	7.0%	98.2	98.2	0.0	0.0%	61	26	59	24	3.3%	7.7%
	R14	RESIDENTIAL	LIVING ROOM		W22/F07	35.7	33.6	2.1	5.9%	94.3	93.1	0.3	1.2%	76	27	74	25	2.6%	7.4%
	R15	RESIDENTIAL	LKD		W23/F07	37.3	35.1	2.2	5.9%	99	99	0.0	0.0%	76	27	74	25	2.6%	7.4%
			LKD		W24/F07	37.3	35.2	2.1	5.6%					75	27	73	25	2.7%	7.4%
			LKD		W25/F07	37.7	35.6	2.1	5.6%					75	28	73	26	2.7%	7.1%
	R16	RESIDENTIAL	KITCHEN (1)		W26/F07	37.7	35.6	2.1	5.6%	98.2	98.2	0.0	0.0%	75	28	73	26	2.7%	7.1%
	R17	RESIDENTIAL	LIVING ROOM		W27/F07	37.4	35.4	2	5.3%	94.3	93.5	0.2	0.8%	79	28	77	26	2.5%	7.1%
	R18	RESIDENTIAL	LKD		W28/F07	37.9	35.9	2	5.3%	99.1	99.1	0.0	0.0%	79	28	77	26	2.5%	7.1%
			LKD		W29/F07	37.8	35.8	2	5.3%					77	28	75	26	2.6%	7.1%
			LKD		W30/F07	38.2	36.2	2	5.2%					76	28	74	26	2.6%	7.1%
	R19	RESIDENTIAL	KITCHEN (1)		W31/F07	38	36.1	1.9	5.0%	98.3	98.3	0.0	0.0%	77	28	74	25	3.9%	10.7%
	R20	RESIDENTIAL	LIVING ROOM		W32/F07	37.6	35.8	1.8	4.8%	94.3	94	0.1	0.3%	80	28	77	25	3.8%	10.7%
	R21	RESIDENTIAL	LKD		W33/F07	38.1	36.3	1.8	4.7%	99	99	0.0	0.0%	80	28	78	26	2.5%	7.1%
			LKD		W34/F07	38	36.2	1.8	4.7%					80	28	78	26	2.5%	7.1%
			LKD		W35/F07	38.3	36.6	1.7	4.4%					80	28	78	26	2.5%	7.1%
	R22	RESIDENTIAL	KITCHEN (1)		W36/F07	38.4	36.7	1.7	4.4%	98.3	98.3	0.0	0.0%	80	28	78	26	2.5%	7.1%
	R23	RESIDENTIAL	LIVING ROOM		W37/F07	38.4	36.7	1.7	4.4%	94.3	94.3	0.0	0.0%	80	28	78	26	2.5%	7.1%

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
F08	R1	RESIDENTIAL	UNKNOWN		W1/F08	24.1	24.1	0	0.0%	99.4	99.4	0.0	0.0%					0.0%	0.0%
			UNKNOWN		W2/F08	39.1	39.1	0	0.0%					31	6	31	6	0.0%	0.0%
			UNKNOWN		W3/F08	29.7	28.9	0.8	2.7%					51	15	51	15	0.0%	0.0%
	R2	RESIDENTIAL	LIVING ROOM		W4/F08	36.9	35.8	1.1	3.0%	94.5	94.5	0.0	0.0%	75	24	75	24	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN (1)		W5/F08	36.6	35.4	1.2	3.3%	98.2	98.2	0.0	0.0%	69	21	69	21	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W6/F08	21.7	20.4	1.3	6.0%	98.2	98.2	0.0	0.0%	37	20	37	20	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/F08	35.1	33.7	1.4	4.0%	94.2	94.2	0.0	0.0%	70	25	70	25	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W8/F08	37.4	35.9	1.5	4.0%	94.3	94.2	0.0	0.1%	75	25	75	25	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (1)		W9/F08	37.2	35.6	1.6	4.3%	98.2	98.2	0.0	0.0%	70	22	70	22	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN (1)		W10/F08	22.3	20.6	1.7	7.6%	98.2	98.2	0.0	0.0%	37	20	37	20	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W11/F08	35.5	33.8	1.7	4.8%	94.3	94.2	0.0	0.0%	70	26	69	25	1.4%	3.8%
	R10	RESIDENTIAL	LIVING ROOM		W12/F08	37.7	35.9	1.8	4.8%	94.3	94.1	0.0	0.2%	71	25	70	24	1.4%	4.0%
	R11	RESIDENTIAL	KITCHEN (1)		W13/F08	37.4	35.5	1.9	5.1%	98.1	98.1	0.0	0.0%	68	23	66	21	2.9%	8.7%
	R12	RESIDENTIAL	KITCHEN (1)		W14/F08	22.2	20.3	1.9	8.6%	98.2	98.2	0.0	0.0%	37	20	35	18	5.4%	10.0%
	R13	RESIDENTIAL	LIVING ROOM		W15/F08	29.1	27.2	1.9	6.5%	93.2	93.1	0.0	0.1%	49	17	47	15	4.1%	11.8%
	R16	RESIDENTIAL	LIVING ROOM		W18/F08	29.7	27.8	1.9	6.4%	93.3	93	0.1	0.3%	52	23	50	21	3.8%	8.7%
	R17	RESIDENTIAL	KITCHEN (1)		W19/F08	22.4	20.5	1.9	8.5%	98.1	98.1	0.0	0.0%	48	27	46	25	4.2%	7.4%
	R18	RESIDENTIAL	KITCHEN (1)		W20/F08	37.7	35.9	1.8	4.8%	98.2	98.2	0.0	0.0%	76	27	74	25	2.6%	7.4%
	R19	RESIDENTIAL	LIVING ROOM		W21/F08	38.2	36.4	1.8	4.7%	94.3	94.1	0.0	0.2%	77	26	75	24	2.6%	7.7%
	R20	RESIDENTIAL	LIVING ROOM		W22/F08	36.3	34.4	1.9	5.2%	94.3	94.3	0.0	0.0%	61	23	59	21	3.3%	8.7%
	R21	RESIDENTIAL	KITCHEN (1)		W23/F08	22.9	21.2	1.7	7.4%	98.2	98.2	0.0	0.0%	49	27	47	25	4.1%	7.4%
	R22	RESIDENTIAL	KITCHEN (1)		W24/F08	38.1	36.4	1.7	4.5%	98.2	98.2	0.0	0.0%	76	27	74	25	2.6%	7.4%
	R23	RESIDENTIAL	LIVING ROOM		W25/F08	38.6	36.9	1.7	4.4%	94.3	94.1	0.0	0.2%	78	27	76	25	2.6%	7.4%
	R24	RESIDENTIAL	LIVING ROOM		W26/F08	36.4	34.7	1.7	4.7%	94.3	94.3	0.0	0.0%	62	23	59	20	4.8%	13.0%
	R25	RESIDENTIAL	KITCHEN (1)		W27/F08	22.8	21.1	1.7	7.5%	98.1	98.1	0.0	0.0%	51	28	48	25	5.9%	10.7%
	R26	RESIDENTIAL	KITCHEN (1)		W28/F08	38.2	36.6	1.6	4.2%	98.2	98.2	0.0	0.0%	78	28	76	26	2.6%	7.1%
	R27	RESIDENTIAL	LIVING ROOM		W29/F08	38.8	37.2	1.6	4.1%	94.3	94.2	0.0	0.1%	79	28	77	26	2.5%	7.1%
	R28	RESIDENTIAL	LIVING ROOM		W30/F08	38.9	37.4	1.5	3.9%	94.3	94.3	0.0	0.0%	80	28	78	26	2.5%	7.1%
	R29	RESIDENTIAL	KITCHEN (1)		W31/F08	38.9	37.5	1.4	3.6%	98.1	98.1	0.0	0.0%	80	28	78	26	2.5%	7.1%
F09	R1	RESIDENTIAL	UNKNOWN		W1/F09	24.2	24.2	0	0.0%	99.9	99.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F09	39.4	39.4	0	0.0%							0	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 21

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
			UNKNOWN		W3/F09	31.2	30.4	0.8	2.6%					52	16	52	16	0.0%	0.0%
	R2	RESIDENTIAL	KITCHEN		W4/F09	38.2	37.2	1	2.6%	98.3	98.3	0.0	0.0%	76	27	76	27	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W5/F09	37.9	36.8	1.1	2.9%	93.9	93.9	0.0	0.0%	79	27	79	27	0.0%	0.0%
	R4	RESIDENTIAL	LKD		W6/F09	38.4	37.2	1.2	3.1%	99	99	0.0	0.0%	78	27	78	27	0.0%	0.0%
			LKD		W7/F09	37.8	36.8	1	2.6%					76	26	76	26	0.0%	0.0%
			LKD		W8/F09	38.6	37.4	1.2	3.1%					75	27	75	27	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN		W9/F09	38.5	37.1	1.4	3.6%	98.3	98.3	0.0	0.0%	75	27	75	27	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W10/F09	38.1	36.8	1.3	3.4%	93.9	93.8	0.0	0.0%	78	27	78	27	0.0%	0.0%
	R7	RESIDENTIAL	LKD		W11/F09	38.6	37.2	1.4	3.6%	99	99	0.0	0.0%	77	27	77	27	0.0%	0.0%
			LKD		W12/F09	38.1	36.9	1.2	3.1%					77	27	77	27	0.0%	0.0%
			LKD		W13/F09	38.8	37.3	1.5	3.9%					75	27	75	27	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN		W14/F09	38.4	36.9	1.5	3.9%	98.2	98.2	0.0	0.0%	72	26	71	25	14%	3.8%
	R9	RESIDENTIAL	LIVING ROOM		W15/F09	37.8	36.3	1.5	4.0%	93.9	93.9	0.0	0.0%	73	26	72	25	14%	3.8%
	R10	RESIDENTIAL	LKD		W16/F09	37.6	36	1.6	4.3%	99	99	0.0	0.0%	68	24	67	23	15%	4.2%
			LKD		W17/F09	36.2	34.9	1.3	3.6%					66	24	64	22	3.0%	8.3%
			LKD		W18/F09	32.6	31	1.6	4.9%					54	18	53	17	19%	5.6%
	R13	RESIDENTIAL	LKD		W21/F09	32.7	31.2	1.5	4.6%	98.9	98.9	0.0	0.0%	68	28	67	27	15%	3.6%
			LKD		W22/F09	36.3	35	1.3	3.6%					72	28	70	26	2.8%	7.1%
			LKD		W23/F09	37.6	36	1.6	4.3%					74	28	74	28	0.0%	0.0%
	R14	RESIDENTIAL	LIVING ROOM		W24/F09	37.9	36.4	1.5	4.0%	94.3	94.2	0.0	0.1%	79	28	78	27	1.3%	3.6%
	R15	RESIDENTIAL	KITCHEN (1)		W25/F09	38.6	37	1.6	4.1%	98.1	98.1	0.0	0.0%	78	28	77	27	1.3%	3.6%
	R16	RESIDENTIAL	LKD		W26/F09	39	37.5	1.5	3.8%	99	99	0.0	0.0%	77	28	76	27	1.3%	3.6%
			LKD		W27/F09	38.3	37.1	1.2	3.1%					75	28	73	26	2.7%	7.1%
			LKD		W28/F09	38.9	37.4	1.5	3.9%					76	28	75	27	1.3%	3.6%
	R17	RESIDENTIAL	LIVING ROOM		W29/F09	38.5	37.1	1.4	3.6%	94.3	94.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R18	RESIDENTIAL	KITCHEN (1)		W30/F09	38.9	37.5	1.4	3.6%	98.1	98.1	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R19	RESIDENTIAL	LKD		W31/F09	39.1	37.8	1.3	3.3%	99	99	0.0	0.0%	78	28	77	27	1.3%	3.6%
			LKD		W32/F09	38.8	37.6	1.2	3.1%					76	28	75	27	1.3%	3.6%
			LKD		W33/F09	39	37.7	1.3	3.3%					76	28	75	27	1.3%	3.6%
	R20	RESIDENTIAL	LIVING ROOM		W34/F09	38.6	37.3	1.3	3.4%	94.3	94.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R21	RESIDENTIAL	KITCHEN (1)		W35/F09	38.9	37.7	1.2	3.1%	98.2	98.2	0.0	0.0%	80	28	79	27	1.3%	3.6%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
	R22	RESIDENTIAL	KITCHEN (1)		W36/F09	39.2	38	1.2	3.1%	98.3	98.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R23	RESIDENTIAL	LIVING ROOM		W37/F09	39.3	38.1	1.2	3.1%	94.3	94.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
F10	R1	RESIDENTIAL	UNKNOWN		W1/F10	24.6	24.6	0	0.0%	99.9	99.9	0.0	0.0%					0.0%	0.0%
			UNKNOWN		W2/F10	39.6	39.6	0	0.0%					32	7	32	7	0.0%	0.0%
			UNKNOWN		W3/F10	32.6	31.7	0.9	2.8%					53	17	53	17	0.0%	0.0%
	R2	RESIDENTIAL	LIVING ROOM		W4/F10	37.1	36.1	1	2.7%	94.5	94.5	0.0	0.0%	62	22	62	22	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN (1)		W5/F10	22.7	21.7	1	4.4%	98.2	98.2	0.0	0.0%	47	26	47	26	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W6/F10	38.9	37.9	1	2.6%	98.2	98.2	0.0	0.0%	77	27	77	27	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/F10	39.3	38.2	1.1	2.8%	94.3	94.3	0.0	0.0%	77	26	77	26	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W8/F10	37.1	35.9	1.2	3.2%	94.3	94.3	0.0	0.0%	61	22	61	22	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (1)		W9/F10	22.6	21.5	1.1	4.9%	98.2	98.2	0.0	0.0%	46	26	46	26	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN (1)		W10/F10	38.9	37.7	1.2	3.1%	98.2	98.2	0.0	0.0%	76	27	76	27	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W11/F10	39.3	38.1	1.2	3.1%	94.3	94.3	0.0	0.0%	75	26	75	26	0.0%	0.0%
	R10	RESIDENTIAL	LIVING ROOM		W12/F10	37	35.8	1.2	3.2%	94.3	94.3	0.0	0.0%	61	22	61	22	0.0%	0.0%
	R11	RESIDENTIAL	KITCHEN (1)		W13/F10	22.1	20.9	1.2	5.4%	98.1	98.1	0.0	0.0%	41	25	41	25	0.0%	0.0%
	R12	RESIDENTIAL	KITCHEN (1)		W14/F10	37.5	36.2	1.3	3.5%	98.2	98.2	0.0	0.0%	65	24	65	24	0.0%	0.0%
	R13	RESIDENTIAL	LIVING ROOM		W15/F10	32.6	31.3	1.3	4.0%	93.2	93.2	0.0	0.0%	52	17	52	17	0.0%	0.0%
	R16	RESIDENTIAL	LIVING ROOM		W18/F10	32.6	31.3	1.3	4.0%	93.3	93.3	0.0	0.0%	70	28	70	28	0.0%	0.0%
	R17	RESIDENTIAL	KITCHEN (1)		W19/F10	37.4	36.2	1.2	3.2%	98.1	98.1	0.0	0.0%	69	24	69	24	0.0%	0.0%
	R18	RESIDENTIAL	KITCHEN (1)		W20/F10	22.1	20.9	1.2	5.4%	98.2	98.2	0.0	0.0%	34	20	34	20	0.0%	0.0%
	R19	RESIDENTIAL	LIVING ROOM		W21/F10	37	35.7	1.3	3.5%	94.3	94.2	0.0	0.1%	74	27	74	27	0.0%	0.0%
	R20	RESIDENTIAL	LIVING ROOM		W22/F10	39.3	38.1	1.2	3.1%	94.3	94.3	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R21	RESIDENTIAL	KITCHEN (1)		W23/F10	38.9	37.8	1.1	2.8%	98.2	98.2	0.0	0.0%	71	24	70	23	1.4%	4.2%
	R22	RESIDENTIAL	KITCHEN (1)		W24/F10	22.6	21.5	1.1	4.9%	98.2	98.2	0.0	0.0%	35	20	34	19	2.9%	5.0%
	R23	RESIDENTIAL	LIVING ROOM		W25/F10	37.1	36	1.1	3.0%	94.3	94.2	0.0	0.0%	75	27	74	26	1.3%	3.7%
	R24	RESIDENTIAL	LIVING ROOM		W26/F10	39.4	38.3	1.1	2.8%	94.3	94.3	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R25	RESIDENTIAL	KITCHEN (1)		W27/F10	39	38	1	2.6%	98.1	98.1	0.0	0.0%	73	25	72	24	1.4%	4.0%
	R26	RESIDENTIAL	KITCHEN (1)		W28/F10	22.9	21.8	1.1	4.8%	98.2	98.2	0.0	0.0%	37	21	36	20	2.7%	4.8%
	R27	RESIDENTIAL	LIVING ROOM		W29/F10	37.1	36	1.1	3.0%	94.3	94.3	0.0	0.0%	76	28	75	27	1.3%	3.6%
	R28	RESIDENTIAL	LIVING ROOM		W30/F10	39.5	38.5	1	2.5%	94.3	94.3	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R29	RESIDENTIAL	KITCHEN (1)		W31/F10	39.6	38.6	1	2.5%	98.1	98.1	0.0	0.0%	80	28	79	27	1.3%	3.6%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)																			
F11	R1	RESIDENTIAL	UNKNOWN		W1/F11	25.7	25.7	0	0.0%	99.9	99.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F11	39.6	39.6	0	0.0%					55		55		0.0%	0.0%
			UNKNOWN		W3/F11	34.2	33.3	0.9	2.6%					57	17	57	17	0.0%	0.0%
	R2	RESIDENTIAL	LKD		W4/F11	39.5	38.8	0.7	1.8%	99	99	0.0	0.0%	79	27	79	27	0.0%	0.0%
			LKD		W5/F11	39.4	38.6	0.8	2.0%					79	27	79	27	0.0%	0.0%
			LKD		W6/F11	39.5	38.7	0.8	2.0%					79	27	79	27	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W7/F11	39.5	38.7	0.8	2.0%	94.3	94.3	0.0	0.0%	79	27	79	27	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W8/F11	39.5	38.7	0.8	2.0%	98.1	98.1	0.0	0.0%	79	27	79	27	0.0%	0.0%
	R5	RESIDENTIAL	LKD		W9/F11	39.6	38.8	0.8	2.0%	99	99	0.0	0.0%	79	27	79	27	0.0%	0.0%
			LKD		W10/F11	39.4	38.6	0.8	2.0%					79	27	79	27	0.0%	0.0%
			LKD		W11/F11	39.6	38.7	0.9	2.3%					79	27	79	27	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W12/F11	39.5	38.7	0.8	2.0%	94.3	94.3	0.0	0.0%	79	27	79	27	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (1)		W13/F11	39.5	38.6	0.9	2.3%	98.2	98.2	0.0	0.0%	78	27	78	27	0.0%	0.0%
	R8	RESIDENTIAL	LKD		W14/F11	39.4	38.5	0.9	2.3%	99	99	0.0	0.0%	76	26	76	26	0.0%	0.0%
			LKD		W15/F11	39.1	38.1	1	2.6%					74	26	74	26	0.0%	0.0%
			LKD		W16/F11	39	38.1	0.9	2.3%					72	25	72	25	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W17/F11	37.9	37	0.9	2.4%	94.3	94.3	0.0	0.0%	67	24	67	24	0.0%	0.0%
	R10	RESIDENTIAL	KITCHEN (1)		W18/F11	31.2	30.3	0.9	2.9%	98.2	98.2	0.0	0.0%	50	15	50	15	0.0%	0.0%
	R13	RESIDENTIAL	KITCHEN (1)		W22/F11	31.1	30.2	0.9	2.9%	98.2	98.2	0.0	0.0%	65	26	65	26	0.0%	0.0%
	R14	RESIDENTIAL	LIVING ROOM		W23/F11	37.9	36.9	1	2.6%	94.3	94.3	0.0	0.0%	77	28	77	28	0.0%	0.0%
	R15	RESIDENTIAL	LKD		W24/F11	38.9	38	0.9	2.3%	99	99	0.0	0.0%	78	28	78	28	0.0%	0.0%
			LKD		W25/F11	39	38.1	0.9	2.3%					79	28	79	28	0.0%	0.0%
			LKD		W26/F11	39.3	38.4	0.9	2.3%					79	28	79	28	0.0%	0.0%
	R16	RESIDENTIAL	KITCHEN (1)		W27/F11	39.5	38.6	0.9	2.3%	98.2	98.2	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R17	RESIDENTIAL	LIVING ROOM		W28/F11	39.5	38.6	0.9	2.3%	94.3	94.3	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R18	RESIDENTIAL	LKD		W29/F11	39.6	38.7	0.9	2.3%	99.1	99.1	0.0	0.0%	80	28	79	27	1.3%	3.6%
			LKD		W30/F11	39.4	38.5	0.9	2.3%					80	28	79	27	1.3%	3.6%
			LKD		W31/F11	39.6	38.7	0.9	2.3%					80	28	79	27	1.3%	3.6%
	R19	RESIDENTIAL	KITCHEN (1)		W32/F11	39.6	38.8	0.8	2.0%	98.3	98.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R20	RESIDENTIAL	LIVING ROOM		W33/F11	39.6	38.8	0.8	2.0%	94.3	94.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R21	RESIDENTIAL	LKD		W34/F11	39.6	38.8	0.8	2.0%	99	99	0.0	0.0%	80	28	79	27	1.3%	3.6%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

SEMLEY HOUSE (CONTINUED)

			LKD		W35/F11	39.5	38.7	0.8	2.0%					80	28	79	27	1.3%	3.6%
			LKD		W36/F11	39.6	38.8	0.8	2.0%					80	28	79	27	1.3%	3.6%
	R22	RESIDENTIAL	KITCHEN (1)		W37/F11	39.6	38.8	0.8	2.0%	98.3	98.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R23	RESIDENTIAL	LIVING ROOM		W38/F11	39.6	38.8	0.8	2.0%	94.3	94.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
F12	R1	RESIDENTIAL	UNKNOWN		W1/F12	31.5	31.5	0	0.0%	100	100	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F12	39.6	39.6	0	0.0%					32	7	32	7	0.0%	0.0%
			UNKNOWN		W3/F12	37.4	36.8	0.6	1.6%					74	22	74	22	0.0%	0.0%

FOUNTAIN COURT

F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	26.5	19.9	6.6	24.9%	85.6	54.9	4.7	35.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	25.8	19	6.8	26.4%	96.3	77.5	3.0	19.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F00	24.8	18.1	6.7	27.0%	97.6	88.8	1.8	9.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F00	24.2	17.4	6.8	28.1%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F00	22.9	16.4	6.5	28.4%	88.3	77.1	1.6	12.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F00	21.2	14.1	7.1	33.5%	75.9	60.2	2.1	20.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F00	19.5	12.3	7.2	36.9%	60.1	42.2	2.6	29.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F00	18.5	11.3	7.2	38.9%	98.9	96.9	0.3	2.0%	18	4	14	4	22.2%	0.0%
			UNKNOWN		W9/F00	22.1	16	6.1	27.6%					41	12	39	12	4.9%	0.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F00	23.4	17.2	6.2	26.5%	98.5	88	0.9	10.6%	43	13	40	12	7.0%	7.7%
	R9	RESIDENTIAL	UNKNOWN		W11/F00	24.4	18.3	6.1	25.0%	98.6	81.6	2.0	17.2%	44	13	42	13	4.5%	0.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	28.4	20.8	7.6	26.8%	88.3	53.8	5.3	39.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.5	19.5	8	29.1%	97.2	77	3.3	20.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F01	26.9	18.8	8.1	30.1%	98.1	88.4	2.0	9.9%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F01	26.3	18.1	8.2	31.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F01	24.9	16.6	8.3	33.3%	89.8	77	1.9	14.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F01	23.8	14.7	9.1	38.2%	77.5	59.9	2.4	22.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F01	22.4	13.1	9.3	41.5%	61.9	41.8	2.9	32.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F01	21.6	12	9.6	44.4%	99	96.9	0.3	2.1%	18	4	14	4	22.2%	0.0%
			UNKNOWN		W9/F01	24.9	17	7.9	31.7%					43	13	40	13	7.0%	0.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F01	26	18.3	7.7	29.6%	98.8	87.4	1.0	11.5%	45	13	40	12	11.1%	7.7%
	R9	RESIDENTIAL	UNKNOWN		W11/F01	27	19.5	7.5	27.8%	98.6	81.1	2.0	17.8%	47	14	42	14	10.6%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
FOUNTAIN COURT (CONTINUED)																			
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.7	21.5	8.2	27.6%	95.1	54	6.3	43.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	17.9	11.3	6.6	36.9%	99.1	75.9	3.7	23.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F02	28.7	19.1	9.6	33.4%	99.4	88.3	2.2	11.1%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F02	28	18.5	9.5	33.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F02	14.4	8.4	6	41.7%	92.2	76.2	2.3	17.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F02	26.3	15	11.3	43.0%	86.7	59.8	3.7	31.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F02	26	13.9	12.1	46.5%	76.5	42.5	4.9	44.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F02	25.3	12.7	12.6	49.8%	99.5	96.9	0.4	2.6%	51	4	13	4	38.1%	5.0%
			UNKNOWN		W9/F02	28	18.1	9.9	35.4%					47	13	39	13	17.0%	0.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F02	29	19.4	9.6	33.1%	99.5	88.4	1.0	11.2%	49	14	41	13	16.3%	7.1%
	R9	RESIDENTIAL	UNKNOWN		W11/F02	29.7	20.6	9.1	30.6%	98.7	81.8	2.0	17.1%	51	16	46	16	9.8%	0.0%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	32.8	23.5	9.3	28.4%	95.9	56.7	6.0	40.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F03	32.6	22.5	10.1	31.0%	99.2	78.6	3.3	20.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F03	32.3	21.4	10.9	33.7%	99.4	89.2	2.0	10.2%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F03	32.1	20.7	11.4	35.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F03	31.6	19.4	12.2	38.6%	99.5	77.4	3.2	22.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F03	30.8	16.9	13.9	45.1%	98.3	60.9	5.1	38.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F03	30	14.8	15.2	50.7%	98.3	43.3	8.0	55.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F03	29.6	13.6	16	54.1%	99.5	97.1	0.4	2.4%	24	5	14	5	41.7%	0.0%
			UNKNOWN		W9/F03	31.5	19.3	12.2	38.7%					51	16	43	16	15.7%	0.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F03	32.1	20.7	11.4	35.5%	99.5	89	0.9	10.5%	54	17	45	16	16.7%	5.9%
	R9	RESIDENTIAL	UNKNOWN		W11/F03	32.5	21.9	10.6	32.6%	98.7	82.7	1.9	16.3%	53	16	46	16	13.2%	0.0%
F04	R1	RESIDENTIAL	UNKNOWN		W1/F04	34.5	24.9	9.6	27.8%	95.9	59.8	5.6	37.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F04	34.5	23.8	10.7	31.0%	99.2	80	3.1	19.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F04	34.5	22.6	11.9	34.5%	99.4	90.1	1.9	9.4%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F04	34.5	21.8	12.7	36.8%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F04	34.4	20.5	13.9	40.4%	99.5	77.9	3.1	21.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F04	34	18	16	47.1%	98.3	61.8	5.0	37.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F04	33.8	15.9	17.9	53.0%	98.3	44.6	7.8	54.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F04	33.6	14.6	19	56.5%	99.6	97.2	0.4	2.4%	23	5	14	5	31.7%	15.7%
			UNKNOWN		W9/F04	34.7	20.6	14.1	40.6%					57	18	44	17	22.8%	5.6%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
FOUNTAIN COURT (CONTINUED)																			
	R8	RESIDENTIAL	UNKNOWN		W10/F04	34.9	22	12.9	37.0%	99.5	90.6	0.8	9.0%	57	18	46	17	19.3%	5.6%
	R9	RESIDENTIAL	UNKNOWN		W11/F04	35.1	23.3	11.8	33.6%	98.7	83.8	1.7	15.1%	59	19	50	19	15.3%	0.0%
F05	R1	RESIDENTIAL	UNKNOWN		W1/F05	35.8	26.3	9.5	26.5%	95.9	62.4	5.2	34.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F05	35.8	25.2	10.6	29.6%	99.2	81.8	2.8	17.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F05	35.9	23.9	12	33.4%	99.4	90.8	1.7	8.7%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F05	35.9	23.1	12.8	35.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F05	35.9	21.7	14.2	39.6%	99.5	78.8	3.0	20.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F05	35.9	19.2	16.7	46.5%	98.3	63.1	4.8	35.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F05	35.9	17	18.9	52.6%	98.3	45.7	7.6	53.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F05	36	15.7	20.3	56.4%	99.6	97.2	0.4	2.3%	32	7	16	5	50.0%	28.6%
			UNKNOWN		W9/F05	36.6	21.8	14.8	40.4%					59	20	44	18	25.4%	10.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F05	36.6	23.2	13.4	36.6%	99.5	92.2	0.6	7.4%	61	20	47	18	23.0%	10.0%
	R9	RESIDENTIAL	UNKNOWN		W11/F05	36.6	24.5	12.1	33.1%	98.7	85.9	1.5	13.0%	60	19	50	19	16.7%	0.0%
F06	R1	RESIDENTIAL	UNKNOWN		W1/F06	36.7	27.6	9.1	24.8%	95.9	66	4.6	31.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F06	36.7	26.5	10.2	27.8%	99.2	84.5	2.4	14.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F06	36.7	25.2	11.5	31.3%	99.4	91.8	1.5	7.6%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F06	36.7	24.3	12.4	33.8%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F06	36.8	22.8	14	38.0%	99.5	80.1	2.8	19.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F06	36.8	20.4	16.4	44.6%	98.3	64.8	4.5	34.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F06	36.8	18.2	18.6	50.5%	98.3	48.1	7.3	51.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F06	36.8	16.8	20	54.3%	99.6	97.8	0.3	1.8%	32	7	17	5	46.9%	28.0%
			UNKNOWN		W9/F06	37.5	23	14.5	38.7%					59	21	45	19	23.7%	9.5%
	R8	RESIDENTIAL	UNKNOWN		W10/F06	37.4	24.4	13	34.8%	99.5	94.4	0.4	5.2%	59	21	46	19	22.0%	9.5%
	R9	RESIDENTIAL	UNKNOWN		W11/F06	37.4	25.7	11.7	31.3%	98.7	88.7	1.2	10.2%	61	21	51	21	16.4%	0.0%
F07	R1	RESIDENTIAL	UNKNOWN		W1/F07	35.3	26.9	8.4	23.8%	95.8	69	4.1	28.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F07	34.9	25.4	9.5	27.2%	99.1	86.3	2.1	12.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F07	34.5	23.7	10.8	31.3%	99.4	92.8	1.3	6.6%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F07	34.2	22.5	11.7	34.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F07	33.7	20.5	13.2	39.2%	99.5	80.3	2.8	19.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F07	33.2	17.6	15.6	47.0%	98.3	64.7	4.6	34.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F07	32.6	14.8	17.8	54.6%	98.2	47.2	7.4	52.0%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

FOUNTAIN COURT (CONTINUED)																			
	R7	RESIDENTIAL	UNKNOWN		W8/F07	32.3	13.1	19.2	59.4%	99.5	97.9	0.3	1.7%	24	7	9	5	62.5%	28.6%
			UNKNOWN		W9/F07	35	21.4	13.6	38.9%					53	20	39	18	26.4%	10.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F07	35	22.8	12.2	34.9%	99.5	95.1	0.4	4.5%	53	20	40	18	24.5%	10.0%
	R9	RESIDENTIAL	UNKNOWN		W11/F07	35	24.1	10.9	31.1%	98.7	90.8	0.9	8.0%	54	21	44	21	18.5%	0.0%
F08	R1	RESIDENTIAL	UNKNOWN		W1/F08	37.8	30.3	7.5	19.8%	83.5	55.8	3.9	33.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F08	38	29.5	8.5	22.4%	96.4	77.5	2.8	19.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F08	38	28.2	9.8	25.8%	97.6	88	1.8	9.8%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F08	38	27.3	10.7	28.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F08	38.2	26	12.2	31.9%	97.6	77.2	2.7	20.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F08	38.1	23.9	14.2	37.3%	93.8	63.3	3.8	32.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F08	38.1	21.7	16.4	43.0%	93.7	38	7.5	59.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F08	38.2	20.4	17.8	46.6%	98	96.6	0.2	1.4%	61	6	17	4	45.2%	33.3%
			UNKNOWN		W9/F08	39.2	26.7	12.5	31.9%					62	21	49	19	21.0%	9.5%
	R8	RESIDENTIAL	UNKNOWN		W10/F08	39.2	28.1	11.1	28.3%	99.9	97.9	0.2	2.1%	62	21	49	19	21.0%	9.5%
	R9	RESIDENTIAL	UNKNOWN		W11/F08	39.2	29.3	9.9	25.3%	99.8	90.1	1.0	9.7%	62	21	54	21	12.9%	0.0%

89-110 COLLESHILL FLATS																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	8	3.7	4.3	53.8%	84.3	24.4	5.5	71.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W2/B01	4.9	5.3	-0.4	-8.2%	41	54.8	-1.0	-33.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	KITCHEN-RESI (1)		W5/B01	21.4	7.5	13.9	65.0%	98.9	57.2	2.1	42.1%	4	0	4	0	0.0%	0.0%
			KITCHEN-RESI (1)		W6/B01	5.8	2.9	2.9	50.0%					0	0	0	0	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/B01	10.1	2	8.1	80.2%	74.6	16.1	5.9	78.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LIVING ROOM		W8/B01	10.4	1.9	8.5	81.7%	77.3	15.8	6.2	79.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	KITCHEN-RESI (1)		W9/B01	5.3	1.4	3.9	73.6%	99.3	62.2	1.9	37.4%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W10/B01	23.2	8.6	14.6	62.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/B01	4.5	2.8	1.7	37.8%	29.9	28.8	0.1	3.8%	0	0	0	0	0.0%	0.0%
	R10	RESIDENTIAL	BEDROOM		W14/B01	9.2	3.4	5.8	63.0%	73.3	30.9	3.9	57.9%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	11.2	5.1	6.1	54.5%	83.1	34.5	4.5	58.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F01	5.5	4	1.5	27.3%	40.6	37.5	0.3	7.7%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F01	8.8	7	1.8	20.5%	99.4	61.8	1.6	37.8%	0	0	0	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F01	27.7	11.8	15.9	57.4%					4	0	4	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 28

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
89-110 COLLESHILL FLATS (CONTINUED)																			
	R6	RESIDENTIAL	BEDROOM		W7/F01	12.1	3.1	9	74.4%	81.7	15.3	6.6	81.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F01	12	3.3	8.7	72.5%	85	20.8	6.4	75.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F01	25.6	10	15.6	60.9%	99.5	90.8	0.4	8.8%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F01	16.9	15.3	1.6	9.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F01	10.7	9.6	1.1	10.3%	50.4	58.3	-0.8	-15.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	13	7.8	5.2	40.0%	92.6	26.8	6.2	71.1%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	12.4	6.4	6	48.4%	89.7	40.1	4.6	55.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F02	6.3	4.9	1.4	22.2%	42.1	40	0.2	4.9%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F02	10	8.3	1.7	17.0%	99.4	69.1	1.3	30.5%	1	0	1	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F02	29.8	13.6	16.2	54.4%					6	0	6	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F02	12.8	3.8	9	70.3%	85.4	20.3	6.5	76.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F02	12.8	4	8.8	68.8%	87.1	25	6.2	71.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F02	27.6	11.7	15.9	57.6%	99.5	94.2	0.2	5.4%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F02	19.1	16.9	2.2	11.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F02	12.6	10.8	1.8	14.3%	60	65.1	-0.5	-8.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	14.5	9	5.5	37.9%	95.1	31.9	5.9	66.5%	N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	14.1	8.3	5.8	41.1%	92.8	48.4	4.2	47.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F03	8	6.8	1.2	15.0%	47.9	47	0.1	1.8%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F03	12.1	10.6	1.5	12.4%	99.4	85.3	0.6	14.2%	1	0	1	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F03	31.9	15.9	16	50.2%					6	0	6	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F03	13.1	4.4	8.7	66.4%	87	26.6	6.0	69.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F03	13.1	4.6	8.5	64.9%	87.3	30.6	5.7	65.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F03	29.9	13.9	16	53.5%	99.5	97.8	0.1	1.7%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F03	21.9	18.8	3.1	14.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F03	15.1	12.3	2.8	18.5%	69	69.7	-0.1	-1.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	16.5	10.7	5.8	35.2%	95.7	39.4	5.3	58.9%	N/A	N/A	N/A	N/A	N/A	N/A
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	17.2	11.8	5.4	31.4%	95.8	61.5	3.2	35.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F04	11.9	10.8	1.1	9.2%	69.3	69.1	0.0	0.4%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F04	16.9	15.6	1.3	7.7%	99.4	99.4	0.0	0.0%	6	0	6	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F04	34	18.7	15.3	45.0%					6	0	6	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F04	8.6	0.5	8.1	94.2%	86.8	10.2	7.6	88.2%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

89-110 COLLESHILL FLATS (CONTINUED)																			
	R7	RESIDENTIAL	BEDROOM		W8/F04	8.8	0.9	7.9	89.8%	87.1	20	6.7	77.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F04	32.4	16.6	15.8	48.8%	99.6	99.4	0.0	0.2%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F04	25.9	21.6	4.3	16.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F04	18.8	14.9	3.9	20.7%	82.1	75.7	0.6	7.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	19.3	12.9	6.4	33.2%	96.8	50.6	4.3	47.7%	N/A	N/A	N/A	N/A	N/A	N/A
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	25.6	20.1	5.5	21.5%	98.9	94.6	0.3	4.3%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W2/F05	31.7	26	5.7	18.0%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W3/F05	29.5	16.3	13.2	44.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	32.3	20.8	11.5	35.6%	100	92.5	0.6	7.5%	0	0	0	0	0.0%	0.0%
			UNKNOWN-RESI		W5/F05	28.5	27.4	1.1	3.9%					39	2	39	2	0.0%	0.0%
			UNKNOWN-RESI		W6/F05	20.3	19.4	0.9	4.4%					10	0	10	0	0.0%	0.0%

176 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	19.4	13.2	6.2	32.0%	76.5	31.6	27.7	58.7%	32	8	19	3	40.6%	62.5%
			UNKNOWN		W2/B01	0	0	0	-					0	0	0	0	0.0%	0.0%
			UNKNOWN		W3/B01	17.3	11.7	5.6	32.4%					34	8	23	4	32.4%	50.0%
			UNKNOWN		W4/B01	14.6	10.3	4.3	29.5%					35	9	26	4	25.7%	55.6%
			UNKNOWN		W5/B01	8.5	8.5	0	0.0%					6	1	6	1	0.0%	0.0%
F00	R1	RESIDENTIAL	BEDROOM		W1/F00	22.3	16.5	5.8	26.0%	95.3	74.1	3.3	22.3%	39	9	29	4	25.6%	55.6%
	R2	RESIDENTIAL	LIVING ROOM		W2/F00	16.6	12.6	4	24.1%	88.4	70.8	3.3	19.9%	41	10	31	5	24.4%	50.0%
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	23.8	18.3	5.5	23.1%	93.1	69.5	3.7	25.3%	35	6	23	2	34.3%	66.7%
	R2	RESIDENTIAL	BEDROOM		W2/F01	26.1	20.9	5.2	19.9%	93.3	71.7	3.3	23.1%	47	11	39	7	17.0%	36.4%
	R3	RESIDENTIAL	LIVING ROOM		W3/F01	19.7	16.2	3.5	17.8%	77.6	61.8	3.0	20.5%	48	15	42	11	12.5%	26.7%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	28.2	23.3	4.9	17.4%	86.8	55	6.1	36.7%	46	8	38	4	17.4%	50.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	30.3	25.8	4.5	14.9%	89.5	68	3.3	24.1%	59	17	50	12	15.3%	29.4%
	R3	RESIDENTIAL	LKD		W3/F02	26.9	23.6	3.3	12.3%	70.5	45.5	7.3	35.6%	56	18	52	14	7.1%	22.2%

174 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	17.5	12.7	4.8	27.4%	58.8	18.4	7.0	68.7%	26	1	17	0	34.6%	100.0%
	R2	RESIDENTIAL	UNKNOWN		W2/B01	11.9	10.1	1.8	15.1%	55	14.9	6.2	72.9%	27	6	23	5	14.8%	16.7%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.4	15.9	7.5	32.1%	96.6	41.4	12.1	57.1%	47	14	28	6	40.4%	57.1%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

174 MOZART TERRACE (CONTINUED)																			
			UNKNOWN		W2/F00	23.4	15.9	7.5	32.1%					46	12	28	6	39.1%	50.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.6	18.8	6.8	26.6%	73.7	49.1	3.0	33.4%	48	14	32	7	33.3%	50.0%
	R3	RESIDENTIAL	UNKNOWN		W2/F01	25.6	18.9	6.7	26.2%	95.5	46.4	10.1	51.4%	51	15	34	7	33.3%	53.3%
			UNKNOWN		W3/F01	25.7	19	6.7	26.1%					51	13	34	7	33.3%	46.2%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28	22.3	5.7	20.4%	74.3	54.7	2.4	26.4%	56	16	42	9	25.0%	43.8%
	R3	RESIDENTIAL	UNKNOWN		W2/F02	28.1	22.4	5.7	20.3%	95	51.5	9.0	45.7%	53	16	44	9	17.0%	43.8%
			UNKNOWN		W3/F02	28.1	22.6	5.5	19.6%					53	15	44	9	17.0%	40.0%

172 MOZART TERRACE																			
B01	R1	RESIDENTIAL	DINING ROOM		W1/B01	18.2	13	5.2	28.6%	74.7	21.5	8.5	71.2%	30	1	17	0	43.3%	100.0%
			DINING ROOM		W2/B01	16	9.2	6.8	42.5%					29	6	13	2	55.2%	66.7%
	R2	RESIDENTIAL	LIVING ROOM		W3/B01	20.2	13.7	6.5	32.2%	83.5	22.3	12.8	73.2%	39	7	26	5	33.3%	28.6%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.7	16	7.7	32.5%	96.6	92.6	1.2	4.2%	45	11	23	4	48.9%	63.6%
			UNKNOWN		W2/F00	24	16.1	7.9	32.9%					46	12	26	6	43.5%	50.0%
			UNKNOWN		W5/F00	22.6	22.6	0	0.0%									0.0%	0.0%
			UNKNOWN		W6/F00	27.4	27.4	0	0.0%					8	0	8	0	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W3/F00	24.3	16.5	7.8	32.1%	93.1	32.4	10.1	65.3%	46	13	28	6	39.1%	53.8%
			BEDROOM		W4/F00	24.4	16.6	7.8	32.0%					46	12	28	6	39.1%	50.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.5	18.4	7.1	27.8%	97	37	7.7	61.9%	48	12	28	5	41.7%	58.3%
			UNKNOWN		W2/F01	25.7	18.6	7.1	27.6%					49	13	31	7	36.7%	46.2%
	R2	RESIDENTIAL	UNKNOWN		W3/F01	26	18.8	7.2	27.7%	85.4	33.9	4.7	60.3%	49	13	32	7	34.7%	46.2%
	R3	RESIDENTIAL	UNKNOWN		W4/F01	26.1	18.9	7.2	27.6%	92.7	32.8	9.9	64.6%	50	14	34	7	32.0%	50.0%
			UNKNOWN		W5/F01	26.2	19	7.2	27.5%					49	13	35	7	28.6%	46.2%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.5	21.4	6.1	22.2%	90.4	41.6	9.0	53.9%	52	15	36	7	30.8%	53.3%
			UNKNOWN		W2/F02	27.8	21.6	6.2	22.3%					52	15	39	9	25.0%	40.0%
	R2	RESIDENTIAL	UNKNOWN		W3/F02	28.1	22	6.1	21.7%	93.5	41.7	10.7	55.4%	54	15	42	10	22.2%	33.3%
			UNKNOWN		W4/F02	28.2	22.1	6.1	21.6%					53	15	42	10	20.8%	33.3%

170 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18	13.2	4.8	26.7%	98.9	35.2	7.9	64.4%	21	1	10	0	52.4%	100.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	21.8	16.1	5.7	26.1%	99.1	42.6	7.0	57.0%	27	4	16	0	40.7%	100.0%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

170 MOZART TERRACE (CONTINUED)

F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	20.4	16	4.4	21.6%	98.5	58	7.4	41.1%	21	2	16	0	23.8%	100.0%
			UNKNOWN		W2/F01	24.6	19.6	5	20.3%					34	5	25	2	26.5%	60.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	23.5	20.1	3.4	14.5%	98.7	61.9	6.7	37.3%	25	3	23	1	8.0%	66.7%
			UNKNOWN		W2/F02	28.1	24.2	3.9	13.9%					44	8	40	4	9.1%	50.0%

168 MOZART TERRACE

B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	16	12.5	3.5	21.9%	92.3	35.4	10.5	61.7%	16	0	9	0	43.8%	0.0%
			UNKNOWN		W2/B01	17.8	14.1	3.7	20.8%					31	4	22	3	29.0%	25.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	24.7	18.4	6.3	25.5%	95.4	38.3	9.7	59.8%	38	8	28	4	26.3%	50.0%
			UNKNOWN		W3/F00	24.8	18.7	6.1	24.6%					41	11	30	5	26.8%	54.5%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	26.7	21.3	5.4	20.2%	93.3	59.3	3.0	36.4%	45	9	34	3	24.4%	66.7%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.1	21.8	5.3	19.6%	98.7	60	6.3	39.2%	49	12	37	5	24.5%	58.3%
			UNKNOWN		W3/F01	27.2	22.1	5.1	18.7%					53	15	41	8	22.6%	46.7%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.5	25.3	4.2	14.2%	94.7	67.2	2.4	29.0%	55	15	48	10	12.7%	33.3%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	29.6	25.5	4.1	13.9%	98.4	68.2	4.9	30.7%	58	17	49	12	15.5%	29.4%
			UNKNOWN		W3/F02	29.6	25.6	4	13.5%					58	17	49	12	15.5%	29.4%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	31.7	28.3	3.4	10.7%	93.2	67.4	2.2	27.7%	59	18	56	15	5.1%	16.7%
	R2	RESIDENTIAL	UNKNOWN		W2/F03	31.7	28.4	3.3	10.4%	97.5	76.1	3.4	22.0%	60	19	56	15	6.7%	21.1%
			UNKNOWN		W3/F03	31.6	28.5	3.1	9.8%					62	20	56	15	9.7%	25.0%

166 MOZART TERRACE

B01	R1	RESIDENTIAL	LIVING ROOM		W1/B01	14.5	11.9	2.6	17.9%	67.2	27.4	10.6	59.2%	16	1	9	0	43.8%	100.0%
			LIVING ROOM		W2/B01	17.8	14.1	3.7	20.8%					33	4	23	2	30.3%	50.0%
			LIVING ROOM		W3/B01	16.3	12.8	3.5	21.5%					36	6	26	4	27.8%	33.3%
F00	R2	RESIDENTIAL	DINING ROOM		W2/F00	24.8	19.3	5.5	22.2%	87.7	44.3	9.6	49.5%	46	12	33	5	28.3%	58.3%
			DINING ROOM		W3/F00	24.7	19.4	5.3	21.5%					45	11	35	6	22.2%	45.5%
F01	R2	RESIDENTIAL	DRAWING ROOM		W1/F01	27.3	22.6	4.7	17.2%	98.4	66.5	9.0	32.4%	52	16	43	10	17.3%	37.5%
			DRAWING ROOM		W2/F01	27.1	22.7	4.4	16.2%					52	17	44	11	15.4%	35.3%
			DRAWING ROOM		W3/F01	27	22.8	4.2	15.6%					53	16	44	11	17.0%	31.3%
F02	R2	RESIDENTIAL	BEDROOM		W1/F02	29.7	26.2	3.5	11.8%	99.1	99.1	0.0	0.0%	58	17	50	13	13.8%	23.5%
			BEDROOM		W2/F02	29.6	26.3	3.3	11.1%					58	17	50	13	13.8%	23.5%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
166 MOZART TERRACE (CONTINUED)																			
			BEDROOM		W3/F02	29.5	26.4	3.1	10.5%					59	18	51	13	13.6%	27.8%
F03	R1	RESIDENTIAL	DRESSING ROOM		W1/F03	31.4	28.7	2.7	8.6%	89	87.9	0.1	1.2%	60	19	56	16	6.7%	15.8%
164 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	14.3	10.6	3.7	25.9%	64.9	32.5	8.0	49.9%	25	2	12	0	52.0%	100.0%
			UNKNOWN		W2/B01	10.5	10.5	0	0.0%					22	3	22	3	0.0%	0.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	24.6	19.7	4.9	19.9%	95.6	54.1	7.4	43.4%	48	13	35	8	27.1%	38.5%
			UNKNOWN		W3/F00	24.6	19.8	4.8	19.5%					46	12	35	8	23.9%	33.3%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	27	22.9	4.1	15.2%	91.1	76.6	1.1	15.9%	52	15	45	12	13.5%	20.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27	23	4	14.8%	99.2	78.6	3.5	20.8%	54	16	47	12	13.0%	25.0%
			UNKNOWN		W3/F01	27	23.1	3.9	14.4%					54	15	46	11	14.8%	26.7%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.4	26.5	2.9	9.9%	88.8	79	0.7	11.0%	57	16	54	14	5.3%	12.5%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	29.4	26.6	2.8	9.5%	99.2	80.7	3.1	18.6%	57	16	53	14	7.0%	12.5%
			UNKNOWN		W3/F02	29.4	26.6	2.8	9.5%					59	17	54	14	8.5%	17.6%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	29.8	27.4	2.4	8.1%	86.1	75.5	1.3	12.3%	53	17	49	13	7.5%	23.5%
	R2	RESIDENTIAL	UNKNOWN		W2/F03	29.7	27.5	2.2	7.4%	85.6	67.5	2.2	21.1%	54	18	50	14	7.4%	22.2%
162 MOZART TERRACE																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	17	15.1	1.9	11.2%	71.3	38.7	8.5	45.7%	29	2	21	0	27.6%	100.0%
			BEDROOM		W2/B01	14.9	13.4	1.5	10.1%					33	6	27	5	18.2%	16.7%
F00	R2	RESIDENTIAL	DINING ROOM		W2/F00	24.7	19.9	4.8	19.4%	94.4	54.7	8.3	42.1%	51	14	36	8	29.4%	42.9%
			DINING ROOM		W3/F00	24.7	20	4.7	19.0%					52	15	37	8	28.8%	46.7%
F01	R1	RESIDENTIAL	DRAWING ROOM		W1/F01	27.1	23.2	3.9	14.4%	99	82.7	4.3	16.4%	53	15	45	11	15.1%	26.7%
			DRAWING ROOM		W2/F01	27.1	23.3	3.8	14.0%					53	15	45	12	15.1%	20.0%
			DRAWING ROOM		W3/F01	27.3	23.4	3.9	14.3%					54	16	46	12	14.8%	25.0%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	29.5	26.8	2.7	9.2%	98.5	88.7	2.6	10.0%	60	17	54	14	10.0%	17.6%
			BEDROOM		W2/F02	29.6	26.9	2.7	9.1%					59	17	53	14	10.2%	17.6%
			BEDROOM		W3/F02	29.7	27	2.7	9.1%					59	17	54	14	8.5%	17.6%
102 EATON TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	4.7	4.7	0	0.0%	56.6	37.1	3.8	34.4%	1	0	1	0	0.0%	0.0%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

102 EATON TERRACE (CONTINUED)																			
	R2	RESIDENTIAL	UNKNOWN		W2/B01	9	8.9	0.1	1.1%	56.5	56.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/B01	9	9	0	0.0%	57	57	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	14.3	11.8	2.5	17.5%	86.7	64.1	3.4	26.1%	25	4	20	1	20.0%	75.0%
	R3	RESIDENTIAL	UNKNOWN		W3/F00	14.4	13.2	1.2	8.3%	99.1	99	0.0	0.1%	38	13	32	8	15.8%	38.5%
			UNKNOWN		W4/F00	22.5	19.3	3.2	14.2%					50	14	42	10	16.0%	28.6%
			UNKNOWN		W5/F00	25	21	4	16.0%					51	15	42	10	17.6%	33.3%
			UNKNOWN		W6/F00	24.7	21.3	3.4	13.8%					48	13	40	8	16.7%	38.5%
			UNKNOWN		W7/F00	24.6	22.2	2.4	9.8%					39	10	31	5	20.5%	50.0%
			UNKNOWN		W8/F00	23.1	22	1.1	4.8%					34	9	19	4	20.5%	50.0%
			UNKNOWN		W9/F00	15.4	15.4	0	0.0%					10	0	10	0	0.0%	0.0%
			UNKNOWN		W10/F00	24.3	24.2	0.1	0.4%					10	0	10	0	0.0%	0.0%
	R5	RESIDENTIAL	UNKNOWN		W12/F00	23.1	23.1	0	0.0%	89.2	89.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	15.1	13.1	2	13.2%	91	67.7	4.5	25.6%	22	2	18	0	18.2%	100.0%
			UNKNOWN		W2/F01	16.6	13.6	3	18.1%					34	10	28	6	17.6%	40.0%
	R2	RESIDENTIAL	UNKNOWN		W3/F01	11.8	10.7	1.1	9.3%	69	68.7	0.0	0.4%	33	12	30	9	9.1%	25.0%
	R3	RESIDENTIAL	UNKNOWN		W4/F01	27.3	24.6	2.7	9.9%	99.2	97.9	0.2	1.3%	55	16	49	12	10.9%	25.0%
			UNKNOWN		W5/F01	27.2	27.1	0.1	0.4%					15	0	15	0	0.0%	0.0%
	R4	RESIDENTIAL	UNKNOWN		W6/F01	26.9	26.8	0.1	0.4%	97.7	97.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F01	26.2	26.1	0.1	0.4%					N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	17.8	16.5	1.3	7.3%	85.6	65.4	4.0	23.7%	26	3	23	1	11.5%	66.7%
			UNKNOWN		W2/F02	19.3	17.3	2	10.4%					38	10	34	6	10.5%	40.0%
	R2	RESIDENTIAL	UNKNOWN		W3/F02	20.8	20	0.8	3.8%	88.3	88.2	0.0	0.0%	44	14	42	12	4.5%	14.3%
	R3	RESIDENTIAL	UNKNOWN		W4/F02	29.6	27.6	2	6.8%	99.2	98.5	0.1	0.7%	59	18	57	16	3.4%	11.1%
			UNKNOWN		W5/F02	29.4	29.3	0.1	0.3%					15	0	15	0	0.0%	0.0%
	R4	RESIDENTIAL	UNKNOWN		W6/F02	29.1	29	0.1	0.3%	97.8	97.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F02	28.4	28.4	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	31.8	31.1	0.7	2.2%	91.3	90.9	0.0	0.4%	69	20	67	18	2.9%	10.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F03	32.1	30.4	1.7	5.3%	96.2	96.1	0.0	0.0%	65	21	62	18	4.6%	14.3%
			UNKNOWN		W3/F03	31.8	31.8	0	0.0%					20		20		0.0%	0.0%
	R3	RESIDENTIAL	UNKNOWN		W4/F03	31.4	31.4	0	0.0%	97	97	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F03	30.8	30.7	0.1	0.3%					N/A	N/A	N/A	N/A	N/A	N/A

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

180 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	15.1	9.3	5.8	38.4%	67	25.1	2.8	62.5%	16	1	4	0	75.0%	100.0%
	R2	RESIDENTIAL	UNKNOWN		W2/B01	20.7	14	6.7	32.4%	95.7	31.2	10.3	67.4%	36	4	22	2	38.9%	50.0%
			UNKNOWN		W3/B01	19.2	13.2	6	31.2%					39	10	29	8	25.6%	20.0%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	24.7	17.4	7.3	29.6%	96	48.4	8.4	49.6%	48	12	32	9	33.3%	25.0%
			UNKNOWN		W2/F00	24.8	17.3	7.5	30.2%					47	12	32	9	31.9%	25.0%
F01	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.2	20.6	6.6	24.3%	96.3	66.2	5.3	31.3%	53	13	38	10	28.3%	23.1%
			UNKNOWN		W3/F01	27.3	20.4	6.9	25.3%					54	14	38	10	29.6%	28.6%
F02	R2	RESIDENTIAL	UNKNOWN		W2/F02	29.9	24.1	5.8	19.4%	97.2	75.7	3.9	22.1%	59	18	49	15	16.9%	16.7%
			UNKNOWN		W3/F02	30	23.9	6.1	20.3%					60	19	49	15	18.3%	21.1%

182 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18.5	14.1	4.4	23.8%	95.5	32.8	10.1	65.7%	30	1	21	1	30.0%	0.0%
			UNKNOWN		W2/B01	18.2	14.3	3.9	21.4%					36	5	27	5	25.0%	0.0%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.9	18.4	5.5	23.0%	95.9	54.6	7.0	43.1%	44	11	34	9	22.7%	18.2%
			UNKNOWN		W2/F00	24	18.1	5.9	24.6%					43	10	32	8	25.6%	20.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	26.6	21.7	4.9	18.4%	96.5	89.6	1.2	7.2%	51	14	42	12	17.6%	14.3%
			UNKNOWN		W2/F01	26.8	21.5	5.3	19.8%					51	14	41	11	19.6%	21.4%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.6	25.3	4.3	14.5%	96.4	92.5	0.7	4.1%	58	17	51	15	12.1%	11.8%
			UNKNOWN		W2/F02	29.7	25	4.7	15.8%					59	18	50	15	15.3%	16.7%

184 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18	14.4	3.6	20.0%	67.2	22.2	11.0	66.9%	34	3	25	2	26.5%	33.3%
			UNKNOWN		W2/B01	16	13.2	2.8	17.5%					34	7	27	6	20.6%	14.3%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	22.3	18.6	3.7	16.6%	81.3	49.7	7.4	38.9%	45	11	35	10	22.2%	9.1%
			UNKNOWN		W3/F00	22.9	18.5	4.4	19.2%					47	12	35	10	25.5%	16.7%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24.4	21.7	2.7	11.1%	81.1	63	2.0	22.3%	46	10	40	10	13.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	24.9	21.7	3.2	12.9%	84.1	65.6	4.0	22.0%	50	12	43	11	14.0%	8.3%
			UNKNOWN		W3/F01	25.5	21.6	3.9	15.3%					52	13	42	11	19.2%	15.4%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.1	24.6	2.5	9.2%	100	100	0.0	0.0%	52	12	46	12	11.5%	0.0%
			UNKNOWN		W3/F02 / HZ (2)	78.4	77.8	0.6	0.8%					37	4	34	4	8.1%	0.0%

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
184 MOZART TERRACE (CONTINUED)																			
	R2	RESIDENTIAL	UNKNOWN		W2/F02	27.6	24.5	3.1	11.2%	82.8	62	4.5	25.1%	54	15	47	14	13.0%	6.7%
			UNKNOWN		W4/F02	28	24.5	3.5	12.5%					56	16	48	14	14.3%	12.5%
186 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	15.6	14.2	1.4	9.0%	45	26.2	4.5	41.9%	25	1	23	1	8.0%	0.0%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	20.4	18.8	1.6	7.8%	71.4	45.6	5.0	36.1%	34	8	33	8	2.9%	0.0%
			UNKNOWN		W2/F00	20.9	18.8	2.1	10.0%					38	9	33	9	13.2%	0.0%
F01	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.4	21.8	1.6	6.8%	80.6	63.3	2.9	21.4%	46	12	43	12	6.5%	0.0%
			UNKNOWN		W3/F01	23.6	21.7	1.9	8.1%					43	10	39	10	9.3%	0.0%
F02	R2	RESIDENTIAL	UNKNOWN		W2/F02	26.2	24.7	1.5	5.7%	75.6	56.7	3.2	25.0%	51	14	49	14	3.9%	0.0%
			UNKNOWN		W3/F02	26.5	24.6	1.9	7.2%					51	14	48	14	5.9%	0.0%
188 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	13.4	12.8	0.6	4.5%	34.3	33.2	0.2	3.0%	13	0	13	0	0.0%	0.0%
			UNKNOWN		W2/B01	11.6	11.6	0	0.0%					21	1	21	1	0.0%	0.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	18.4	17.6	0.8	4.3%	61.5	51.5	2.0	16.3%	29	3	29	3	0.0%	0.0%
			UNKNOWN		W3/F00	19.3	18.3	1	5.2%					34	8	34	8	0.0%	0.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	23.5	22.9	0.6	2.6%	62.1	62.1	0.0	0.0%	47	14	46	14	2.1%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.4	22.6	0.8	3.4%	71.8	64.6	1.3	10.0%	47	14	46	14	2.1%	0.0%
			UNKNOWN		W3/F01	23.2	22.2	1	4.3%					43	12	42	12	2.3%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	26.5	25.8	0.7	2.6%	59.5	59.5	0.0	0.0%	52	15	51	15	1.9%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	26.3	25.6	0.7	2.7%	68.4	62.2	1.1	9.1%	53	15	51	15	3.8%	0.0%
			UNKNOWN		W3/F02	26.1	25.2	0.9	3.4%					51	13	49	13	3.9%	0.0%
190 EBURY STREET																			
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24.4	24	0.4	1.6%	48.7	48.7	0.0	0.0%	45	14	45	14	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	24	23.5	0.5	2.1%	48.1	48.1	0.0	0.0%	46	14	46	14	0.0%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.2	26.8	0.4	1.5%	61.7	61.7	0.0	0.0%	51	16	51	16	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	26.8	26.3	0.5	1.9%	60.3	60.3	0.0	0.0%	51	15	51	15	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
192 EBURY STREET																			
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.5	25.3	0.2	0.8%	80.9	80.5	0.1	0.5%	44	15	44	15	0.0%	0.0%
			UNKNOWN		W2/F01	24.9	24.6	0.3	1.2%					44	14	44	14	0.0%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28.1	27.8	0.3	1.1%	95.5	95.4	0.0	0.1%	53	17	53	17	0.0%	0.0%
			UNKNOWN		W2/F02	27.6	27.3	0.3	1.1%					51	16	51	16	0.0%	0.0%
			UNKNOWN		W3/F02 / INC (2)	63	63	0	0.0%					53	15	53	15	0.0%	0.0%
194 EBURY STREET																			
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.9	25.7	0.2	0.8%	94.4	94.4	0.0	0.0%	36	12	36	12	0.0%	0.0%
			UNKNOWN		W2/F01	25.9	25.7	0.2	0.8%					42	13	42	13	0.0%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28.3	28.1	0.2	0.7%	95.4	95.4	0.0	0.0%	44	12	44	12	0.0%	0.0%
			UNKNOWN		W2/F02	28.4	28.2	0.2	0.7%					49	13	49	13	0.0%	0.0%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	31.5	31.2	0.3	1.0%	85.8	85.8	0.0	0.0%	58	18	57	18	1.7%	0.0%
17A PIMLICO ROAD																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	18.1	15.3	2.8	15.5%	96.7	94	0.3	2.8%	N/A	N/A	N/A	N/A	N/A	N/A
F00	R1	RESIDENTIAL	KITCHEN		W1/F00	21.3	17.9	3.4	16.0%	81.1	74.8	1.0	7.8%	N/A	N/A	N/A	N/A	N/A	N/A
17 PIMLICO ROAD																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	13.8	13.3	0.5	3.6%	51.8	56	-0.7	-8.1%	N/A	N/A	N/A	N/A	N/A	N/A
F00	R2	RESIDENTIAL	UNKNOWN		W3/F00	17.8	16.3	1.5	8.4%	71.9	68.1	0.6	5.3%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24.3	20.7	3.6	14.8%	92.8	92.3	0.1	0.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.4	20.9	2.5	10.7%	80.9	73.3	0.8	9.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F01	22.6	20.9	1.7	7.5%	87	79.9	1.2	8.1%	7	0	7	0	0.0%	0.0%
			UNKNOWN		W4/F01	0	0	0	-					0	0	0	0	0.0%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.7	24	3.7	13.4%	77.4	70.1	1.4	9.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	27	24.2	2.8	10.4%	89.1	78	1.2	12.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F02	26.3	24.4	1.9	7.2%	80.4	72.4	1.3	10.0%	8	0	8	0	0.0%	0.0%
			UNKNOWN		W4/F02	0	0	0	-					0	0	0	0	0.0%	0.0%
15 PIMLICO ROAD																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	17.3	15	2.3	13.3%	91.8	58.3	5.0	36.4%	N/A	N/A	N/A	N/A	N/A	N/A

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

15 PIMLICO ROAD (CONTINUED)

			UNKNOWN		W2/B01	19.5	15.8	3.7	19.0%					N/A	N/A	N/A	N/A	N/A	N/A
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	22.3	17.9	4.4	19.7%	96.9	82.7	21	14.7%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R2	RESIDENTIAL	UNKNOWN		W2/F01	25.4	20.7	4.7	18.5%	99.1	97.6	0.2	1.4%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28.3	23.5	4.8	17.0%	74.4	66.1	1.2	11.1%	N/A	N/A	N/A	N/A	N/A	N/A

13 PIMLICO ROAD

B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18.5	12.8	5.7	30.8%	70.2	51.4	2.8	26.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/B01	18	14.6	3.4	18.9%	86.9	54.6	5.3	37.1%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W3/B01	19.3	14.2	5.1	26.4%					N/A	N/A	N/A	N/A	N/A	N/A
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.1	16.8	6.3	27.3%	97	90.4	1.0	6.8%	1	0	2	1	0.0%	0.0%
			UNKNOWN		W4/F00	11.5	11.4	0.1	0.9%					19	2	19	2	0.0%	0.0%
	R3	RESIDENTIAL	UNKNOWN		W3/F00	23.3	17.7	5.6	24.0%	94.7	80.1	2.4	15.4%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	26.5	19.6	6.9	26.0%	98.5	97.3	0.2	1.3%	4	0	4	0	0.0%	0.0%
			UNKNOWN		W4/F01	19.3	19.3	0	0.0%					38	7	38	7	0.0%	0.0%
	R3	RESIDENTIAL	UNKNOWN		W3/F01	26.1	20.2	5.9	22.6%	98.8	95.1	0.6	3.8%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.4	22.2	7.2	24.5%	99.4	98.7	0.1	0.6%	7	0	7	0	0.0%	0.0%
			UNKNOWN		W3/F02	28.9	28.8	0.1	0.3%					60	18	60	18	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	29	22.9	6.1	21.0%	67	55.3	1.9	17.4%	N/A	N/A	N/A	N/A	N/A	N/A

2 RANELAGH GROVE

F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	12.9	12.1	0.8	6.2%	89.3	88.9	0.0	0.4%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	23.5	19.7	3.8	16.2%	98	95.7	0.4	2.3%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F01	24	19.8	4.2	17.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W3/F01	16.2	15.4	0.8	4.9%	88.3	87.9	0.0	0.4%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.6	23.3	4.3	15.6%	98.2	97.5	0.1	0.7%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F02	28.2	23.4	4.8	17.0%					N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	30.3	25.7	4.6	15.2%	72.3	44.7	3.5	38.2%	N/A	N/A	N/A	N/A	N/A	N/A

4 RANELAGH GROVE

F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	12.9	9.9	3	23.3%	59.8	59.6	0.0	0.4%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	15.7	12.5	3.2	20.4%	65.3	65.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
4 RANELAGH GROVE (CONTINUED)																			
	R2	RESIDENTIAL	UNKNOWN		W2/F01	16.6	13.7	2.9	17.5%	52.7	51.9	0.1	1.5%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	23.7	20	3.7	15.6%	95.7	95.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	22.9	19.8	3.1	13.5%	71.6	71.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	28	25.6	2.4	8.6%	69.7	65.5	0.4	6.0%	N/A	N/A	N/A	N/A	N/A	N/A
67-88 COLLESHILL FLATS																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	8.5	2.1	6.4	75.3%	77.3	17.1	5.5	77.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W2/B01	4.3	1	3.3	76.7%	27.2	6.7	1.5	75.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	KITCHEN-RESI (1)		W5/B01	24.3	11.4	12.9	53.1%	96.9	76	11	21.6%	4	0	4	0	0.0%	0.0%
			KITCHEN-RESI (1)		W6/B01	5.2	4.2	1	19.2%					0	0	0	0	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/B01	11.2	6.2	5	44.6%	82.1	53.6	2.9	34.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LIVING ROOM		W8/B01	9.9	3.4	6.5	65.7%	77	27.5	5.0	64.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	KITCHEN-RESI (1)		W9/B01	5.1	1.2	3.9	76.5%	97.2	85.8	0.6	11.8%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W10/B01	24.1	13	11.1	46.1%					N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/B01	3.3	3.1	0.2	6.1%	27	27	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R10	RESIDENTIAL	BEDROOM		W14/B01	10.1	6.7	3.4	33.7%	87.7	64.2	2.2	26.8%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	12.1	9	3.1	25.6%	91.4	72.3	1.8	20.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F01	4.6	4.4	0.2	4.3%	36.7	36.7	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F01	7.4	7.2	0.2	2.7%	98.9	98.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F01	27.9	17.7	10.2	36.6%					0	0	0	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F01	11.8	5	6.8	57.6%	83.8	32.4	5.1	61.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F01	12.9	8.1	4.8	37.2%	86.1	60.1	2.6	30.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F01	28.2	14	14.2	50.4%	99.1	76.5	1.0	22.8%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F01	8.6	3.5	5.1	59.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F01	5.2	2.1	3.1	59.6%	40.4	10.6	2.9	73.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	10.6	3.7	6.9	65.1%	89.3	21.2	6.4	76.2%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	13.1	10.3	2.8	21.4%	91.9	77.7	1.3	15.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F02	5.6	5.5	0.1	1.8%	41.4	41.4	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F02	8.9	8.7	0.2	2.2%	98.9	98.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F02	30.2	20.3	9.9	32.8%					0	0	0	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F02	12.6	5.9	6.7	53.2%	86.3	39.4	4.7	54.4%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 39

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
67-88 COLLESHILL FLATS (CONTINUED)																			
	R7	RESIDENTIAL	BEDROOM		W8/F02	13.7	9.1	4.6	33.6%	86.9	65.7	2.1	24.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F02	30.3	16.1	14.2	46.9%	99.1	83.6	0.7	15.7%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F02	9.7	4.8	4.9	50.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F02	6.1	3	3.1	50.8%	42.2	15.3	2.7	63.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	11.8	4.9	6.9	58.5%	91.8	28.3	5.9	69.2%	N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	14.7	12.2	2.5	17.0%	93	85.4	0.7	8.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F03	7.5	7.3	0.2	2.7%	47.3	47.3	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F03	11.3	11.2	0.1	0.9%	98.9	98.9	0.0	0.0%	1	0	1	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F03	32.4	23.1	9.3	28.7%					5	0	5	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F03	12.9	6.5	6.4	49.6%	87.2	49.8	3.7	42.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F03	13.8	9.6	4.2	30.4%	87.1	72.4	1.5	16.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F03	32.4	18.6	13.8	42.6%	99.1	89.5	0.4	9.7%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F03	11.8	7.2	4.6	39.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F03	7.7	4.9	2.8	36.4%	47.9	25.2	2.2	47.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	13.5	6.9	6.6	48.9%	93.1	38.6	5.1	58.6%	N/A	N/A	N/A	N/A	N/A	N/A
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	17.8	15.7	2.1	11.8%	95.8	94.6	0.1	1.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F04	11.5	11.3	0.2	1.7%	67.5	67.5	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F04	16.4	16.2	0.2	1.2%	98.9	98.9	0.0	0.0%	4	0	4	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F04	34.5	26.2	8.3	24.1%					5		5	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F04	8.4	2.6	5.8	69.0%	87.1	52.8	3.4	39.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F04	9.2	5.5	3.7	40.2%	86.9	78.8	0.8	9.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F04	34.4	21.6	12.8	37.2%	99.1	98.9	0.0	0.3%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F04	16.7	12.4	4.3	25.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F04	11.6	8.9	2.7	23.3%	69.1	47.7	2.1	30.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	16.8	10.5	6.3	37.5%	96	55.4	3.8	42.3%	N/A	N/A	N/A	N/A	N/A	N/A
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	19.7	16.7	3	15.2%	98.9	98	0.1	0.9%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W2/F05	27	22.8	4.2	15.6%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W3/F05	30.2	19.8	10.4	34.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	31.4	26.5	4.9	15.6%	98.8	98.3	0.0	0.5%	0	0	0	0	0.0%	0.0%
			UNKNOWN-RESI		W5/F05	27.3	27.2	0.1	0.4%					34	1	34	1	0.0%	0.0%
			UNKNOWN-RESI		W6/F05	19.8	19.6	0.2	1.0%					10	0	10	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 40

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

45-66 COLLESHILL FLATS																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	10.3	5.9	4.4	42.7%	86.7	57.4	2.7	33.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W2/B01	3.6	1.9	1.7	47.2%	27.6	14	1.0	49.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	KITCHEN-RESI (1)		W5/B01	20.8	14.2	6.6	31.7%	99.4	99.2	0.0	0.2%	4	0	4	0	0.0%	0.0%
			KITCHEN-RESI (1)		W6/B01	3.2	3.2	0	0.0%					0	0	0	0	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/B01	8.8	6.9	1.9	21.6%	65.9	51.8	1.4	21.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LIVING ROOM		W8/B01	10.2	7	3.2	31.4%	80.2	53.6	2.7	33.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	KITCHEN-RESI (1)		W9/B01	5.2	3.2	2	38.5%	98.9	98.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W10/B01	18.3	14.1	4.2	23.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/B01	10.3	14.4	-4.1	-39.8%	84.1	84.2	0.0	-0.1%	5	0	11	1	-120.0%	-
	R10	RESIDENTIAL	BEDROOM		W14/B01	8.8	10.1	-1.3	-14.8%	50.8	50.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	12	7.9	4.1	34.2%	91.5	70.7	1.9	22.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F01	4.7	3	1.7	36.2%	39.5	14.5	2.5	63.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F01	8.3	4.6	3.7	44.6%	99.3	98.9	0.0	0.4%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W4/F01	27.1	19.8	7.3	26.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W7/F01	11.2	9.5	1.7	15.2%	77.8	71.4	0.6	8.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F01	12.2	9.4	2.8	23.0%	83.9	67.7	1.6	19.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F01	23.6	19.7	3.9	16.5%	99.6	99.6	0.0	0.0%	5	0	5	0	0.0%	0.0%
			KITCHEN-RESI (1)		W12/F01	26.8	26.8	0	0.0%					29	6	29	6	0.0%	0.0%
	R11	RESIDENTIAL	LIVING ROOM		W13/F01	19.6	19.6	0	0.0%	71.9	71.9	0.0	0.0%	16	2	16	2	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W14/F01	14.1	14.1	0	0.0%	74.5	74.4	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	13	9.2	3.8	29.2%	91.6	79.6	1.1	13.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F02	5.6	4	1.6	28.6%	41.4	19.9	2.1	52.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F02	9.4	6	3.4	36.2%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W4/F02	29.6	22.8	6.8	23.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W7/F02	12.3	10.8	1.5	12.2%	86.5	84.4	0.2	2.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F02	13.1	10.5	2.6	19.8%	86.7	77.7	0.9	10.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F02	26.5	22.9	3.6	13.6%	99.6	99.6	0.0	0.0%	5	0	5	0	0.0%	0.0%
			KITCHEN-RESI (1)		W12/F02	28.5	28.5	0	0.0%					30	7	30	7	0.0%	0.0%
	R11	RESIDENTIAL	LIVING ROOM		W13/F02	20.9	20.9	0	0.0%	81.1	81.1	0.0	0.0%	16	2	16	2	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W14/F02	16.2	16.2	0	0.0%	93	92.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

45-66 COLLESHILL FLATS (CONTINUED)																			
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	14.6	11.1	3.5	24.0%	93.1	89.1	0.4	4.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F03	7.4	5.9	1.5	20.3%	47.5	30.4	1.7	35.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F03	11.6	8.5	3.1	26.7%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W4/F03	32.1	25.9	6.2	19.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W7/F03	12.9	11.6	1.3	10.1%	87.2	86.6	0.1	0.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F03	13.4	11.1	2.3	17.2%	86.9	82.7	0.4	4.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F03	29.7	26.4	3.3	11.1%	99.8	99.8	0.0	0.0%	5	0	5	0	0.0%	0.0%
			KITCHEN-RESI (1)		W12/F03	30.5	30.5	0	0.0%					31	7	31	7	0.0%	0.0%
	R11	RESIDENTIAL	LIVING ROOM		W13/F03	22.4	22.4	0	0.0%	86.2	86.2	0.0	0.0%	16	2	16	2	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W14/F03	18.7	18.7	0	0.0%	96.4	96.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	17.7	14.4	3.3	18.6%	96	96	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F04	11.4	9.8	1.6	14.0%	67.6	58.8	0.9	13.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F04	16.3	13.6	2.7	16.6%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W4/F04	34.5	29.1	5.4	15.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W7/F04	8.8	7.7	1.1	12.5%	86.9	86.7	0.0	0.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F04	9	7	2	22.2%	86.7	86.2	0.1	0.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F04	32.8	30	2.8	8.5%	99.6	99.6	0.0	0.0%	7	0	6	0	14.3%	0.0%
			KITCHEN-RESI (1)		W12/F04	33	33	0	0.0%					36	8	36	8	0.0%	0.0%
	R11	RESIDENTIAL	LIVING ROOM		W13/F04	24.7	24.7	0	0.0%	87.3	87.3	0.0	0.0%	18	2	18	2	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W14/F04	21.8	21.8	0	0.0%	97.5	97.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	19.1	17.2	1.9	9.9%	98.9	98.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W2/F05	26.2	23.1	3.1	11.8%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W3/F05	30.5	26.1	4.4	14.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	27.4	26.1	1.3	4.7%	98	97.6	0.0	0.4%	10	1	10	1	0.0%	0.0%
			UNKNOWN-RESI		W5/F05	36.3	36.3	0	0.0%					45	10	45	10	0.0%	0.0%
			UNKNOWN-RESI		W6/F05	28.4	28.4	0	0.0%					23	3	23	3	0.0%	0.0%

23-44 COLLESHILL FLATS																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	8.2	8.2	0	0.0%	61.5	61.5	0.0	0.0%	10	1	10	1	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/B01	10.6	10.6	0	0.0%	79.4	79.4	0.0	0.0%	26	3	26	3	0.0%	0.0%
	R3	RESIDENTIAL	BEDROOM		W3/B01	10	10	0	0.0%	74.2	74.2	0.0	0.0%	27	4	27	4	0.0%	0.0%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

23-44 COLLESHILL FLATS (CONTINUED)																			
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W6/B01	20.5	19.4	1.1	5.4%	88.1	88	0.0	0.1%	34	9	34	10	0.0%	-11.1%
			KITCHEN-RESI (1)		W7/B01	5.5	4.8	0.7	12.7%					7	0	6	0	14.3%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W8/B01	7.5	7.4	0.1	1.3%	46.9	46.8	0.0	0.1%	9	0	9	0	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W9/B01	7.7	7.7	0	0.0%	50.1	50.1	0.0	0.0%	14	3	14	3	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W10/B01	5.5	5.5	0	0.0%	89.1	89.1	0.0	0.0%	20	8	20	8	0.0%	0.0%
			KITCHEN-RESI (1)		W11/B01	21.2	19.3	1.9	9.0%					41	14	40	14	2.4%	0.0%
	R10	RESIDENTIAL	BEDROOM		W14/B01	4.2	3.6	0.6	14.3%	28.7	21	0.6	26.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W15/B01	8.3	8.1	0.2	2.4%	63.5	63.4	0.0	0.1%	15	0	15	0	0.0%	0.0%
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	18.1	18.1	0	0.0%	85.5	85.5	0.0	0.0%	44	17	44	17	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F01	22.3	22.3	0	0.0%	91.7	91.7	0.0	0.0%	50	22	50	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F01	26.8	25.5	1.3	4.9%	99.5	99.5	0.0	0.0%	51	17	49	17	3.9%	0.0%
			KITCHEN-RESI (1)		W6/F01	6.7	5.9	0.8	11.9%					13	0	12	0	7.7%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F01	10.1	10	0.1	1.0%	71.7	71.7	0.0	0.0%	14	0	14	0	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F01	10.5	10.5	0	0.0%	70.9	70.9	0.0	0.0%	21	4	21	4	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F01	7	7	0	0.0%	99.3	99.3	0.0	0.0%	23	9	23	9	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F01	26.9	25.1	1.8	6.7%					53	16	52	16	1.9%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F01	5.3	4.7	0.6	11.3%	35.3	29.9	0.4	15.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	10.7	10.5	0.2	1.9%	87.6	87.6	0.0	0.0%	18	1	18	1	0.0%	0.0%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	19.5	19.5	0	0.0%	91.7	91.7	0.0	0.0%	46	17	46	17	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	23.3	23.3	0	0.0%	91.7	91.7	0.0	0.0%	50	22	50	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F02	29.6	28.3	1.3	4.4%	99.8	99.8	0.0	0.0%	59	18	58	18	1.7%	0.0%
			KITCHEN-RESI (1)		W6/F02	6.9	6.2	0.7	10.1%					15	0	14	0	9.7%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F02	11.3	11.2	0.1	0.9%	84.2	84.2	0.0	0.0%	17	0	17	0	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F02	11.5	11.5	0	0.0%	85.2	85.2	0.0	0.0%	22	4	22	4	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F02	7.4	7.4	0	0.0%	99.3	99.3	0.0	0.0%	23	9	23	9	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F02	29.6	27.9	1.7	5.7%					60	17	58	17	3.3%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F02	6.1	5.6	0.5	8.2%	38	35.2	0.2	7.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	12	11.9	0.1	0.8%	90.6	90.6	0.0	0.0%	19	1	19	1	0.0%	0.0%
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	20.9	20.9	0	0.0%	93.9	93.9	0.0	0.0%	45	17	45	17	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F03	24.3	24.3	0	0.0%	91.9	91.9	0.0	0.0%	50	22	50	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F03	31.9	30.7	1.2	3.8%	99.5	99.5	0.0	0.0%	59	17	57	17	3.4%	0.0%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

23-44 COLLESHILL FLATS (CONTINUED)

			KITCHEN-RESI (1)		W6/F03	7.6	6.9	0.7	9.2%					16	0	15	0	6.3%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F03	12	11.9	0.1	0.8%	88.1	88.1	0.0	0.0%	19	1	19	1	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F03	12	12	0	0.0%	87.9	87.9	0.0	0.0%	24	6	24	6	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F03	7.7	7.7	0	0.0%	99.3	99.3	0.0	0.0%	25	10	25	10	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F03	32	30.4	1.6	5.0%					59	17	57	17	3.4%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F03	7.9	7.3	0.6	7.6%	46.1	45.1	0.1	2.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	13.9	13.7	0.2	1.4%	91.8	91.8	0.0	0.0%	20	2	20	2	0.0%	0.0%
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	22.7	22.7	0	0.0%	94.8	94.8	0.0	0.0%	48	18	48	18	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F04	25.2	25.2	0	0.0%	92.3	92.3	0.0	0.0%	49	22	49	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F04	34.2	33	1.2	3.5%	99.5	99.5	0.0	0.0%	62	19	60	19	3.2%	0.0%
			KITCHEN-RESI (1)		W6/F04	5.6	4.9	0.7	12.5%					17	1	16	1	5.9%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F04	5.9	5.8	0.1	1.7%	87.7	87.6	0.0	0.1%	8	2	8	2	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F04	5.8	5.8	0	0.0%	87.5	87.5	0.0	0.0%	8	6	8	6	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F04	5.7	5.7	0	0.0%	99.3	99.3	0.0	0.0%	19	11	19	11	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F04	34.1	32.6	1.5	4.4%					61	20	59	20	3.3%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F04	12.1	11.6	0.5	4.1%	73.3	73.2	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	17.2	17.1	0.1	0.6%	94.7	94.7	0.0	0.0%	23	2	23	2	0.0%	0.0%
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	30.4	30.4	0	0.0%	99.6	99.6	0.0	0.0%	60	24	60	24	0.0%	0.0%
			UNKNOWN-RESI		W2/F05	37.9	37.9	0	0.0%					70	26	70	26	0.0%	0.0%
			UNKNOWN-RESI		W3/F05	33.4	33	0.4	1.2%					66	22	66	22	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	30.9	29.3	1.6	5.2%	98.8	98.8	0.0	0.0%	41	9	41	9	0.0%	0.0%
			UNKNOWN-RESI		W5/F05	27.9	25.7	2.2	7.9%					19	3	18	3	9.3%	0.0%
			UNKNOWN-RESI		W6/F05	21.4	20.4	1	4.7%					20	2	18	2	10.0%	0.0%

01-22 COLLESHILL FLATS

B01	R1	RESIDENTIAL	BEDROOM		W1/B01	6.7	6.7	0	0.0%	50.1	50.1	0.0	0.0%	12	0	12	0	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/B01	3.5	3.5	0	0.0%	26.8	26.8	0.0	0.0%	13	2	13	2	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN-RESI (1)		W5/B01	22.4	18.6	3.8	17.0%	96.8	96.7	0.0	0.0%	48	11	46	11	4.2%	0.0%
			KITCHEN-RESI (1)		W6/B01	6	3.2	2.8	46.7%									83.3%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/B01	10.5	8.7	1.8	17.1%	72.9	67.8	0.5	7.0%	17	0	14	0	17.6%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W8/B01	8.4	8.4	0	0.0%	52.7	52.7	0.0	0.0%	18	0	18	0	0.0%	0.0%

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

01-22 COLLESHILL FLATS (CONTINUED)																			
F01	R7	RESIDENTIAL	KITCHEN-RESI (1)		W9/B01	4.3	4.3	0	0.0%	97.3	96.9	0.0	0.5%	18	3	18	3	0.0%	0.0%
			KITCHEN-RESI (1)		W10/B01	22.6	17.2	5.4	23.9%					46	8	38	8	17.4%	0.0%
	R9	RESIDENTIAL	BEDROOM		W13/B01	6.2	1.3	4.9	79.0%	47.5	7.4	2.9	84.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/B01	7.4	6.4	1	13.5%	80.5	76.5	0.4	4.9%	11	0	9	0	18.2%	0.0%
	R1	RESIDENTIAL	BEDROOM		W1/F01	9.4	9.4	0	0.0%	82.3	82.3	0.0	0.0%	18	3	18	3	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F01	4.9	4.9	0	0.0%	36.6	36.6	0.0	0.0%	18	5	18	5	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F01	27.3	23.5	3.8	13.9%	99.6	99.6	0.0	0.0%	53	13	50	13	5.7%	0.0%
			KITCHEN-RESI (1)		W6/F01	6.9	4.2	2.7	39.1%					15	3	11	3	35.7%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F01	12.4	10.8	1.6	12.9%	87.5	84.7	0.3	3.1%	19	1	17	1	10.5%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F01	11	11	0	0.0%	84.3	84.3	0.0	0.0%	21	3	21	3	0.0%	0.0%
F02	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F01	5.7	5.7	0	0.0%	99.7	99.7	0.0	0.0%	20	6	20	6	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F01	27.4	21.8	5.6	20.4%					54	13	46	13	14.8%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F01	13.9	2	11.9	85.6%	79.3	5.3	5.7	93.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	16.3	8.4	7.9	48.5%	93.8	79.9	1.3	14.9%	19	1	11	1	42.1%	0.0%
	R1	RESIDENTIAL	BEDROOM		W1/F02	10.9	10.9	0	0.0%	90.7	90.7	0.0	0.0%	22	5	22	5	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	5.9	5.9	0	0.0%	38.4	38.4	0.0	0.0%	21	7	21	7	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F02	29.8	26.2	3.6	12.1%	99.6	99.6	0.0	0.0%	56	14	52	14	7.1%	0.0%
			KITCHEN-RESI (1)		W6/F02	7.3	4.7	2.6	35.6%							15		35.4%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F02	13.2	11.8	1.4	10.6%	87.9	87.2	0.1	0.9%	20	2	19	2	5.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F02	12.1	12.1	0	0.0%	87.4	87.4	0.0	0.0%	23	5	23	5	0.0%	0.0%
F03	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F02	6.4	6.4	0	0.0%	99.7	99.7	0.0	0.0%	22	8	22	8	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F02	29.9	24.3	5.6	18.7%					58	16	49	16	15.5%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F02	15.8	2.8	13	82.3%	91.6	9.1	6.3	90.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	17.7	9.5	8.2	46.3%	94	81.8	1.2	13.0%	20	2	14	2	30.0%	0.0%
	R1	RESIDENTIAL	BEDROOM		W1/F03	12.9	12.9	0	0.0%	91.6	91.6	0.0	0.0%	23	5	23	5	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F03	7.7	7.7	0	0.0%	46.4	46.4	0.0	0.0%	24	8	24	8	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F03	32.3	28.9	3.4	10.5%	99.6	99.6	0.0	0.0%	60	18	56	18	6.7%	0.0%
			KITCHEN-RESI (1)		W6/F03	7.7	5.4	2.3	29.9%							15		35.5%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F03	13.5	12.1	1.4	10.4%	88.1	88	0.0	0.2%	20	2	20	2	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F03	12.7	12.7	0	0.0%	87.6	87.6	0.0	0.0%	25	7	25	7	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F03	7.1	7.1	0	0.0%	99.7	99.7	0.0	0.0%	25	10	25	10	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 45

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX. %	PR. %	LOSS	LOSS %	EX. %	PR. %	LOSS SQM	LOSS %	EX.		PR.		LOSS %	
														ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

01-22 COLLESHILL FLATS (CONTINUED)																			
			KITCHEN-RESI (1)		W10/F03	32.3	26.8	5.5	17.0%					60	18	52	18	13.3%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F03	17.9	3.9	14	78.2%	92.2	16.9	5.8	81.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	19.3	11	8.3	43.0%	94.3	83.9	1.0	11.0%	21	3	15	3	28.6%	0.0%
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	16.5	16.5	0	0.0%	94.1	94.1	0.0	0.0%	32	7	32	7	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F04	11.5	11.5	0	0.0%	73.1	73.1	0.0	0.0%	33	11	33	11	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F04	34.3	31.2	3.1	9.0%	99.6	99.6	0.0	0.0%	62	21	58	21	6.5%	0.0%
			KITCHEN-RESI (1)		W6/F04	5.7	3.6	2.1	36.8%					15	5	14	5	33.3%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F04	7	5.8	1.2	17.1%	87.7	84.1	0.3	4.1%	10	3	10	3	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F04	6.5	6.5	0	0.0%	87.1	87.1	0.0	0.0%	11	8	11	8	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F04	5.3	5.3	0	0.0%	99.7	99.7	0.0	0.0%	19	11	19	11	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F04	34.2	29.1	5.1	14.9%					61	20	57	20	6.6%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F04	20.9	6.4	14.5	69.4%	92.5	30.7	4.7	66.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	21.6	13.3	8.3	38.4%	95.2	89.3	0.6	6.2%	26	3	17	3	34.6%	0.0%
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	21.3	21.3	0	0.0%	99.8	99.8	0.0	0.0%	48	17	48	17	0.0%	0.0%
			UNKNOWN-RESI		W2/F05	29.1	29.1	0	0.0%					60	20	60	20	0.0%	0.0%
			UNKNOWN-RESI		W3/F05	33.2	32	1.2	3.6%					67	23	63	23	6.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	30.6	24.7	5.9	19.3%	99.8	98.3	0.1	1.5%	42	10	37	10	11.9%	0.0%
			UNKNOWN-RESI		W5/F05	34.3	14.3	20	58.3%					21	2	15	2	28.6%	0.0%
			UNKNOWN-RESI		W6/F05	27.2	11.5	15.7	57.7%					11	4	14	4	13.3%	0.0%

8 RANELAGH GROVE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	8.9	8.3	0.6	6.7%	43.4	43.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	19.2	18.6	0.6	3.1%	61.9	61.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	14.3	13.7	0.6	4.2%	83.1	83.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.7	26.7	1	3.6%	98.7	98.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	23.9	21.9	2	8.4%	99.8	99.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F02 / INC (2)	83.2	82.1	1.1	1.3%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W3/F02 / INC (2)	84.4	83	1.4	1.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W4/F02	26.2	25.9	0.3	1.1%	98	98	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F02	34.5	32.1	2.4	7.0%					N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2
(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)
(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 46

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES	%	%		%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
6 RANELAGH GROVE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	9.9	9.9	0	0.0%	43	43	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	15.6	13.4	2.2	14.1%	40.4	40.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	15.2	15.2	0	0.0%	80.6	80.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.1	20.9	2.2	9.5%	88.4	88.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	24.7	24.7	0	0.0%	98.6	98.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	28.2	26.7	1.5	5.3%	72.4	72.1	0.0	0.5%	N/A	N/A	N/A	N/A	N/A	N/A
1 EBURY BRIDGE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	24.4	22	2.4	9.8%	92	92	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	24	21.7	2.3	9.6%	92.7	92.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W3/F00	23.6	21.4	2.2	9.3%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F00	23.7	21.8	1.9	8.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W5/F00	22.4	20.7	1.7	7.6%	78.8	77.7	0.7	1.4%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W6/F00	21.8	20.4	1.4	6.4%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F00	21.1	20	1.1	5.2%					N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24	23.8	0.2	0.8%	95.2	95.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F01	27	24.6	2.4	8.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W3/F01	26.4	24.1	2.3	8.7%	97.9	86.5	4.3	11.6%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F01	26.2	24.1	2.1	8.0%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F01	25.4	23.5	1.9	7.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W6/F01	25.1	23.5	1.6	6.4%	74.9	64.4	6.8	14.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F01	24.4	23	1.4	5.7%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W8/F01	24.1	23	1.1	4.6%					N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	25.2	24.9	0.3	1.2%	95.2	95.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F02	28.3	26	2.3	8.1%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W3/F02	28.1	25.9	2.2	7.8%	97.4	67.5	11.4	30.7%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F02	27.7	25.6	2.1	7.6%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F02	27.2	25.4	1.8	6.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W6/F02	26.7	25.2	1.5	5.6%	69.4	49.8	12.7	28.2%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F02	26.3	25	1.3	4.9%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W8/F02	25.9	24.8	1.1	4.2%					N/A	N/A	N/A	N/A	N/A	N/A

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY BRIDGE (CONTINUED)																			
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	24.6	24.4	0.2	0.8%	95.2	95.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F03	27.6	25.4	2.2	8.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W3/F03	27.8	25.7	2.1	7.6%	97.4	88.5	3.4	9.1%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F03	27.3	25.4	1.9	7.0%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F03	26.8	25	1.8	6.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W6/F03	26.4	24.9	1.5	5.7%	78.2	69.2	5.9	11.6%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F03	26	24.7	1.3	5.0%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W8/F03	25.6	24.6	1	3.9%					N/A	N/A	N/A	N/A	N/A	N/A

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY SQUARE-BLOCK A																			
F00	R1	RESIDENTIAL	LIVING ROOM		W1/F00	22.6	22.6	0	0.0%	98.8	98.4	0.2	0.4%	12	1	11	0	9.3%	100.0%
			LIVING ROOM		W2/F00	15.8	15.8	0	0.0%					11	2	10	1	9.1%	50.0%
			LIVING ROOM		W3/F00	16.6	16.5	0.1	0.6%					22	4	21	3	4.5%	25.0%
			LIVING ROOM		W4/F00	24.5	13	11.5	46.9%					49	6	25	0	49.0%	100.0%
	R2	RESIDENTIAL	KITCHEN-DINING		W5/F00	21.4	9.6	11.8	55.1%	90.1	60.2	13.8	33.2%	49	8	19	0	61.2%	100.0%
			KITCHEN-DINING		W6/F00	15.6	9.8	5.8	37.2%					30	8	11	0	63.3%	100.0%
			KITCHEN-DINING		W7/F00	13.6	9.3	4.3	31.6%					26	7	11	0	57.7%	100.0%
	R3	RESIDENTIAL	BEDROOM		W8/F00	10.3	9.1	1.2	11.7%	44.1	44.1	0.0	0.0%	21	6	15	0	28.6%	100.0%
	R4	RESIDENTIAL	BEDROOM		W9/F00	10	9.2	0.8	8.0%	31.5	30.7	0.2	2.4%	19	5	15	1	21.1%	80.0%
	R5	RESIDENTIAL	BEDROOM		W10/F00	10.1	9.9	0.2	2.0%	43.8	43.8	0.0	0.0%	20	5	18	3	10.0%	40.0%
	R6	RESIDENTIAL	BEDROOM		W11/F00	10.3	10.1	0.2	1.9%	35.7	35.7	0.0	0.0%	19	5	17	3	10.5%	40.0%
			BEDROOM		W12/F00	10.5	10.4	0.1	1.0%					18	4	17	3	5.6%	25.0%
	R7	RESIDENTIAL	BEDROOM		W13/F00	13.2	13.1	0.1	0.8%	63.5	63.5	0.0	0.0%	21	4	20	3	4.8%	25.0%
	R8	RESIDENTIAL	BEDROOM		W14/F00	15.1	15.1	0	0.0%	69.4	69.4	0.0	0.0%	25	4	24	3	4.0%	25.0%
F01	R1	RESIDENTIAL	LKD		W1/F01	29.2	29.2	0	0.0%	99.2	99.2	0.0	0.0%	29	5	28	4	3.4%	20.0%
			LKD		W2/F01	29.9	29.8	0.1	0.3%					30	5	29	5	3.3%	16.7%
			LKD		W3/F01	30.5	30.4	0.1	0.3%					28	5	27	4	3.6%	20.0%
			LKD		W4/F01	27.2	16.5	10.7	39.3%					63	13	38	1	39.7%	92.3%
	R2	RESIDENTIAL	BEDROOM		W5/F01	24.3	13	11.3	46.5%	94.3	71.2	6.1	24.5%	57	9	29	0	49.1%	100.0%
			BEDROOM		W6/F01	17.8	11.9	5.9	33.1%					32	8	15	0	53.1%	100.0%
	R3	RESIDENTIAL	BEDROOM		W7/F01	15.8	11.4	4.4	27.8%	71.1	45	4.0	36.7%	29	8	16	0	44.8%	100.0%
	R4	RESIDENTIAL	BEDROOM		W8/F01	12.7	11.1	1.6	12.6%	30.3	30.3	0.0	0.0%	24	7	18	1	25.0%	85.7%
	R5	RESIDENTIAL	BEDROOM		W9/F01	12.3	11.1	1.2	9.8%	23.2	23.2	0.0	0.0%	22	6	17	1	22.7%	83.3%
	R6	RESIDENTIAL	BEDROOM		W10/F01	12	11.2	0.8	6.7%	23.5	23.5	0.0	0.0%	23	6	20	3	13.0%	50.0%
	R7	RESIDENTIAL	BEDROOM		W11/F01	11.9	11.3	0.6	5.0%	31.6	31.6	0.0	0.0%	21	6	19	4	9.5%	33.3%
	R8	RESIDENTIAL	BEDROOM		W12/F01	12.1	11.8	0.3	2.5%	31.4	31.4	0.0	0.0%	22	7	20	5	9.1%	28.6%
	R9	RESIDENTIAL	BEDROOM		W13/F01	12.2	12.1	0.1	0.8%	23.9	23.9	0.0	0.0%	23	7	21	5	8.7%	28.6%
	R10	RESIDENTIAL	BEDROOM		W14/F01	12.5	12.3	0.2	1.6%	23.7	23.7	0.0	0.0%	21	6	20	5	4.8%	16.7%
	R11	RESIDENTIAL	BEDROOM		W15/F01	12.7	12.6	0.1	0.8%	31.9	31.9	0.0	0.0%	22	6	21	5	4.5%	16.7%
	R12	RESIDENTIAL	BEDROOM		W16/F01	15.1	15	0.1	0.7%	59	59	0.0	0.0%	25	6	25	6	0.0%	0.0%
	R13	RESIDENTIAL	BEDROOM		W17/F01	17	16.9	0.1	0.6%	59.7	59.7	0.0	0.0%	28	6	28	6	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY SQUARE-BLOCK A (CONTINUED)																			
F02	R1	RESIDENTIAL	LKD		W1/F02	31.7	31.6	0.1	0.3%	99.2	99.2	0.0	0.0%						
			LKD		W2/F02	32.4	32.3	0.1	0.3%					31	6	30	5	3.2%	16.7%
			LKD		W3/F02	33	32.9	0.1	0.3%					31	6	30	5	3.2%	
			LKD		W4/F02	29.9	20.5	9.4	31.4%					67	15	50	2	25.4%	86.7%
	R2	RESIDENTIAL	BEDROOM		W5/F02	27.3	17.1	10.2	37.4%	94.9	78.6	4.3	17.1%	65	14	44	1	32.3%	92.9%
			BEDROOM		W6/F02	20.4	14.5	5.9	28.9%					37	12	22	0	40.5%	100.0%
	R3	RESIDENTIAL	BEDROOM		W7/F02	18.4	14.1	4.3	23.4%	73.2	51.4	3.3	29.7%	35	13	22	1	37.1%	92.3%
	R4	RESIDENTIAL	BEDROOM		W8/F02	15.2	13.6	1.6	10.5%	34.7	34.7	0.0	0.0%	27	8	23	4	14.8%	50.0%
	R5	RESIDENTIAL	BEDROOM		W9/F02	14.8	13.7	1.1	7.4%	26.5	26.5	0.0	0.0%	28	8	24	4	14.3%	50.0%
	R6	RESIDENTIAL	BEDROOM		W10/F02	14.5	13.7	0.8	5.5%	26.7	26.7	0.0	0.0%	27	8	24	5	11.1%	37.5%
	R7	RESIDENTIAL	BEDROOM		W11/F02	14.4	13.8	0.6	4.2%	36.3	36.3	0.0	0.0%	26	7	24	5	7.7%	28.6%
	R8	RESIDENTIAL	BEDROOM		W12/F02	14.5	14.2	0.3	2.1%	36.3	36.3	0.0	0.0%	26	7	24	5	7.7%	28.6%
	R9	RESIDENTIAL	BEDROOM		W13/F02	14.6	14.4	0.2	1.4%	27.6	27.6	0.0	0.0%	26	7	24	5	7.7%	28.6%
	R10	RESIDENTIAL	BEDROOM		W14/F02	14.9	14.7	0.2	1.3%	27.4	27.4	0.0	0.0%	27	6	27	6	0.0%	0.0%
	R11	RESIDENTIAL	BEDROOM		W15/F02	15.2	15	0.2	1.3%	37.1	37.1	0.0	0.0%	26	6	26	6	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W16/F02	17.4	17.4	0	0.0%	65.8	65.8	0.0	0.0%	31	6	31	6	0.0%	0.0%
	R13	RESIDENTIAL	BEDROOM		W17/F02	19.2	19.2	0	0.0%	66.2	66.2	0.0	0.0%	33	6	33	6	0.0%	0.0%
F03	R1	RESIDENTIAL	LKD		W1/F03	34	34	0	0.0%	99.4	99.2	0.1	0.2%	32	7	31	6	3.1%	14.3%
			LKD		W2/F03	34.7	34.7	0	0.0%							31		1.3%	14.3%
			LKD		W3/F03	35.3	35.3	0	0.0%					32	7	31	6	3.1%	14.3%
			LKD		W4/F03	32.8	26	6.8	20.7%					72	20	60	8	16.7%	60.0%
	R2	RESIDENTIAL	BEDROOM		W5/F03	30.7	22.5	8.2	26.7%	96.1	92.1	1.0	4.1%	68	17	52	2	23.5%	88.2%
			BEDROOM		W6/F03	23.6	17.8	5.8	24.6%					43	16	29	2	32.6%	87.5%
	R3	RESIDENTIAL	BEDROOM		W7/F03	21.6	17.4	4.2	19.4%	78.9	61.5	2.7	22.1%	39	14	28	3	28.2%	78.6%
	R4	RESIDENTIAL	BEDROOM		W8/F03	18.4	16.8	1.6	8.7%	42.9	42.9	0.0	0.0%	34	11	30	7	11.8%	36.4%
	R5	RESIDENTIAL	BEDROOM		W9/F03	17.9	16.8	1.1	6.1%	32.5	32.5	0.0	0.0%	33	10	30	7	9.1%	30.0%
	R6	RESIDENTIAL	BEDROOM		W10/F03	17.6	16.8	0.8	4.5%	32.4	32.4	0.0	0.0%	32	10	29	7	9.4%	30.0%
	R7	RESIDENTIAL	BEDROOM		W11/F03	17.5	16.8	0.7	4.0%	43.9	43.9	0.0	0.0%	32	10	29	7	9.4%	30.0%
	R8	RESIDENTIAL	BEDROOM		W12/F03	17.5	17.2	0.3	1.7%	45.1	45.1	0.0	0.0%	31	8	30	7	3.2%	12.5%
	R9	RESIDENTIAL	BEDROOM		W13/F03	17.7	17.4	0.3	1.7%	34.1	34.1	0.0	0.0%	32	8	31	7	3.1%	12.5%
	R10	RESIDENTIAL	BEDROOM		W14/F03	17.9	17.7	0.2	1.1%	35	35	0.0	0.0%	32	8	31	7	3.1%	12.5%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

v2.02

PAGE 2

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK A (CONTINUED)																			
	R11	RESIDENTIAL	BEDROOM		W15/F03	18.2	18.1	0.1	0.5%	46.5	46.5	0.0	0.0%	31	8	30	7	3.2%	12.5%
	R12	RESIDENTIAL	BEDROOM		W16/F03	20.4	20.3	0.1	0.5%	76.3	76.3	0.0	0.0%	39	8	38	7	2.6%	12.5%
	R13	RESIDENTIAL	BEDROOM		W17/F03	22	21.9	0.1	0.5%	71.1	71.1	0.0	0.0%	41	8	40	7	2.4%	12.5%
F04	R1	RESIDENTIAL	LKD		W3/F04	36.3	32.8	3.5	9.6%	99	99	0.0	0.0%	78	26	71	19	9.0%	26.9%
			LKD		W4/F04	35.7	31.3	4.4	12.3%					77	25	68	16	11.7%	36.0%
			LKD		W5/F04	34.8	29.3	5.5	15.8%					76	24	63	11	17.1%	54.2%
			LKD		W6/F04	28.8	23.6	5.2	18.1%					55	20	45	10	18.2%	50.0%
			LKD		W7/F04	26.7	22.4	4.3	16.1%					54	20	44	10	18.5%	50.0%
	R2	RESIDENTIAL	BEDROOM		W8/F04	24.3	22.6	1.7	7.0%	83.1	82.2	0.2	1.1%	45	13	40	8	11.1%	38.5%
			BEDROOM		W9/F04	24.4	22.8	1.6	6.6%					46	13	42	9	8.7%	30.8%
	R3	RESIDENTIAL	LKD		W1/F04	33.6	33.6	0	0.0%	99.6	99.6	0.0	0.0%	30	7	30	7	0.0%	0.0%
			LKD		W2/F04	34	34	0	0.0%					30	7	30	7	0.0%	0.0%
			LKD		W10/F04	23.9	22.7	1.2	5.0%					48	15	45	12	6.3%	20.0%
			LKD		W11/F04	23	22.1	0.9	3.9%					47	14	44	11	6.4%	21.4%
	R4	RESIDENTIAL	BEDROOM		W12/F04	22.8	22.4	0.4	1.8%	74.1	74.1	0.0	0.0%	39	9	38	8	2.6%	11.1%
			BEDROOM		W13/F04	22.9	22.5	0.4	1.7%					44	10	43	9	2.3%	10.0%
	R5	RESIDENTIAL	BEDROOM		W14/F04	23.6	23.5	0.1	0.4%	84.6	84.6	0.0	0.0%	47	12	46	11	2.1%	8.3%
			BEDROOM		W15/F04	23.4	23.2	0.2	0.9%					48	13	47	12	2.1%	7.7%
	R6	RESIDENTIAL	LKD		W16/F04	25.1	25.1	0	0.0%	98.9	98.9	0.0	0.0%	43	8	43	8	0.0%	0.0%
			LKD		W17/F04	26.9	26.8	0.1	0.4%					53	12	52	11	1.9%	8.3%
			LKD		W18/F04	37.4	37.4	0	0.0%					17	2	17	2	0.0%	0.0%
			LKD		W19/F04	37.8	37.8	0	0.0%					18	2	18	2	0.0%	0.0%
			LKD		W20/F04	38.1	38.1	0	0.0%					20	2	20	2	0.0%	0.0%

1 EBURY SQUARE-BLOCK B																			
F00	R1	RESIDENTIAL	RECEPTION		W1/F00	0.4	0.4	0	0.0%	43.3	41.4	6.5	4.4%	0	0	0	0	0.0%	0.0%
			RECEPTION		W2/F00	0.5	0.5	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W3/F00	0.6	0.6	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W4/F00	0.7	0.7	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W5/F00	0.7	0.7	0	0.0%					0	0	0	0	0.0%	0.0%
			RECEPTION		W15/F00	9.9	9.8	0.1	1.0%					19	7	19	7	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			RECEPTION		W16/F00	11	9.7	1.3	11.8%					24	12	19	7	20.8%	41.7%
	R2	RESIDENTIAL	BEDROOM		W6/F00	0.3	0	0.3	100.0%	29.3	21.1	1.3	28.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W7/F00	0	0	0	-	12.3	12.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4 (3)	RESIDENTIAL	LIVING ROOM		W8/F00	1.3	0.2	1.1	84.6%	33.8	20.9	5.9	38.1%	N/A	N/A	N/A	N/A	N/A	
	R7 (3)	RESIDENTIAL	LIVING ROOM		W12/F00	12.4	10	2.4	19.4%	85.4	84.7	0.5	0.9%	28	6	23	2	17.9%	66.7%
	R8 (3)	RESIDENTIAL	LIVING ROOM		W13/F00	13.5	11.1	2.4	17.8%	97.6	96.1	0.9	1.5%	29	7	25	4	13.8%	42.9%
	R9 (3)	RESIDENTIAL	LIVING ROOM		W14/F00	14.1	12	2.1	14.9%	97.5	97.4	0.0	0.1%	28	9	24	5	14.3%	44.4%
	R10 (3)	RESIDENTIAL	LIVING ROOM		W17/F00	14.1	13.2	0.9	6.4%	99.9	99.9	0.0	0.0%	31	12	27	8	12.9%	33.3%
	R11 (3)	RESIDENTIAL	LIVING ROOM		W18/F00	13.6	13	0.6	4.4%	98.4	98.4	0.0	0.1%	30	12	29	11	3.3%	8.3%
	R12 (3)	RESIDENTIAL	LIVING ROOM		W19/F00	12.9	12.5	0.4	3.1%	96.4	96.3	0.0	0.1%	27	13	26	12	3.7%	7.7%
F01	R1	RESIDENTIAL	LKD		W1/F01	25.3	25.3	0	0.0%	91	91	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F01	22	22	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F01	20.3	20.3	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F01	19.4	19.4	0	0.0%	35.6	35.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F01	18.4	18.3	0.1	0.5%	28.6	28.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F01	17.5	17.5	0	0.0%	35.2	35.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F01	17.2	17.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F01	1.4	1.4	0	0.0%	3.6	3.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F01	1.3	1.3	0	0.0%	3.7	3.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F01	16.8	16.7	0.1	0.6%	34.7	33.6	0.2	3.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F01	16.9	16.7	0.2	1.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F01	17.5	16.9	0.6	3.4%	26.9	26.3	0.2	2.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F01	18	16.9	1.1	6.1%	28.6	27.6	0.3	3.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F01	18.4	16.6	1.8	9.8%	75.1	61	3.3	18.8%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F01	19.4	16.9	2.5	12.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F01	21.5	17.9	3.6	16.7%	95.4	72.2	10.1	24.3%	17	11	4	1	76.5%	81%
			BEDROOM		W17/F01	23.5	7	16.5	70.2%					55	14	12	0	78.2%	100.0%
			BEDROOM		W18/F01	24.7	6.7	18	72.9%					60	16	11	0	81.7%	100.0%
	R14	RESIDENTIAL	BEDROOM		W21/F01	24.2	6	18.2	75.2%	73.7	7.6	12.8	89.7%	55	11	11	1	80.0%	90.9%
	R15	RESIDENTIAL	LKD		W22/F01	22.7	5.9	16.8	74.0%	77.7	77	0.9	0.8%	52	9	11	1	78.8%	88.9%
			LKD		W23/F01	11.3	8.7	2.6	23.0%					24	6	18	2	25.0%	66.7%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			LKD		W24/F01	4.8	0.8	4	83.3%					20	8	10	1	50.0%	87.5%
			LKD		W25/F01	30.2	24.2	6	19.9%					55	11	39	5	29.1%	54.5%
			LKD		W26/F01	30	24.7	5.3	17.7%					54	13	40	5	25.9%	61.5%
			LKD		W27/F01	30.9	26.1	4.8	15.5%					54	13	42	5	22.2%	61.5%
	R16	RESIDENTIAL	BEDROOM		W28/F01	12.6	11.3	1.3	10.3%	57.9	54.9	1.0	5.2%	26	8	23	5	11.5%	37.5%
	R17	RESIDENTIAL	LKD		W29/F01	31.3	27.4	3.9	12.5%	85.2	85	0.2	0.2%	59	19	46	8	22.0%	57.9%
			LKD		W30/F01	31.3	27.8	3.5	11.2%					59	19	49	10	16.9%	47.4%
			LKD		W31/F01	5.1	5.1	0	0.0%					14	1	14	1	0.0%	0.0%
			LKD		W32/F01	13.2	12.5	0.7	5.3%					26	8	25	7	3.8%	12.5%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F01	12.9	12.7	0.2	1.6%	97.2	97.2	0.0	0.0%	27	9	26	8	3.7%	11.1%
	R19	RESIDENTIAL	BEDROOM		W34/F01	30.7	28.5	2.2	7.2%	99.1	99.1	0.0	0.0%	62	22	52	12	16.1%	45.5%
	R21	RESIDENTIAL	LKD		W35/F01	30.4	28.4	2	6.6%	84.5	84.5	0.0	0.0%	62	22	54	14	12.9%	36.4%
			LKD		W36/F01	12.7	12.7	0	0.0%					27	9	27	9	0.0%	0.0%
	R22 (3)	RESIDENTIAL	LKD		W37/F01	29.3	27.8	1.5	5.1%	85.1	85.1	0.0	0.0%	61	21	55	15	9.8%	28.6%
			LKD		W38/F01	27.5	26.4	1.1	4.0%					51	17	49	15	3.9%	11.8%
	R23	RESIDENTIAL	BEDROOM		W39/F01	27.6	26.4	1.2	4.3%	92.9	92.9	0.0	0.0%	55	20	50	15	9.1%	25.0%
			BEDROOM		W40/F01	19	19	0	0.0%					11	3	11	3	0.0%	0.0%
			BEDROOM		W41/F01	11.4	11.4	0	0.0%					22	9	22	9	0.0%	0.0%
F02	R1	RESIDENTIAL	LKD		W1/F02	28.1	28.1	0	0.0%	92.8	92.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F02	25.4	25.4	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F02	24	24	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F02	23.3	23.2	0.1	0.4%	43.4	43.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F02	22.4	22.4	0	0.0%	36.9	36.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F02	21.7	21.7	0	0.0%	49.1	49.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F02	21.5	21.5	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F02	4.1	4.1	0	0.0%	12	12	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F02	4	4	0	0.0%	11.1	11.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F02	21.2	21.1	0.1	0.5%	48.6	48.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F02	21.3	21	0.3	1.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F02	21.7	21.2	0.5	2.3%	35.2	35.2	0.0	0.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F02	22.1	21.2	0.9	4.1%	35.8	35.8	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R10	RESIDENTIAL	BEDROOM		W14/F02	22.5	21	1.5	6.7%	84	76.8	1.7	8.6%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F02	23.4	21.3	2.1	9.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F02	25.1	22	3.1	12.4%	96.6	76.1	8.9	21.2%	18	0	8	0	55.6%	0.0%
			BEDROOM		W17/F02	26.4	9.3	17.1	64.8%					62	16	20	1	67.7%	93.8%
			BEDROOM		W18/F02	27.5	8.7	18.8	68.4%					66	17	18	1	72.7%	94.1%
	R14	RESIDENTIAL	BEDROOM		W21/F02	27.2	7.8	19.4	71.3%	77.7	10.7	13.0	86.2%	64	15	15	1	76.6%	93.3%
	R15	RESIDENTIAL	LKD		W22/F02	26	7.5	18.5	71.2%	84.4	83.3	1.5	1.3%	64	14	13	1	79.7%	92.9%
			LKD		W23/F02	12.6	9.4	3.2	25.4%					26	8	20	3	23.1%	62.5%
			LKD		W24/F02	6	1	5	83.3%					23	11	10	1	56.5%	90.9%
			LKD		W25/F02	32.3	25.7	6.6	20.4%					60	16	41	6	31.7%	62.5%
			LKD		W26/F02	31.2	25.3	5.9	18.9%					57	18	41	6	28.1%	66.7%
			LKD		W27/F02	32.8	27.5	5.3	16.2%					61	19	47	8	23.0%	57.9%
	R16	RESIDENTIAL	BEDROOM		W28/F02	13.6	12.1	1.5	11.0%	63.5	60.7	0.9	4.4%	27	9	24	6	11.1%	33.3%
	R17	RESIDENTIAL	LKD		W29/F02	33	28.9	4.1	12.4%	91.8	91.3	0.4	0.4%	63	21	51	10	19.0%	52.4%
			LKD		W30/F02	32.9	29.3	3.6	10.9%					63	22	52	11	17.5%	50.0%
			LKD		W31/F02	5.6	5.6	0	0.0%					15	5	15	5	0.0%	0.0%
			LKD		W32/F02	14.1	13.4	0.7	5.0%					27	9	26	8	3.7%	11.1%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F02	13.8	13.6	0.2	1.4%	97.4	97.4	0.0	0.0%	27	9	26	8	3.7%	11.1%
	R19	RESIDENTIAL	BEDROOM		W34/F02	32.2	30	2.2	6.8%	99.2	99.2	0.0	0.0%	62	22	54	14	12.9%	36.4%
	R20	RESIDENTIAL	LKD		W35/F02	31.9	29.9	2	6.3%	87.3	87.2	0.0	0.0%	62	22	55	15	11.3%	31.8%
			LKD		W36/F02	13.6	13.6	0	0.0%					27	9	27	9	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F02	30.8	29.2	1.6	5.2%	92.9	92.7	0.1	0.2%	62	22	57	17	8.1%	22.7%
			LKD		W38/F02	27.6	26.5	1.1	4.0%					51	17	49	15	3.9%	11.8%
	R22	RESIDENTIAL	BEDROOM		W39/F02	29.1	27.9	1.2	4.1%	93.2	93.2	0.0	0.0%	57	20	52	15	8.8%	25.0%
			BEDROOM		W40/F02	2.3	2.3	0	0.0%					12	2	12	2	0.0%	0.0%
			BEDROOM		W41/F02	12.1	12.1	0	0.0%					22	9	22	9	0.0%	0.0%
F03	R1	RESIDENTIAL	LKD		W1/F03	31.6	31.6	0	0.0%	97	97	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F03	29.5	29.5	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F03	28.5	28.5	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F03	28.1	28.1	0	0.0%	64.9	64.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F03	27.5	27.4	0.1	0.4%	56.5	56.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R4	RESIDENTIAL	BEDROOM		W6/F03	26.8	26.8	0	0.0%	78.4	78.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F03	26.6	26.6	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F03	7.2	7.2	0	0.0%	29.5	29.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F03	7.2	7.2	0	0.0%	28.7	28.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F03	26.4	26.3	0.1	0.4%	79.1	79.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F03	26.5	26.3	0.2	0.8%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F03	27	26.6	0.4	1.5%	55.5	55.5	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F03	27.3	26.5	0.8	2.9%	54.6	54.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F03	27.4	26.3	1.1	4.0%	94.2	94.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F03	28.1	26.5	1.6	5.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F03	29.6	26.9	2.7	9.1%	96.7	79.6	7.5	17.7%	63	16	16	3	30.4%	100.0%
			BEDROOM		W17/F03	29.6	12.5	17.1	57.8%					66	17	29	1	56.1%	94.1%
			BEDROOM		W18/F03	30.6	11.7	18.9	61.8%					69	19	27	1	60.9%	94.7%
	R14	RESIDENTIAL	BEDROOM		W21/F03	30.5	10.1	20.4	66.9%	82.5	15	13.1	81.8%	68	18	20	1	70.6%	94.4%
	R15	RESIDENTIAL	LKD		W22/F03	29.5	9.7	19.8	67.1%	90.6	89.8	1.0	0.8%	69	18	19	1	72.5%	94.4%
			LKD		W23/F03	13.8	10.1	3.7	26.8%					27	9	20	3	25.9%	66.7%
			LKD		W24/F03	7.2	1.2	6	83.3%					25	13	10	1	60.0%	92.3%
			LKD		W25/F03	34.3	27.1	7.2	21.0%					64	20	45	6	29.7%	70.0%
			LKD		W26/F03	33.7	27.5	6.2	18.4%					60	18	45	6	25.0%	66.7%
			LKD		W27/F03	34.5	29	5.5	15.9%					61	19	47	7	23.0%	63.2%
	R16	RESIDENTIAL	BEDROOM		W28/F03	14.4	13	1.4	9.7%	69.4	66.8	0.9	3.8%	27	9	25	7	7.4%	22.2%
	R17	RESIDENTIAL	LKD		W29/F03	34.5	30.5	4	11.6%	93.4	92.1	1.2	1.4%	66	23	55	12	16.7%	47.8%
			LKD		W30/F03	34.4	30.8	3.6	10.5%					65	23	55	13	15.4%	43.5%
			LKD		W31/F03	6.2	6.2	0	0.0%					17	2	17	2	0.0%	0.0%
			LKD		W32/F03	14.9	14.2	0.7	4.7%					28	10	27	9	3.6%	10.0%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F03	14.6	14.4	0.2	1.4%	97.5	97.5	0.0	0.0%	28	10	27	9	3.6%	10.0%
	R19	RESIDENTIAL	BEDROOM		W34/F03	33.6	31.4	2.2	6.5%	99.2	99.2	0.0	0.0%	63	23	56	16	11.1%	30.4%
	R20	RESIDENTIAL	LKD		W35/F03	33.3	31.4	1.9	5.7%	88.4	88.4	0.0	0.0%	63	23	57	17	9.5%	26.1%
			LKD		W36/F03	14.4	14.4	0	0.0%					28	10	28	10	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F03	32.1	30.6	1.5	4.7%	95.5	95.5	0.0	0.0%	63	23	58	18	7.9%	21.7%
			LKD		W38/F03	30.2	29.2	1	3.3%					53	18	51	16	3.8%	11.1%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R22	RESIDENTIAL	BEDROOM		W39/F03	30.4	29.3	1.1	3.6%	93.3	93.3	0.0	0.0%	58	21	55	18	5.2%	14.3%
			BEDROOM		W40/F03	2.7	2.7	0	0.0%					14	2	14	2	0.0%	0.0%
			BEDROOM		W41/F03	12.8	12.8	0	0.0%					25	10	25	10	0.0%	0.0%
F04	R1	RESIDENTIAL	LKD		W1/F04	35.1	35.1	0	0.0%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F04	33.9	33.9	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F04	33.3	33.3	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F04	33.2	33.2	0	0.0%	99.6	99.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F04	32.8	32.8	0	0.0%	82.1	82.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F04	32.2	32.2	0	0.0%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F04	32.1	32.1	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F04	10.5	10.5	0	0.0%	66.1	66.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F04	10.5	10.5	0	0.0%	65.6	65.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F04	32	31.8	0.2	0.6%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F04	32	31.8	0.2	0.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F04	32.5	32.1	0.4	1.2%	89.4	89.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F04	32.7	32.1	0.6	1.8%	90.2	90.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F04	32.6	31.8	0.8	2.5%	99	98.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F04	33	31.8	1.2	3.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F04	33.9	32	1.9	5.6%	98	87.2	4.7	11.0%	26	2	21	0	18.2%	100.0%
			BEDROOM		W17/F04	33	17	16	48.5%					72	21	41	2	43.1%	90.5%
			BEDROOM		W18/F04	33.7	15.7	18	53.4%					75	23	39	1	48.0%	95.7%
	R14	RESIDENTIAL	BEDROOM		W21/F04	33.6	13	20.6	61.3%	95.8	20.7	14.6	78.4%	73	22	29	1	60.3%	95.5%
	R15	RESIDENTIAL	LKD		W22/F04	33	12.7	20.3	61.5%	92.7	90.8	2.5	1.9%	72	21	29	1	59.7%	95.2%
			LKD		W23/F04	14.7	10.9	3.8	25.9%					27	9	20	3	25.9%	66.7%
			LKD		W24/F04	8.1	1.4	6.7	82.7%					26	14	12	2	53.8%	85.7%
			LKD		W25/F04	36	28.7	7.3	20.3%					65	21	48	7	26.2%	66.7%
			LKD		W26/F04	34.4	28.3	6.1	17.7%					59	20	44	7	25.4%	65.0%
			LKD		W27/F04	36	30.7	5.3	14.7%					66	22	52	9	21.2%	59.1%
	R16	RESIDENTIAL	BEDROOM		W28/F04	15.2	13.8	1.4	9.2%	72.7	70.5	0.8	3.1%	28	10	26	8	7.1%	20.0%
	R17	RESIDENTIAL	LKD		W29/F04	35.9	32	3.9	10.9%	94.4	92.4	1.8	2.1%	66	23	55	12	16.7%	47.8%
			LKD		W30/F04	35.8	32.3	3.5	9.8%					66	23	57	14	13.6%	39.1%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			LKD		W31/F04	6.7	6.7	0	0.0%					18	8	18	8	0.0%	0.0%
			LKD		W32/F04	15.7	15.1	0.6	3.8%					28	10	27	9	3.6%	10.0%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F04	15.3	15.2	0.1	0.7%	97.6	97.6	0.0	0.0%	28	10	27	9	3.6%	10.0%
	R19	RESIDENTIAL	BEDROOM		W34/F04	35	32.9	2.1	6.0%	99.2	99.2	0.0	0.0%	65	23	59	17	9.2%	26.1%
	R20	RESIDENTIAL	LKD		W35/F04	34.7	32.8	1.9	5.5%	90.2	90.2	0.0	0.0%	64	23	58	17	9.4%	26.1%
			LKD		W36/F04	15.2	15.2	0	0.0%					28	10	28	10	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F04	33.7	32.3	1.4	4.2%	96	95.9	0.0	0.0%	63	23	60	20	4.8%	13.0%
			LKD		W38/F04	30.2	29.3	0.9	3.0%					52	18	51	17	1.9%	5.6%
	R22	RESIDENTIAL	BEDROOM		W39/F04	32	31	1	3.1%	93.4	93.4	0.0	0.0%	62	22	59	19	4.8%	13.6%
			BEDROOM		W40/F04	3.3	3.3	0	0.0%					15	2	15	2	0.0%	0.0%
			BEDROOM		W41/F04	13.6	13.6	0	0.0%					26	10	26	10	0.0%	0.0%
F05	R1	RESIDENTIAL	LKD		W1/F05	37.1	37	0.1	0.3%	99.5	99.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W2/F05	36	36	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			LKD		W3/F05	35.8	35.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W4/F05	36.5	36.5	0	0.0%	99.8	99.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F05	36.3	36.3	0	0.0%	89.4	89.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W6/F05	35.4	35.4	0	0.0%	99.6	99.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F05	35.2	35.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	LKD		W8/F05	12.6	12.6	0	0.0%	87.4	87.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LKD		W9/F05	12.6	12.6	0	0.0%	86.6	86.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F05	35.4	35.3	0.1	0.3%	99.5	99.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F05	35.2	35.1	0.1	0.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R8	RESIDENTIAL	BEDROOM		W12/F05	36.3	36.1	0.2	0.6%	95.6	95.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/F05	36.2	35.9	0.3	0.8%	96.8	96.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/F05	35.6	35.3	0.3	0.8%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W15/F05	35.7	35	0.7	2.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W16/F05	36.7	35.6	1.1	3.0%	98	91.1	3.0	7.1%	54	8	25	1	9.3%	66.7%
			BEDROOM		W17/F05	36.2	21.7	14.5	40.1%					77	26	54	5	29.9%	80.8%
			BEDROOM		W18/F05	36.5	20.1	16.4	44.9%					78	26	49	2	37.2%	92.3%
	R14	RESIDENTIAL	BEDROOM		W21/F05	36.5	16.1	20.4	55.9%	96.4	28.5	13.2	70.4%	79	27	41	2	48.1%	92.6%
	R15	RESIDENTIAL	LKD		W22/F05	36.1	16.1	20	55.4%	94.5	91.6	3.8	3.0%	79	27	39	5	50.6%	81.5%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY SQUARE-BLOCK B (CONTINUED)																			
			LKD		W23/F05	18.1	14.2	3.9	21.5%					32	10	25	4	21.9%	60.0%
			LKD		W24/F05	8.8	2	6.8	77.3%					31	16	17	3	45.2%	81.3%
			LKD		W25/F05	35.6	28.6	7	19.7%					63	22	47	8	25.4%	63.6%
			LKD		W26/F05	36.4	30.6	5.8	15.9%					62	21	49	8	21.0%	61.9%
			LKD		W27/F05	35.5	30.5	5	14.1%					63	22	52	11	17.5%	50.0%
	R16	RESIDENTIAL	BEDROOM		W28/F05	18.6	17.3	1.3	7.0%	73.5	72.2	0.5	1.8%	32	10	30	8	6.3%	20.0%
	R17	RESIDENTIAL	LKD		W29/F05	35.3	31.7	3.6	10.2%	95	93.4	1.5	1.8%	63	22	54	13	14.3%	40.9%
			LKD		W30/F05	35	32.2	2.8	8.0%					57	18	51	12	10.5%	33.3%
			LKD		W31/F05	7.6	7.6	0	0.0%					19	2	19	2	0.0%	0.0%
			LKD		W32/F05	19.2	18.3	0.9	4.7%					33	12	31	10	6.1%	16.7%
	R18 (3)	RESIDENTIAL	BEDROOM		W33/F05	18.7	18.6	0.1	0.5%	97.8	97.8	0.0	0.0%	33	10	33	10	0.0%	0.0%
	R19	RESIDENTIAL	BEDROOM		W34/F05	34.5	32.6	1.9	5.5%	98.6	98.6	0.0	0.0%	62	22	56	16	9.7%	27.3%
	R20	RESIDENTIAL	LKD		W35/F05	33.9	32.6	1.3	3.8%	90.4	90.4	0.0	0.0%	56	18	54	16	3.6%	11.1%
			LKD		W36/F05	18.9	18.8	0.1	0.5%					34	12	34	12	0.0%	0.0%
	R21 (3)	RESIDENTIAL	LKD		W37/F05	32.9	32	0.9	2.7%	96.6	96.6	0.0	0.0%	53	18	52	17	1.9%	5.6%
			LKD		W38/F05	33.6	32.4	1.2	3.6%					59	22	56	19	5.1%	13.6%
	R22	RESIDENTIAL	BEDROOM		W39/F05	31.5	30.9	0.6	1.9%	93.3	93.3	0.0	0.0%	53	18	52	17	1.9%	5.6%
			BEDROOM		W40/F05	4.4	4.4	0	0.0%					15	2	15	2	0.0%	0.0%
			BEDROOM		W41/F05	17.4	17.4	0	0.0%					32	12	32	12	0.0%	0.0%
F06	R1	RESIDENTIAL	BEDROOM		W1/F06	34.6	34.6	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W2/F06	38.8	38.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2 (3)	RESIDENTIAL	BEDROOM		W3/F06	38.7	38.7	0	0.0%	97.6	97.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	BEDROOM		W5/F06	25.7	25.7	0	0.0%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W6/F06	30.8	30.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F06	25	25	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R5 (3)	RESIDENTIAL	BEDROOM		W8/F06	38	38	0	0.0%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6 (3)	RESIDENTIAL	BEDROOM		W9/F06	38	38	0	0.0%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W10/F06	24.2	24.1	0.1	0.4%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F06	31.2	31.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W12/F06	25.9	25.9	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R9 (3)	RESIDENTIAL	BEDROOM		W14/F06	38.7	38.4	0.3	0.8%	98	98	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
1 EBURY SQUARE-BLOCK B (CONTINUED)																			
	R10	RESIDENTIAL	BEDROOM		W15/F06	38.9	38.4	0.5	1.3%	100	100	0.0	0.0%	75	28	30	9	1.3%	25.0%
			BEDROOM		W16/F06	38.9	28.5	10.4	26.7%					79	28	65	14	17.7%	50.0%
	R11	RESIDENTIAL	LKD		W17/F06	37.5	25	12.5	33.3%	100	100	0.0	0.0%	67	25	49	7	26.9%	72.0%
			LKD		W18/F06	38.9	23.9	15	38.6%					80	28	59	8	26.3%	71.4%
			LKD		W19/F06	38	32.4	5.6	14.7%					67	23	58	14	13.4%	39.1%
	R12	RESIDENTIAL	BEDROOM		W20/F06	37.9	33.3	4.6	12.1%	85.3	85.2	0.0	0.1%	67	23	60	16	10.4%	30.4%
			BEDROOM		W21/F06	37.8	34	3.8	10.1%					67	23	60	16	10.4%	30.4%
	R13	RESIDENTIAL	BEDROOM		W22/F06	28.7	28.2	0.5	1.7%	100	100	0.0	0.0%	37	9	36	8	2.7%	11.1%
			BEDROOM		W23/F06	33.8	31	2.8	8.3%					52	16	47	11	9.6%	31.3%
			BEDROOM		W24/F06	27.1	24.2	2.9	10.7%					55	20	50	15	9.1%	25.0%
	R14	RESIDENTIAL	LKD		W25/F06	36.3	35	1.3	3.6%	94.2	94.2	0.0	0.0%	64	20	61	17	4.7%	15.0%
	R15	RESIDENTIAL	LKD		W26/F06	37	35.1	1.9	5.1%	94.2	94.2	0.0	0.0%	67	23	64	20	4.5%	13.0%
	R16	RESIDENTIAL	BEDROOM		W27/F06	25.1	25.1	0	0.0%	99.2	99.2	0.0	0.0%	32	5	32	5	0.0%	0.0%
			BEDROOM		W28/F06	31.6	31.5	0.1	0.3%					48	15	47	14	2.1%	6.7%
			BEDROOM		W29/F06	27.9	27.1	0.8	2.9%					55	19	52	16	5.5%	15.8%
	R17	RESIDENTIAL	BEDROOM		W30/F06	36.1	34.9	1.2	3.3%	85.8	85.8	0.0	0.0%	64	23	62	21	3.1%	8.7%
			BEDROOM		W31/F06	35.8	34.7	1.1	3.1%					63	23	61	21	3.2%	8.7%
	R18	RESIDENTIAL	LKD		W32/F06	35	34.1	0.9	2.6%	100	100	0.0	0.0%	63	23	62	22	1.6%	4.3%
			LKD		W33/F06	29.9	29.9	0	0.0%					15	5	15	5	0.0%	0.0%
			LKD		W34/F06	32.1	32.1	0	0.0%					9	0	9	0	0.0%	0.0%
F07	R1	RESIDENTIAL	BEDROOM		W1/F07	34.3	34.3	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W2/F07	13.8	13.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W3/F07	7.2	7.2	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W4/F07	39.2	39.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	BEDROOM		W5/F07	25.9	25.9	0	0.0%	99.1	99.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W6/F07	31.8	31.8	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W7/F07	26.1	26.1	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R4 (3)	RESIDENTIAL	BEDROOM		W8/F07	39.2	39.1	0.1	0.3%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R5 (3)	RESIDENTIAL	BEDROOM		W9/F07	39.2	39.2	0	0.0%	87.1	87.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W10/F07	25	25	0	0.0%	100	100	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W11/F07	31.4	31.4	0	0.0%						N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

1 EBURY SQUARE-BLOCK B (CONTINUED)

			BEDROOM		W12/F07	26.2	26.2	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W13/F07	39.2	39.1	0.1	0.3%	100	100	0.0	0.0%	31	3	31	3	0.0%	0.0%
			BEDROOM		W14/F07	7.2	6.8	0.4	5.6%					14	4	14	4	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W15/F07	13.8	13.7	0.1	0.7%	100	100	0.0	0.0%	11	3	10	3	0.0%	0.0%
			BEDROOM		W16/F07	37.1	30.2	6.9	18.6%					72	26	64	18	11.1%	30.8%
	R9	RESIDENTIAL	LKD		W17/F07	37.5	28.7	8.8	23.5%	100	100	0.0	0.0%	70	25	60	15	14.3%	40.0%
			LKD		W18/F07	37.9	27.2	10.7	28.2%					73	27	62	16	15.1%	40.7%
			LKD		W19/F07	13.7	10.2	3.5	25.5%					19	12	14	7	26.3%	41.7%
	R10	RESIDENTIAL	BEDROOM		W20/F07	7.1	2	5.1	71.8%	87.7	86.8	0.4	1.1%	14	12	7	5	50.0%	58.3%
			BEDROOM		W21/F07	38.4	35	3.4	8.9%					67	23	61	17	9.0%	26.1%
	R11	RESIDENTIAL	BEDROOM		W22/F07	30	29.6	0.4	1.3%	100	100	0.0	0.0%	37	9	37	9	0.0%	0.0%
			BEDROOM		W23/F07	35.8	33.5	2.3	6.4%					58	16	54	12	6.9%	25.0%
			BEDROOM		W24/F07	29.7	27.3	2.4	8.1%					60	21	57	18	5.0%	14.3%
	R12	RESIDENTIAL	LKD		W25/F07	38.4	36.4	2	5.2%	94.4	94.4	0.0	0.0%	67	23	64	20	4.5%	13.0%
	R13	RESIDENTIAL	LKD		W26/F07	38.1	36.6	1.5	3.9%	94.4	94.4	0.0	0.0%	67	23	65	21	3.0%	8.7%
	R14	RESIDENTIAL	BEDROOM		W27/F07	27.9	27.9	0	0.0%	99.2	99.2	0.0	0.0%	33	6	33	6	0.0%	0.0%
			BEDROOM		W28/F07	34.7	34	0.7	2.0%					56	15	56	15	0.0%	0.0%
			BEDROOM		W29/F07	29.6	28.6	1	3.4%					59	20	58	19	1.7%	5.0%
	R15	RESIDENTIAL	BEDROOM		W30/F07	37.2	36.3	0.9	2.4%	86.9	86.9	0.0	0.0%	65	23	64	22	1.5%	4.3%
			BEDROOM		W31/F07	3.1	3.1	0	0.0%					3	0	3	0	0.0%	0.0%
	R16	RESIDENTIAL	LKD		W32/F07	11.7	11.7	0	0.0%	100	100	0.0	0.0%	15	8	15	8	0.0%	0.0%
			LKD		W33/F07	32.1	32.1	0	0.0%					15	3	15	3	0.0%	0.0%
			LKD		W34/F07	34.3	34.3	0	0.0%					14	0	14	0	0.0%	0.0%

11 PIMLICO ROAD

F02	R1	RESIDENTIAL	LIVING ROOM		W1/F02	29.4	22	7.4	25.2%	99.2	99	0.1	0.2%	N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W2/F02	29.6	21.8	7.8	26.4%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W3/F02	29.6	21.7	7.9	26.7%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W4/F02	29.7	21.5	8.2	27.6%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W5/F02	29.6	21.1	8.5	28.7%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W6/F02	29.9	14.2	15.7	52.5%					N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
11 PIMLICO ROAD (CONTINUED)																			
			LIVING ROOM		W7/F02	30.2	14.4	15.8	52.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W8/F02	30.3	14.5	15.8	52.1%	74	26.8	5.2	63.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	BEDROOM		W9/F02	30.3	14.6	15.7	51.8%	82.1	19.8	13.0	75.9%	N/A	N/A	N/A	N/A	N/A	N/A
			BEDROOM		W10/F02	30.3	14.7	15.6	51.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	LIVING ROOM		W11/F02	29.9	14.5	15.4	51.5%	92.5	37.1	19.8	59.9%	N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W12/F02	30.3	15.5	14.8	48.8%					N/A	N/A	N/A	N/A	N/A	N/A
			LIVING ROOM		W13/F02	30.2	17.6	12.6	41.7%					N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN-RESI		W1/F03	32.3	23.9	8.4	26.0%	84.6	74.3	2.8	12.1%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W2/F03	32.4	23.7	8.7	26.9%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W3/F03	32.5	23.5	9	27.7%					N/A	N/A	N/A	N/A	N/A	N/A
KILMUIR HOUSE																			
F00	R2	RESIDENTIAL	BEDROOM		W7/F00	20	19.8	0.2	1.0%	38.9	38.8	0.0	0.2%	30	6	28	4	6.7%	33.3%
	R3	RESIDENTIAL	BEDROOM		W8/F00	21.3	21.2	0.1	0.5%	39.8	39.8	0.0	0.0%	37	9	37	9	0.0%	0.0%
	R4	RESIDENTIAL	LIVING ROOM		W9/F00	15	14.9	0.1	0.7%	30.2	30.2	0.0	0.1%	39	10	38	9	2.6%	10.0%
	R5 (3)	RESIDENTIAL	LIVING ROOM		W10/F00	11.2	11.1	0.1	0.9%	32.7	32.7	0.0	0.0%	21	7	20	6	4.8%	14.3%
	R6	RESIDENTIAL	BEDROOM		W11/F00	21.2	21.1	0.1	0.5%	38.6	38.4	0.0	0.5%	32	5	31	4	3.1%	20.0%
	R7	RESIDENTIAL	BEDROOM		W12/F00	23.1	23	0.1	0.4%	37.3	37.3	0.0	0.0%	40	8	39	7	2.5%	12.5%
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	29.4	28.8	0.6	2.0%	92.4	92	0.0	0.5%	66	16	65	15	1.5%	6.3%
	R2	RESIDENTIAL	BEDROOM		W2/F01	24.3	24	0.3	1.2%	50.5	46.5	0.5	8.0%	51	14	51	14	0.0%	0.0%
	R3 (3)	RESIDENTIAL	LIVING ROOM		W3/F01	18.1	17.8	0.3	1.7%	39.9	35.7	0.7	10.7%	50	14	50	14	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F01	22.3	22.1	0.2	0.9%	44.9	44.8	0.0	0.1%	35	7	35	7	0.0%	0.0%
	R5	RESIDENTIAL	BEDROOM		W5/F01	22.6	22.5	0.1	0.4%	45.5	45.5	0.0	0.0%	43	11	43	11	0.0%	0.0%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F01	13.3	13.2	0.1	0.8%	34.6	33.9	0.1	2.1%	30	12	30	12	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F01	17.5	17.4	0.1	0.6%	39	39	0.0	0.0%	28	9	28	9	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F01	24.4	24.3	0.1	0.4%	47	47	0.0	0.0%	42	9	42	9	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F01	25.3	25.3	0	0.0%	46.2	46.2	0.0	0.0%	48	12	48	12	0.0%	0.0%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	32.3	31.7	0.6	1.9%	86.8	80.4	0.9	7.3%	71	20	70	19	1.4%	5.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	27	26.5	0.5	1.9%	61.2	58.1	0.4	5.2%	57	17	55	15	3.5%	11.8%
	R3	RESIDENTIAL	LKD		W3/F02	20.7	20.4	0.3	1.4%	77.7	75.8	0.5	2.4%	54	14	54	14	0.0%	0.0%
			LKD		W10/F02	22.4	22.4	0	0.0%					29	5	29	5	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
KILMUIR HOUSE (CONTINUED)																			
	R4	RESIDENTIAL	BEDROOM		W4/F02	24.9	24.6	0.3	1.2%	57.3	57.3	0.0	0.0%	40	9	39	8	2.5%	11.1%
	R5	RESIDENTIAL	BEDROOM		W5/F02	26.1	26	0.1	0.4%	58	58	0.0	0.0%	48	13	47	12	2.1%	7.7%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F02	19.9	19.8	0.1	0.5%	43.3	42.9	0.1	0.9%	50	12	50	12	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F02	16.1	16	0.1	0.6%	45	45	0.0	0.1%	32	9	32	9	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F02	25.9	25.8	0.1	0.4%	58.4	58.4	0.0	0.0%	42	8	42	8	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F02	27.6	27.6	0	0.0%	57.7	57.7	0.0	0.0%	51	12	51	12	0.0%	0.0%
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	35	34.3	0.7	2.0%	90.8	84.4	0.9	7.1%	77	25	75	23	2.6%	8.0%
	R2	RESIDENTIAL	BEDROOM		W2/F03	29.5	28.8	0.7	2.4%	77	75.8	0.1	1.6%	62	19	59	16	4.8%	15.8%
	R3	RESIDENTIAL	LKD		W3/F03	23.2	22.7	0.5	2.2%	80.2	80.2	0.0	0.0%	60	18	58	16	3.3%	11.1%
			LKD		W10/F03	24.1	24.1	0	0.0%					31	6	31	6	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F03	27.5	27.1	0.4	1.5%	74.8	74.8	0.0	0.0%	44	10	43	9	2.3%	10.0%
	R5	RESIDENTIAL	BEDROOM		W5/F03	27.8	27.4	0.4	1.4%	75.7	75.7	0.0	0.0%	52	14	51	13	1.9%	7.1%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F03	18.4	18.1	0.3	1.6%	54.1	52.3	0.3	3.4%	38	14	38	14	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F03	22.4	22.2	0.2	0.9%	58.2	58.2	0.0	0.0%	35	11	35	11	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F03	29.3	29.1	0.2	0.7%	75.9	75.9	0.0	0.0%	50	12	49	11	2.0%	8.3%
	R9	RESIDENTIAL	BEDROOM		W9/F03	30.1	29.9	0.2	0.7%	75	75	0.0	0.0%	55	15	54	14	1.8%	6.7%
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	36.9	36.1	0.8	2.2%	91.9	86.9	0.7	5.4%	79	27	77	25	2.5%	7.4%
	R2	RESIDENTIAL	BEDROOM		W2/F04	31.7	30.8	0.9	2.8%	95.4	94	0.2	1.5%	64	20	61	17	4.7%	15.0%
	R3	RESIDENTIAL	LKD		W3/F04	25.7	25	0.7	2.7%	84	84	0.0	0.0%	64	20	61	17	4.7%	15.0%
			LKD		W10/F04	25.7	25.7	0	0.0%					32	7	32	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F04	29.8	29.1	0.7	2.3%	90.9	90.2	0.1	0.7%	48	13	46	11	4.2%	15.4%
	R5	RESIDENTIAL	BEDROOM		W5/F04	31	30.4	0.6	1.9%	93.1	92.7	0.0	0.4%	56	17	54	15	3.6%	11.8%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F04	24.9	24.4	0.5	2.0%	73.4	70.6	0.5	3.8%	61	18	59	16	3.3%	11.1%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F04	20.9	20.5	0.4	1.9%	72.9	72.7	0.0	0.3%	42	15	40	13	4.8%	13.3%
	R8	RESIDENTIAL	BEDROOM		W8/F04	30.6	30.1	0.5	1.6%	94.1	94	0.0	0.1%	50	13	48	11	4.0%	15.4%
	R9	RESIDENTIAL	BEDROOM		W9/F04	32.1	31.7	0.4	1.2%	92.7	92.7	0.0	0.0%	58	17	57	16	1.7%	5.9%
F05	R1	RESIDENTIAL	BEDROOM		W1/F05	38	37	1	2.6%	92.3	90.5	0.3	1.9%	79	27	78	26	1.3%	3.7%
	R2	RESIDENTIAL	BEDROOM		W2/F05	33.4	32.1	1.3	3.9%	99.5	99.5	0.0	0.0%	66	21	64	19	3.0%	9.5%
	R3	RESIDENTIAL	LKD		W3/F05	27.3	26.2	1.1	4.0%	89.4	89.1	0.1	0.3%	65	21	64	20	1.5%	4.8%
			LKD		W10/F05	26.8	26.8	0	0.0%					31	7	31	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F05	31.3	30.3	1	3.2%	98.4	98.4	0.0	0.0%	50	14	49	13	2.0%	7.1%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
KILMUJR HOUSE (CONTINUED)																			
	R5	RESIDENTIAL	BEDROOM		W5/F05	31.6	30.6	1	3.2%	99.2	99.2	0.0	0.0%	59	18	58	17	1.7%	5.6%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F05	22.3	21.5	0.8	3.6%	89.9	84.1	1.0	6.5%	46	19	45	18	2.2%	5.3%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F05	26.3	25.6	0.7	2.7%	89.3	89.3	0.0	0.0%	42	16	42	16	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F05	33	32.2	0.8	2.4%	99.3	99.3	0.0	0.0%	55	16	55	16	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F05	33.6	32.9	0.7	2.1%	98.5	98.5	0.0	0.0%	61	19	61	19	0.0%	0.0%
F06	R1	RESIDENTIAL	BEDROOM		W1/F06	38.6	37.5	1.1	2.8%	92.2	91.4	0.1	0.9%	79	27	79	27	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F06	34.9	33.3	1.6	4.6%	99.5	99.5	0.0	0.0%	66	21	66	21	0.0%	0.0%
	R3	RESIDENTIAL	LKD		W3/F06	28.8	27.4	1.4	4.9%	92.3	91.9	0.1	0.4%	66	21	66	21	0.0%	0.0%
			LKD		W10/F06	27.4	27.4	0	0.0%					30	7	30	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F06	32.9	31.6	1.3	4.0%	98.6	98.6	0.0	0.0%	50	14	50	14	0.0%	0.0%
	R5	RESIDENTIAL	BEDROOM		W5/F06	34	32.8	1.2	3.5%	99.3	99.3	0.0	0.0%	61	18	61	18	0.0%	0.0%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F06	27.9	26.8	1.1	3.9%	99.3	98.9	0.1	0.4%	64	19	64	19	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F06	23.7	22.8	0.9	3.8%	99.5	99.5	0.0	0.0%	43	16	43	16	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F06	33.4	32.5	0.9	2.7%	99.3	99.3	0.0	0.0%	52	14	52	14	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F06	34.9	34	0.9	2.6%	98.5	98.5	0.0	0.0%	62	18	62	18	0.0%	0.0%
F07	R1	RESIDENTIAL	BEDROOM		W1/F07	39	37.8	1.2	3.1%	92.3	92.1	0.0	0.2%	79	27	79	27	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F07	36.2	34.6	1.6	4.4%	99.5	99.5	0.0	0.0%	66	21	66	21	0.0%	0.0%
	R3	RESIDENTIAL	LKD		W3/F07	29.9	28.3	1.6	5.4%	97.4	97.4	0.0	0.0%	66	21	66	21	0.0%	0.0%
			LKD		W10/F07	26.9	26.9	0	0.0%					27	7	27	7	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F07	34.4	33	1.4	4.1%	98.6	98.6	0.0	0.0%	52	14	52	14	0.0%	0.0%
	R5	RESIDENTIAL	BEDROOM		W5/F07	34.5	33.2	1.3	3.8%	99.2	99.2	0.0	0.0%	65	20	65	20	0.0%	0.0%
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F07	24.9	23.7	1.2	4.8%	99.3	99.2	0.0	0.1%	50	21	50	21	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F07	29	27.9	1.1	3.8%	99.6	99.6	0.0	0.0%	42	16	42	16	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F07	35.9	34.9	1	2.8%	99.3	99.3	0.0	0.0%	62	17	62	17	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F07	36.3	35.3	1	2.8%	98.6	98.6	0.0	0.0%	67	22	67	22	0.0%	0.0%
F08	R1	RESIDENTIAL	BEDROOM		W1/F08	38.8	37.7	1.1	2.8%	92.3	92.2	0.0	0.1%	76	27	76	27	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F08	37.6	35.9	1.7	4.5%	99.5	99.5	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R3	RESIDENTIAL	LKD		W3/F08	37.5	36	1.5	4.0%	100	100	0.0	0.0%	67	22	67	22	0.0%	0.0%
			LKD		W10/F08	20.9	20.9	0	0.0%					16	3	16	3	0.0%	0.0%
	R4	RESIDENTIAL	BEDROOM		W4/F08	37.6	36.2	1.4	3.7%	98.7	98.7	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R5	RESIDENTIAL	BEDROOM		W5/F08	37.5	36.2	1.3	3.5%	99.3	99.3	0.0	0.0%	67	22	67	22	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m²

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
KILMUJR HOUSE (CONTINUED)																			
	R6 (3)	RESIDENTIAL	LIVING ROOM		W6/F08	37.4	36.1	1.3	3.5%	99.3	99.2	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R7 (3)	RESIDENTIAL	LIVING ROOM		W7/F08	37.3	36.2	1.1	2.9%	99.6	99.6	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R8	RESIDENTIAL	BEDROOM		W8/F08	37.4	36.4	1	2.7%	99.4	99.4	0.0	0.0%	67	22	67	22	0.0%	0.0%
	R9	RESIDENTIAL	BEDROOM		W9/F08	37.4	36.5	0.9	2.4%	98.5	98.5	0.0	0.0%	67	22	67	22	0.0%	0.0%
SEMLEY HOUSE																			
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	20.8	20.8	0	0.0%	92.9	92.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F02	34	34	0	0.0%					31	0	31	0	0.0%	0.0%
			UNKNOWN		W3/F02	15.4	15.4	0	0.0%					30	1	30	1	0.0%	0.0%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	21.9	21.9	0	0.0%	93.9	93.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F03	35.1	35.1	0	0.0%					24	1	24	1	0.0%	0.0%
			UNKNOWN		W3/F03	17.7	17.7	0	0.0%					33	2	33	2	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W4/F03	33.5	30.8	2.7	8.1%	99.6	99.6	0.0	0.0%	73	25	70	22	4.1%	12.0%
	R3	RESIDENTIAL	UNKNOWN		W5/F03	33.3	30.5	2.8	8.4%	100	100	0.0	0.0%	73	25	70	22	4.1%	12.0%
F04	R1	RESIDENTIAL	UNKNOWN		W1/F04	22.9	22.9	0	0.0%	95.8	95.8	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F04	36.2	36.2	0	0.0%					24	1	24	1	0.0%	0.0%
			UNKNOWN		W3/F04	20.7	20.5	0.2	1.0%					38	4	38	4	0.0%	0.0%
	R2	RESIDENTIAL	LKD		W4/F04	27.4	26.8	0.6	2.2%	94.9	85.5	2.8	9.9%	62	15	62	15	0.0%	0.0%
			LKD		W5/F04	27.2	26.5	0.7	2.6%					61	15	61	15	0.0%	0.0%
			LKD		W6/F04	28.2	27.1	1.1	3.9%					64	18	63	17	1.6%	5.6%
	R3	RESIDENTIAL	LKD		W7/F04	10.9	9.3	1.6	14.7%	99.9	99.8	0.1	0.2%	23	15	22	14	4.3%	6.7%
			LKD		W8/F04	29.3	27.5	1.8	6.1%					66	20	65	19	1.5%	5.0%
			LKD		W9/F04	30.5	28.7	1.8	5.9%					64	20	63	19	1.6%	5.0%
	R4	RESIDENTIAL	LKD		W10/F04	31.1	29.3	1.8	5.8%	100	100	0.0	0.0%	67	21	65	19	3.0%	9.5%
			LKD		W11/F04	31.2	29.3	1.9	6.1%					68	21	66	19	2.9%	9.5%
			LKD		W12/F04	31.7	29.8	1.9	6.0%					68	23	66	21	2.9%	8.7%
	R5	RESIDENTIAL	LKD		W13/F04	13.6	11.4	2.2	16.2%	99.9	99.8	0.0	0.1%	27	19	26	18	3.7%	5.3%
			LKD		W14/F04	31.6	29.3	2.3	7.3%					69	24	67	22	2.9%	8.3%
			LKD		W15/F04	32.6	30.3	2.3	7.1%					68	24	66	22	2.9%	8.3%
	R6	RESIDENTIAL	LKD		W16/F04	33.1	30.8	2.3	6.9%	99.9	99.7	0.1	0.2%	68	23	66	21	2.9%	8.7%
			LKD		W17/F04	33	30.7	2.3	7.0%					68	23	66	21	2.9%	8.7%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
			LKD		W18/F04	33.3	30.9	2.4	7.2%					67	23	65	21	3.0%	8.7%
	R7	RESIDENTIAL	LKD		W19/F04	14.2	11.7	2.5	17.6%	100	96.5	1.0	3.5%	25	16	24	15	4.0%	6.3%
			LKD		W20/F04	25.2	22.7	2.5	9.9%					45	12	44	11	2.2%	8.3%
			LKD		W21/F04	20.5	18.2	2.3	11.2%					33	7	32	6	3.0%	14.3%
	R10	RESIDENTIAL	LKD		W24/F04	22.3	20.1	2.2	9.9%	99.9	96	1.1	3.9%	46	20	44	18	4.3%	10.0%
			LKD		W25/F04	27.2	24.6	2.6	9.6%					50	22	47	19	6.0%	13.6%
			LKD		W26/F04	15.5	12.9	2.6	16.8%					25	20	22	17	12.0%	15.0%
	R11	RESIDENTIAL	LKD		W27/F04	35	32.4	2.6	7.4%	100	98	0.6	2.0%	72	25	70	23	2.8%	8.0%
			LKD		W28/F04	35.2	32.6	2.6	7.4%					72	25	69	22	4.2%	12.0%
			LKD		W29/F04	35.3	32.8	2.5	7.1%					72	25	69	22	4.2%	12.0%
	R12	RESIDENTIAL	LKD		W30/F04	35.1	32.5	2.6	7.4%	100	98.6	0.4	1.4%	67	23	64	20	4.5%	13.0%
			LKD		W31/F04	34.2	31.7	2.5	7.3%					60	22	58	20	3.3%	9.1%
			LKD		W32/F04	16.6	14.1	2.5	15.1%					30	20	28	18	6.7%	10.0%
	R13	RESIDENTIAL	LKD		W33/F04	35.6	33.2	2.4	6.7%	100	99.7	0.1	0.3%	74	26	71	23	4.1%	11.5%
			LKD		W34/F04	35.7	33.4	2.3	6.4%					74	26	71	23	4.1%	11.5%
			LKD		W35/F04	35.8	33.5	2.3	6.4%					75	27	71	23	5.3%	14.8%
	R14	RESIDENTIAL	LKD		W36/F04	35.4	33.1	2.3	6.5%	100	100	0.0	0.0%	70	25	66	21	5.7%	16.0%
			LKD		W37/F04	34.6	32.3	2.3	6.6%					65	25	61	21	6.2%	16.0%
			LKD		W38/F04	16.9	14.7	2.2	13.0%					34	23	30	19	11.8%	17.4%
	R15	RESIDENTIAL	LKD		W39/F04	35.9	33.7	2.2	6.1%	100	100	0.0	0.0%	77	27	73	23	5.2%	14.8%
			LKD		W40/F04	36	33.9	2.1	5.8%					77	27	74	24	3.9%	11.1%
			LKD		W41/F04	36.2	34.1	2.1	5.8%					77	27	74	24	3.9%	11.1%
	R16	RESIDENTIAL	LKD		W42/F04	36.2	34.2	2	5.5%	100	100	0.0	0.0%	78	27	75	24	3.8%	11.1%
			LKD		W43/F04	36.1	34	2.1	5.8%					78	27	75	24	3.8%	11.1%
			LKD		W44/F04	36.3	34.3	2	5.5%					78	27	76	25	2.6%	7.4%
F05	R1	RESIDENTIAL	UNKNOWN		W1/F05	23.6	23.6	0	0.0%	96.3	96.3	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F05	37.3	37.3	0	0.0%					0	0	0	0	0.0%	0.0%
			UNKNOWN		W3/F05	23.2	22.9	0.3	1.3%					41	5	41	5	0.0%	0.0%
	R2	RESIDENTIAL	KITCHEN		W4/F05	29.9	29.2	0.7	2.3%	87.2	81.8	0.8	6.1%	65	18	65	18	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W5/F05	30.2	29.1	1.1	3.6%	84.9	69.4	3.4	18.3%	69	19	68	18	1.4%	5.3%
	R4	RESIDENTIAL	LKD		W6/F05	31.5	29.9	1.6	5.1%	99	99	0.0	0.0%	70	20	69	19	1.4%	5.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
			LKD		W7/F05	31.3	29.8	1.5	4.8%					67	20	66	19	15%	5.0%
			LKD		W8/F05	32.5	30.9	1.6	4.9%					67	20	66	19	15%	5.0%
	R5	RESIDENTIAL	KITCHEN		W9/F05	33	31.1	1.9	5.8%	98.2	98.2	0.0	0.0%	71	24	69	22	2.8%	8.3%
	R6	RESIDENTIAL	LIVING ROOM		W10/F05	33	31	2	6.1%	93.8	91	0.6	3.1%	72	24	71	23	1.4%	4.2%
	R7	RESIDENTIAL	LKD		W11/F05	33.8	31.8	2	5.9%	99	99	0.0	0.0%	72	24	71	23	1.4%	4.2%
			LKD		W12/F05	33.6	31.6	2	6.0%					71	24	70	23	1.4%	4.2%
			LKD		W13/F05	34.4	32.2	2.2	6.4%					71	24	70	23	1.4%	4.2%
	R8	RESIDENTIAL	KITCHEN		W14/F05	34.4	32.1	2.3	6.7%	98.3	96.4	0.2	1.9%	67	23	65	21	3.0%	8.7%
	R9	RESIDENTIAL	LIVING ROOM		W15/F05	34	31.7	2.3	6.8%	93.9	90.3	0.8	3.9%	68	23	66	21	2.9%	8.7%
	R10	RESIDENTIAL	LKD		W16/F05	34	31.6	2.4	7.1%	99	98.8	0.0	0.1%	65	22	63	20	3.1%	9.1%
			LKD		W17/F05	33	30.6	2.4	7.3%					62	22	60	20	3.2%	9.1%
			LKD		W18/F05	29.6	27.1	2.5	8.4%					50	16	48	14	4.0%	12.5%
	R13	RESIDENTIAL	LKD		W21/F05	30.9	28.4	2.5	8.1%	98.9	98.8	0.0	0.1%	67	27	65	25	3.0%	7.4%
			LKD		W22/F05	34	31.6	2.4	7.1%					68	27	65	24	4.4%	11.1%
			LKD		W23/F05	34.9	32.4	2.5	7.2%					70	27	68	25	2.9%	7.4%
	R14	RESIDENTIAL	LIVING ROOM		W24/F05	35.3	32.8	2.5	7.1%	94.2	87.2	1.6	7.5%	74	27	72	25	2.7%	7.4%
	R15	RESIDENTIAL	KITCHEN (1)		W25/F05	36.1	33.6	2.5	6.9%	98.2	94.8	0.4	3.5%	76	27	74	25	2.6%	7.4%
	R16	RESIDENTIAL	LKD		W26/F05	36.6	34.1	2.5	6.8%	99	98.9	0.0	0.1%	75	27	73	25	2.7%	7.4%
			LKD		W27/F05	36.2	33.8	2.4	6.6%					73	27	70	24	4.1%	11.1%
			LKD		W28/F05	36.5	34.1	2.4	6.6%					74	27	72	25	2.7%	7.4%
	R17	RESIDENTIAL	LIVING ROOM		W29/F05	36.1	33.8	2.3	6.4%	94.3	88.5	1.3	6.1%	78	28	75	25	3.8%	10.7%
	R18	RESIDENTIAL	KITCHEN (1)		W30/F05	36.6	34.3	2.3	6.3%	98.1	96.7	0.2	1.4%	77	27	75	25	2.6%	7.4%
	R19	RESIDENTIAL	LKD		W31/F05	36.9	34.7	2.2	6.0%	99	99	0.0	0.0%	77	28	74	25	3.9%	10.7%
			LKD		W32/F05	36.6	34.4	2.2	6.0%					75	28	71	24	5.3%	14.3%
			LKD		W33/F05	36.7	34.6	2.1	5.7%					75	28	72	25	4.0%	10.7%
	R20	RESIDENTIAL	LIVING ROOM		W34/F05	36.4	34.3	2.1	5.8%	94.3	90.2	0.9	4.3%	78	27	75	24	3.8%	11.1%
	R21	RESIDENTIAL	KITCHEN (1)		W35/F05	36.8	34.8	2	5.4%	98.1	98.1	0.0	0.0%	79	27	77	25	2.5%	7.4%
	R22	RESIDENTIAL	KITCHEN		W36/F05	37.1	35.1	2	5.4%	98.3	98.3	0.0	0.0%	79	27	77	25	2.5%	7.4%
	R23	RESIDENTIAL	LIVING ROOM		W37/F05	37.1	35.2	1.9	5.1%	94.1	93.9	0.0	0.1%	79	27	77	25	2.5%	7.4%
F06	R1	RESIDENTIAL	UNKNOWN		W1/F06	23.9	23.9	0	0.0%	97.1	97.1	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F06	38.1	38.1	0	0.0%					28	3	28	3	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
			UNKNOWN		W3/F06	25.4	25	0.4	1.6%					48	12	48	12	0.0%	0.0%
	R2	RESIDENTIAL	LIVING ROOM		W4/F06	30.3	29.4	0.9	3.0%	80.6	80.3	0.1	0.4%	55	17	55	17	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN (1)		W5/F06	17	15.8	1.2	7.1%	95.9	95.6	0.0	0.4%	39	20	39	20	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W6/F06	33.2	31.8	1.4	4.2%	98.2	98.2	0.0	0.0%	69	21	69	21	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/F06	34.1	32.5	1.6	4.7%	94.1	91.8	0.5	2.4%	70	21	69	20	1.4%	4.8%
	R6	RESIDENTIAL	LIVING ROOM		W8/F06	32.3	30.6	1.7	5.3%	90.2	89.5	0.2	0.8%	57	19	56	18	1.8%	5.3%
	R7	RESIDENTIAL	KITCHEN (1)		W9/F06	18.7	16.8	1.9	10.2%	98.2	98.2	0.0	0.0%	41	23	41	23	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN (1)		W10/F06	34.8	32.8	2	5.7%	98.2	98.2	0.0	0.0%	70	24	70	24	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W11/F06	35.5	33.4	2.1	5.9%	94.3	93	0.3	1.4%	70	23	70	23	0.0%	0.0%
	R10	RESIDENTIAL	LIVING ROOM		W12/F06	33.5	31.4	2.1	6.3%	93.8	93	0.2	0.9%	57	19	56	18	1.8%	5.3%
	R11	RESIDENTIAL	KITCHEN (1)		W13/F06	19.3	17.1	2.2	11.4%	98	97.3	0.1	0.7%	40	23	38	21	5.0%	8.7%
	R12	RESIDENTIAL	KITCHEN (1)		W14/F06	34.4	32.1	2.3	6.7%	98.2	97.5	0.1	0.7%	62	22	60	20	3.2%	9.1%
	R13	RESIDENTIAL	LIVING ROOM		W15/F06	30	27.7	2.3	7.7%	93	86.9	1.3	6.5%	50	16	48	14	4.0%	12.5%
	R16	RESIDENTIAL	LIVING ROOM		W18/F06	31.2	28.9	2.3	7.4%	93.5	90.6	0.6	3.1%	68	27	66	25	2.9%	7.4%
	R17	RESIDENTIAL	KITCHEN (1)		W19/F06	35.2	32.8	2.4	6.8%	98.1	97.2	0.1	0.9%	67	23	65	21	3.0%	8.7%
	R18	RESIDENTIAL	KITCHEN (1)		W20/F06	20.4	18.1	2.3	11.3%	98.2	97	0.1	1.2%	33	19	31	17	6.1%	10.5%
	R19	RESIDENTIAL	LIVING ROOM		W21/F06	34.8	32.5	2.3	6.6%	94.3	92.7	0.4	1.7%	69	26	67	24	2.9%	7.7%
	R20	RESIDENTIAL	LIVING ROOM		W22/F06	37.2	34.9	2.3	6.2%	94.3	89.8	1.0	4.7%	76	27	74	25	2.6%	7.4%
	R21	RESIDENTIAL	KITCHEN (1)		W23/F06	36.8	34.6	2.2	6.0%	98.3	97.3	0.1	1.0%	69	23	67	21	2.9%	8.7%
	R22	RESIDENTIAL	KITCHEN (1)		W24/F06	21	18.9	2.1	10.0%	98.2	97.8	0.0	0.4%	34	19	32	17	5.9%	10.5%
	R23	RESIDENTIAL	LIVING ROOM		W25/F06	35.2	33	2.2	6.3%	94.2	93.6	0.2	0.7%	72	26	70	24	2.8%	7.7%
	R24	RESIDENTIAL	LIVING ROOM		W26/F06	37.5	35.4	2.1	5.6%	94.3	91	0.7	3.4%	79	28	76	25	3.8%	10.7%
	R25	RESIDENTIAL	KITCHEN (1)		W27/F06	37	35.1	1.9	5.1%	98.1	98.1	0.0	0.0%	73	25	70	22	4.1%	12.0%
	R26	RESIDENTIAL	KITCHEN (1)		W28/F06	21.4	19.5	1.9	8.9%	98.2	98.2	0.0	0.0%	37	21	34	18	8.1%	14.3%
	R27	RESIDENTIAL	LIVING ROOM		W29/F06	35.2	33.3	1.9	5.4%	94.1	93.9	0.0	0.2%	76	28	74	26	2.6%	7.1%
	R28	RESIDENTIAL	LIVING ROOM		W30/F06	37.7	35.9	1.8	4.8%	94.2	92.3	0.4	2.1%	78	27	76	25	2.6%	7.4%
	R29	RESIDENTIAL	KITCHEN		W31/F06	37.8	36.1	1.7	4.5%	98.1	98.1	0.0	0.0%	79	27	77	25	2.5%	7.4%
F07	R1	RESIDENTIAL	UNKNOWN		W1/F07	24	24	0	0.0%	97.4	97.3	0.0	0.1%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F07	38.7	38.7	0	0.0%									0.0%	0.0%
			UNKNOWN		W3/F07	27.6	27	0.6	2.2%					49	13	49	13	0.0%	0.0%
	R2	RESIDENTIAL	LKD		W4/F07	35.2	34	1.2	3.4%	98.9	98.9	0.0	0.0%	72	22	72	22	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
			LKD		W5/F07	34.8	33.6	1.2	3.4%					69	22	69	22	0.0%	0.0%
			LKD		W6/F07	35.4	34.1	1.3	3.7%					69	22	69	22	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W7/F07	35.1	33.7	1.4	4.0%	89.6	89.5	0.0	0.2%	73	23	72	22	1.4%	4.3%
	R4	RESIDENTIAL	KITCHEN (I)		W8/F07	35.8	34.2	1.6	4.5%	98.1	98.1	0.0	0.0%	75	24	74	23	1.3%	4.2%
	R5	RESIDENTIAL	LKD		W9/F07	36.3	34.7	1.6	4.4%	99.1	99.1	0.0	0.0%	74	24	74	24	0.0%	0.0%
			LKD		W10/F07	36	34.3	1.7	4.7%					71	24	71	24	0.0%	0.0%
			LKD		W11/F07	36.3	34.6	1.7	4.7%					70	24	70	24	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W12/F07	36	34.2	1.8	5.0%	94.1	93.8	0.1	0.4%	73	24	73	24	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (I)		W13/F07	36.6	34.7	1.9	5.2%	98.2	98.2	0.0	0.0%	73	24	73	24	0.0%	0.0%
	R8	RESIDENTIAL	LKD		W14/F07	36.9	34.9	2	5.4%	99	99	0.0	0.0%	71	24	70	23	1.4%	4.2%
			LKD		W15/F07	36.5	34.5	2	5.5%					70	24	69	23	1.4%	4.2%
			LKD		W16/F07	36.7	34.6	2.1	5.7%					69	24	67	22	2.9%	8.3%
	R9	RESIDENTIAL	LIVING ROOM		W17/F07	35.2	33.1	2.1	6.0%	94.2	93.3	0.2	0.9%	66	23	64	21	3.0%	8.7%
	R10	RESIDENTIAL	KITCHEN (I)		W18/F07	29.1	27	2.1	7.2%	98.2	98.2	0.0	0.0%	49	14	47	12	4.1%	14.3%
	R13	RESIDENTIAL	KITCHEN (I)		W21/F07	29.9	27.8	2.1	7.0%	98.2	98.2	0.0	0.0%	61	26	59	24	3.3%	7.7%
	R14	RESIDENTIAL	LIVING ROOM		W22/F07	35.7	33.6	2.1	5.9%	94.3	93.2	0.2	1.2%	76	27	74	25	2.6%	7.4%
	R15	RESIDENTIAL	LKD		W23/F07	37.3	35.2	2.1	5.6%	99	99	0.0	0.0%	76	27	74	25	2.6%	7.4%
			LKD		W24/F07	37.3	35.2	2.1	5.6%					75	27	73	25	2.7%	7.4%
			LKD		W25/F07	37.7	35.7	2	5.3%					75	28	73	26	2.7%	7.1%
	R16	RESIDENTIAL	KITCHEN (I)		W26/F07	37.7	35.6	2.1	5.6%	98.2	98.2	0.0	0.0%	75	28	73	26	2.7%	7.1%
	R17	RESIDENTIAL	LIVING ROOM		W27/F07	37.4	35.4	2	5.3%	94.3	93.6	0.2	0.8%	79	28	77	26	2.5%	7.1%
	R18	RESIDENTIAL	LKD		W28/F07	37.9	35.9	2	5.3%	99.1	99.1	0.0	0.0%	79	28	77	26	2.5%	7.1%
			LKD		W29/F07	37.8	35.9	1.9	5.0%					77	28	75	26	2.6%	7.1%
			LKD		W30/F07	38.2	36.3	1.9	5.0%					76	28	74	26	2.6%	7.1%
	R19	RESIDENTIAL	KITCHEN (I)		W31/F07	38	36.1	1.9	5.0%	98.3	98.3	0.0	0.0%	77	28	74	25	3.9%	10.7%
	R20	RESIDENTIAL	LIVING ROOM		W32/F07	37.6	35.8	1.8	4.8%	94.3	94	0.1	0.3%	80	28	77	25	3.8%	10.7%
	R21	RESIDENTIAL	LKD		W33/F07	38.1	36.3	1.8	4.7%	99	99	0.0	0.0%	80	28	78	26	2.5%	7.1%
			LKD		W34/F07	38	36.2	1.8	4.7%					80	28	78	26	2.5%	7.1%
			LKD		W35/F07	38.3	36.6	1.7	4.4%					80	28	78	26	2.5%	7.1%
	R22	RESIDENTIAL	KITCHEN (I)		W36/F07	38.4	36.7	1.7	4.4%	98.3	98.3	0.0	0.0%	80	28	78	26	2.5%	7.1%
	R23	RESIDENTIAL	LIVING ROOM		W37/F07	38.4	36.8	1.6	4.2%	94.3	94.3	0.0	0.0%	80	28	78	26	2.5%	7.1%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
F08	R1	RESIDENTIAL	UNKNOWN		W1/F08	24.1	24.1	0	0.0%	99.4	99.4	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F08	39.1	39.1	0	0.0%					31	6	31	6	0.0%	0.0%
			UNKNOWN		W3/F08	29.7	28.9	0.8	2.7%					51	15	51	15	0.0%	0.0%
	R2	RESIDENTIAL	LIVING ROOM		W4/F08	36.9	35.8	1.1	3.0%	94.5	94.5	0.0	0.0%	75	24	75	24	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN (1)		W5/F08	36.6	35.5	1.1	3.0%	98.2	98.2	0.0	0.0%	69	21	69	21	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W6/F08	21.7	20.4	1.3	6.0%	98.2	98.2	0.0	0.0%	37	20	37	20	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/F08	35.1	33.7	1.4	4.0%	94.2	94.2	0.0	0.0%	70	25	70	25	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W8/F08	37.4	35.9	1.5	4.0%	94.3	94.2	0.0	0.1%	75	25	75	25	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (1)		W9/F08	37.2	35.6	1.6	4.3%	98.2	98.2	0.0	0.0%	70	22	70	22	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN (1)		W10/F08	22.3	20.7	1.6	7.2%	98.2	98.2	0.0	0.0%	37	20	37	20	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W11/F08	35.5	33.8	1.7	4.8%	94.3	94.2	0.0	0.0%	70	26	69	25	1.4%	3.8%
	R10	RESIDENTIAL	LIVING ROOM		W12/F08	37.7	35.9	1.8	4.8%	94.3	94.2	0.0	0.1%	71	25	70	24	1.4%	4.0%
	R11	RESIDENTIAL	KITCHEN (1)		W13/F08	37.4	35.6	1.8	4.8%	98.1	98.1	0.0	0.0%	68	23	66	21	2.9%	8.7%
	R12	RESIDENTIAL	KITCHEN (1)		W14/F08	22.2	20.3	1.9	8.6%	98.2	98.2	0.0	0.0%	37	20	35	18	5.4%	10.0%
	R13	RESIDENTIAL	LIVING ROOM		W15/F08	29.1	27.3	1.8	6.2%	93.2	93.1	0.0	0.1%	49	17	47	15	4.1%	11.8%
	R16	RESIDENTIAL	LIVING ROOM		W18/F08	29.7	27.8	1.9	6.4%	93.3	93.1	0.0	0.2%	52	23	50	21	3.8%	8.7%
	R17	RESIDENTIAL	KITCHEN (1)		W19/F08	22.4	20.5	1.9	8.5%	98.1	98.1	0.0	0.0%	48	27	46	25	4.2%	7.4%
	R18	RESIDENTIAL	KITCHEN (1)		W20/F08	37.7	35.9	1.8	4.8%	98.2	98.2	0.0	0.0%	76	27	74	25	2.6%	7.4%
	R19	RESIDENTIAL	LIVING ROOM		W21/F08	38.2	36.4	1.8	4.7%	94.3	94.1	0.0	0.2%	77	26	75	24	2.6%	7.7%
	R20	RESIDENTIAL	LIVING ROOM		W22/F08	36.3	34.5	1.8	5.0%	94.3	94.3	0.0	0.0%	61	23	59	21	3.3%	8.7%
	R21	RESIDENTIAL	KITCHEN (1)		W23/F08	22.9	21.2	1.7	7.4%	98.2	98.2	0.0	0.0%	49	27	47	25	4.1%	7.4%
	R22	RESIDENTIAL	KITCHEN (1)		W24/F08	38.1	36.4	1.7	4.5%	98.2	98.2	0.0	0.0%	76	27	74	25	2.6%	7.4%
	R23	RESIDENTIAL	LIVING ROOM		W25/F08	38.6	36.9	1.7	4.4%	94.3	94.1	0.0	0.1%	78	27	76	25	2.6%	7.4%
	R24	RESIDENTIAL	LIVING ROOM		W26/F08	36.4	34.7	1.7	4.7%	94.3	94.3	0.0	0.0%	62	23	60	21	3.2%	8.7%
	R25	RESIDENTIAL	KITCHEN (1)		W27/F08	22.8	21.2	1.6	7.0%	98.1	98.1	0.0	0.0%	51	28	48	25	5.9%	10.7%
	R26	RESIDENTIAL	KITCHEN (1)		W28/F08	38.2	36.7	1.5	3.9%	98.2	98.2	0.0	0.0%	78	28	76	26	2.6%	7.1%
	R27	RESIDENTIAL	LIVING ROOM		W29/F08	38.8	37.2	1.6	4.1%	94.3	94.2	0.0	0.1%	79	28	77	26	2.5%	7.1%
	R28	RESIDENTIAL	LIVING ROOM		W30/F08	38.9	37.4	1.5	3.9%	94.3	94.3	0.0	0.0%	80	28	78	26	2.5%	7.1%
	R29	RESIDENTIAL	KITCHEN (1)		W31/F08	38.9	37.5	1.4	3.6%	98.1	98.1	0.0	0.0%	80	28	78	26	2.5%	7.1%
F09	R1	RESIDENTIAL	UNKNOWN		W1/F09	24.2	24.2	0	0.0%	99.9	99.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F09	39.4	39.4	0	0.0%							31	6	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
			UNKNOWN		W3/F09	31.2	30.4	0.8	2.6%					52	16	52	16	0.0%	0.0%
	R2	RESIDENTIAL	KITCHEN		W4/F09	38.2	37.2	1	2.6%	98.3	98.3	0.0	0.0%	76	27	76	27	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W5/F09	37.9	36.8	1.1	2.9%	93.9	93.9	0.0	0.0%	79	27	79	27	0.0%	0.0%
	R4	RESIDENTIAL	LKD		W6/F09	38.4	37.2	1.2	3.1%	99	99	0.0	0.0%	78	27	78	27	0.0%	0.0%
			LKD		W7/F09	37.8	36.9	0.9	2.4%					76	26	76	26	0.0%	0.0%
			LKD		W8/F09	38.6	37.4	1.2	3.1%					75	27	75	27	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN		W9/F09	38.5	37.2	1.3	3.4%	98.3	98.3	0.0	0.0%	75	27	75	27	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W10/F09	38.1	36.8	1.3	3.4%	93.9	93.8	0.0	0.0%	78	27	78	27	0.0%	0.0%
	R7	RESIDENTIAL	LKD		W11/F09	38.6	37.2	1.4	3.6%	99	99	0.0	0.0%	77	27	77	27	0.0%	0.0%
			LKD		W12/F09	38.1	36.9	1.2	3.1%					77	27	77	27	0.0%	0.0%
			LKD		W13/F09	38.8	37.3	1.5	3.9%					75	27	75	27	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN		W14/F09	38.4	37	1.4	3.6%	98.2	98.2	0.0	0.0%	72	26	71	25	14%	3.8%
	R9	RESIDENTIAL	LIVING ROOM		W15/F09	37.8	36.3	1.5	4.0%	93.9	93.9	0.0	0.0%	73	26	72	25	14%	3.8%
	R10	RESIDENTIAL	LKD		W16/F09	37.6	36	1.6	4.3%	99	99	0.0	0.0%	68	24	67	23	15%	4.2%
			LKD		W17/F09	36.2	35	1.2	3.3%					66	24	64	22	3.0%	8.3%
			LKD		W18/F09	32.6	31	1.6	4.9%					54	18	53	17	19%	5.6%
	R13	RESIDENTIAL	LKD		W21/F09	32.7	31.2	1.5	4.6%	98.9	98.9	0.0	0.0%	68	28	67	27	15%	3.6%
			LKD		W22/F09	36.3	35.1	1.2	3.3%					72	28	70	26	2.8%	7.1%
			LKD		W23/F09	37.6	36	1.6	4.3%					74	28	73	27	14%	3.6%
	R14	RESIDENTIAL	LIVING ROOM		W24/F09	37.9	36.4	1.5	4.0%	94.3	94.2	0.0	0.0%	79	28	78	27	13%	3.6%
	R15	RESIDENTIAL	KITCHEN (1)		W25/F09	38.6	37.1	1.5	3.9%	98.1	98.1	0.0	0.0%	78	28	77	27	13%	3.6%
	R16	RESIDENTIAL	LKD		W26/F09	39	37.5	1.5	3.8%	99	99	0.0	0.0%	77	28	76	27	13%	3.6%
			LKD		W27/F09	38.3	37.2	1.1	2.9%					75	28	73	26	2.7%	7.1%
			LKD		W28/F09	38.9	37.5	1.4	3.6%					76	28	75	27	13%	3.6%
	R17	RESIDENTIAL	LIVING ROOM		W29/F09	38.5	37.1	1.4	3.6%	94.3	94.3	0.0	0.0%	80	28	79	27	13%	3.6%
	R18	RESIDENTIAL	KITCHEN (1)		W30/F09	38.9	37.5	1.4	3.6%	98.1	98.1	0.0	0.0%	79	28	78	27	13%	3.6%
	R19	RESIDENTIAL	LKD		W31/F09	39.1	37.8	1.3	3.3%	99	99	0.0	0.0%	78	28	77	27	13%	3.6%
			LKD		W32/F09	38.8	37.6	1.2	3.1%					76	28	75	27	13%	3.6%
			LKD		W33/F09	39	37.7	1.3	3.3%					76	28	75	27	13%	3.6%
	R20	RESIDENTIAL	LIVING ROOM		W34/F09	38.6	37.3	1.3	3.4%	94.3	94.3	0.0	0.0%	80	28	79	27	13%	3.6%
	R21	RESIDENTIAL	KITCHEN (1)		W35/F09	38.9	37.7	1.2	3.1%	98.2	98.2	0.0	0.0%	80	28	79	27	13%	3.6%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
	R22	RESIDENTIAL	KITCHEN (1)		W36/F09	39.2	38	1.2	3.1%	98.3	98.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
	R23	RESIDENTIAL	LIVING ROOM		W37/F09	39.3	38.1	1.2	3.1%	94.3	94.3	0.0	0.0%	80	28	79	27	1.3%	3.6%
F10	R1	RESIDENTIAL	UNKNOWN		W1/F10	24.6	24.6	0	0.0%	99.9	99.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F10	39.6	39.6	0	0.0%					32	7	32	7	0.0%	0.0%
			UNKNOWN		W3/F10	32.6	31.7	0.9	2.8%					53	17	53	17	0.0%	0.0%
	R2	RESIDENTIAL	LIVING ROOM		W4/F10	37.1	36.1	1	2.7%	94.5	94.5	0.0	0.0%	62	22	62	22	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN (1)		W5/F10	22.7	21.7	1	4.4%	98.2	98.2	0.0	0.0%	47	26	47	26	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W6/F10	38.9	37.9	1	2.6%	98.2	98.2	0.0	0.0%	77	27	77	27	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/F10	39.3	38.2	1.1	2.8%	94.3	94.3	0.0	0.0%	77	26	77	26	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W8/F10	37.1	36	1.1	3.0%	94.3	94.3	0.0	0.0%	61	22	61	22	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (1)		W9/F10	22.6	21.5	1.1	4.9%	98.2	98.2	0.0	0.0%	46	26	46	26	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN (1)		W10/F10	38.9	37.8	1.1	2.8%	98.2	98.2	0.0	0.0%	76	27	76	27	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W11/F10	39.3	38.2	1.1	2.8%	94.3	94.3	0.0	0.0%	75	26	75	26	0.0%	0.0%
	R10	RESIDENTIAL	LIVING ROOM		W12/F10	37	35.8	1.2	3.2%	94.3	94.3	0.0	0.0%	61	22	61	22	0.0%	0.0%
	R11	RESIDENTIAL	KITCHEN (1)		W13/F10	22.1	20.9	1.2	5.4%	98.1	98.1	0.0	0.0%	41	25	41	25	0.0%	0.0%
	R12	RESIDENTIAL	KITCHEN (1)		W14/F10	37.5	36.3	1.2	3.2%	98.2	98.2	0.0	0.0%	65	24	65	24	0.0%	0.0%
	R13	RESIDENTIAL	LIVING ROOM		W15/F10	32.6	31.4	1.2	3.7%	93.2	93.2	0.0	0.0%	52	17	52	17	0.0%	0.0%
	R16	RESIDENTIAL	LIVING ROOM		W18/F10	32.6	31.4	1.2	3.7%	93.3	93.3	0.0	0.0%	70	28	70	28	0.0%	0.0%
	R17	RESIDENTIAL	KITCHEN (1)		W19/F10	37.4	36.2	1.2	3.2%	98.1	98.1	0.0	0.0%	69	24	69	24	0.0%	0.0%
	R18	RESIDENTIAL	KITCHEN (1)		W20/F10	22.1	20.9	1.2	5.4%	98.2	98.2	0.0	0.0%	34	20	34	20	0.0%	0.0%
	R19	RESIDENTIAL	LIVING ROOM		W21/F10	37	35.8	1.2	3.2%	94.3	94.2	0.0	0.0%	74	27	74	27	0.0%	0.0%
	R20	RESIDENTIAL	LIVING ROOM		W22/F10	39.3	38.2	1.1	2.8%	94.3	94.3	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R21	RESIDENTIAL	KITCHEN (1)		W23/F10	38.9	37.8	1.1	2.8%	98.2	98.2	0.0	0.0%	71	24	70	23	1.4%	4.2%
	R22	RESIDENTIAL	KITCHEN (1)		W24/F10	22.6	21.5	1.1	4.9%	98.2	98.2	0.0	0.0%	35	20	34	19	2.9%	5.0%
	R23	RESIDENTIAL	LIVING ROOM		W25/F10	37.1	36	1.1	3.0%	94.3	94.2	0.0	0.0%	75	27	74	26	1.3%	3.7%
	R24	RESIDENTIAL	LIVING ROOM		W26/F10	39.4	38.3	1.1	2.8%	94.3	94.3	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R25	RESIDENTIAL	KITCHEN (1)		W27/F10	39	38	1	2.6%	98.1	98.1	0.0	0.0%	73	25	72	24	1.4%	4.0%
	R26	RESIDENTIAL	KITCHEN (1)		W28/F10	22.9	21.9	1	4.4%	98.2	98.2	0.0	0.0%	37	21	36	20	2.7%	4.8%
	R27	RESIDENTIAL	LIVING ROOM		W29/F10	37.1	36.1	1	2.7%	94.3	94.3	0.0	0.0%	76	28	75	27	1.3%	3.6%
	R28	RESIDENTIAL	LIVING ROOM		W30/F10	39.5	38.5	1	2.5%	94.3	94.3	0.0	0.0%	79	28	78	27	1.3%	3.6%
	R29	RESIDENTIAL	KITCHEN (1)		W31/F10	39.6	38.6	1	2.5%	98.1	98.1	0.0	0.0%	80	28	79	27	1.3%	3.6%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
F11	R1	RESIDENTIAL	UNKNOWN		W1/F11	25.7	25.7	0	0.0%	99.9	99.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F11	39.6	39.6	0	0.0%					55	5	55	5	0.0%	0.0%
			UNKNOWN		W3/F11	34.2	33.4	0.8	2.3%					57	17	57	17	0.0%	0.0%
	R2	RESIDENTIAL	LKD		W4/F11	39.5	38.8	0.7	1.8%	99	99	0.0	0.0%	79	27	79	27	0.0%	0.0%
			LKD		W5/F11	39.4	38.6	0.8	2.0%					79	27	79	27	0.0%	0.0%
			LKD		W6/F11	39.5	38.8	0.7	1.8%					79	27	79	27	0.0%	0.0%
	R3	RESIDENTIAL	LIVING ROOM		W7/F11	39.5	38.7	0.8	2.0%	94.3	94.3	0.0	0.0%	79	27	79	27	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN (1)		W8/F11	39.5	38.7	0.8	2.0%	98.1	98.1	0.0	0.0%	79	27	79	27	0.0%	0.0%
	R5	RESIDENTIAL	LKD		W9/F11	39.6	38.8	0.8	2.0%	99	99	0.0	0.0%	79	27	79	27	0.0%	0.0%
			LKD		W10/F11	39.4	38.6	0.8	2.0%					79	27	79	27	0.0%	0.0%
			LKD		W11/F11	39.6	38.8	0.8	2.0%					79	27	79	27	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W12/F11	39.5	38.7	0.8	2.0%	94.3	94.3	0.0	0.0%	79	27	79	27	0.0%	0.0%
	R7	RESIDENTIAL	KITCHEN (1)		W13/F11	39.5	38.7	0.8	2.0%	98.2	98.2	0.0	0.0%	78	27	78	27	0.0%	0.0%
	R8	RESIDENTIAL	LKD		W14/F11	39.4	38.5	0.9	2.3%	99	99	0.0	0.0%	76	26	76	26	0.0%	0.0%
			LKD		W15/F11	39.1	38.2	0.9	2.3%					74	26	74	26	0.0%	0.0%
			LKD		W16/F11	39	38.2	0.8	2.1%					72	25	72	25	0.0%	0.0%
	R9	RESIDENTIAL	LIVING ROOM		W17/F11	37.9	37	0.9	2.4%	94.3	94.3	0.0	0.0%	67	24	67	24	0.0%	0.0%
	R10	RESIDENTIAL	KITCHEN (1)		W18/F11	31.2	30.3	0.9	2.9%	98.2	98.2	0.0	0.0%	50	15	50	15	0.0%	0.0%
	R13	RESIDENTIAL	KITCHEN (1)		W22/F11	31.1	30.2	0.9	2.9%	98.2	98.2	0.0	0.0%	65	26	65	26	0.0%	0.0%
	R14	RESIDENTIAL	LIVING ROOM		W23/F11	37.9	37	0.9	2.4%	94.3	94.3	0.0	0.0%	77	28	77	28	0.0%	0.0%
	R15	RESIDENTIAL	LKD		W24/F11	38.9	38.1	0.8	2.1%	99	99	0.0	0.0%	78	28	78	28	0.0%	0.0%
			LKD		W25/F11	39	38.1	0.9	2.3%					79	28	79	28	0.0%	0.0%
			LKD		W26/F11	39.3	38.4	0.9	2.3%					79	28	79	28	0.0%	0.0%
	R16	RESIDENTIAL	KITCHEN (1)		W27/F11	39.5	38.6	0.9	2.3%	98.2	98.2	0.0	0.0%	79	28	79	28	0.0%	0.0%
	R17	RESIDENTIAL	LIVING ROOM		W28/F11	39.5	38.7	0.8	2.0%	94.3	94.3	0.0	0.0%	79	28	79	28	0.0%	0.0%
	R18	RESIDENTIAL	LKD		W29/F11	39.6	38.7	0.9	2.3%	99.1	99.1	0.0	0.0%	80	28	80	28	0.0%	0.0%
			LKD		W30/F11	39.4	38.6	0.8	2.0%					80	28	79	27	1.3%	3.6%
			LKD		W31/F11	39.6	38.8	0.8	2.0%					80	28	80	28	0.0%	0.0%
	R19	RESIDENTIAL	KITCHEN (1)		W32/F11	39.6	38.8	0.8	2.0%	98.3	98.3	0.0	0.0%	80	28	80	28	0.0%	0.0%
	R20	RESIDENTIAL	LIVING ROOM		W33/F11	39.6	38.8	0.8	2.0%	94.3	94.3	0.0	0.0%	80	28	80	28	0.0%	0.0%
	R21	RESIDENTIAL	LKD		W34/F11	39.6	38.8	0.8	2.0%	99	99	0.0	0.0%	80	28	80	28	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
SEMLEY HOUSE (CONTINUED)																			
			LKD		W35/F11	39.5	38.7	0.8	2.0%					80	28	79	27	1.3%	3.6%
			LKD		W36/F11	39.6	38.9	0.7	1.8%					80	28	80	28	0.0%	0.0%
	R22	RESIDENTIAL	KITCHEN (1)		W37/F11	39.6	38.9	0.7	1.8%	98.3	98.3	0.0	0.0%	80	28	80	28	0.0%	0.0%
	R23	RESIDENTIAL	LIVING ROOM		W38/F11	39.6	38.9	0.7	1.8%	94.3	94.3	0.0	0.0%	80	28	80	28	0.0%	0.0%
F12	R1	RESIDENTIAL	UNKNOWN		W1/F12	31.5	31.5	0	0.0%	100	100	0.0	0.0%	0	0	0	0	0.0%	0.0%
			UNKNOWN		W2/F12	39.6	39.6	0	0.0%					32	7	32	7	0.0%	0.0%
			UNKNOWN		W3/F12	37.4	36.9	0.5	1.3%					74	22	74	22	0.0%	0.0%
FOUNTAIN COURT																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	26.5	20	6.5	24.5%	85.6	55.7	4.6	34.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	25.8	19.1	6.7	26.0%	96.3	77.6	3.0	19.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F00	24.8	18.2	6.6	26.6%	97.6	89	1.7	8.8%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F00	24.2	17.5	6.7	27.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F00	22.9	16.5	6.4	27.9%	88.3	77.4	1.6	12.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F00	21.2	14.3	6.9	32.5%	75.9	61.4	2.0	19.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F00	19.5	12.4	7.1	36.4%	60.1	43.4	2.4	27.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F00	18.5	11.3	7.2	38.9%	98.9	96.9	0.3	2.0%	18	4	18	4	22.2%	0.0%
			UNKNOWN		W9/F00	22.1	16.1	6	27.1%					41	12	39	12	4.9%	0.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F00	23.4	17.2	6.2	26.5%	98.5	88.2	0.9	10.5%	43	13	40	12	7.0%	7.7%
	R9	RESIDENTIAL	UNKNOWN		W11/F00	24.4	18.4	6	24.6%	98.6	81.7	2.0	17.1%	44	13	42	13	4.5%	0.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	28.4	20.9	7.5	26.4%	88.3	54.8	5.2	38.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.5	19.6	7.9	28.7%	97.2	76.9	3.3	20.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F01	26.9	18.9	8	29.7%	98.1	88.6	1.9	9.7%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F01	26.3	18.2	8.1	30.8%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F01	24.9	16.8	8.1	32.5%	89.8	77.2	1.8	14.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F01	23.8	14.9	8.9	37.4%	77.5	61.2	2.2	21.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F01	22.4	13.2	9.2	41.1%	61.9	42.7	2.8	31.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F01	21.6	12	9.6	44.4%	99	96.9	0.3	2.1%	18	4	14	4	22.2%	0.0%
			UNKNOWN		W9/F01	24.9	17.1	7.8	31.3%					43	13	40	13	7.0%	0.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F01	26	18.3	7.7	29.6%	98.8	87.4	1.0	11.5%	45	13	41	12	8.9%	7.7%
	R9	RESIDENTIAL	UNKNOWN		W11/F01	27	19.5	7.5	27.8%	98.6	81.1	2.0	17.8%	47	14	42	14	10.6%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
FOUNTAIN COURT (CONTINUED)																			
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.7	21.6	8.1	27.3%	95.1	54.7	6.2	42.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	17.9	11.4	6.5	36.3%	99.1	75.9	3.7	23.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F02	28.7	19.2	9.5	33.1%	99.4	88.5	2.2	10.9%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F02	28	18.6	9.4	33.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F02	14.4	8.5	5.9	41.0%	92.2	76.5	2.3	17.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F02	26.3	15.2	11.1	42.2%	86.7	61	3.5	29.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F02	26	14	12	46.2%	76.5	43.7	4.8	42.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F02	25.3	12.7	12.6	49.8%	99.5	96.9	0.4	2.5%	31	4	13	4	38.1%	5.0%
			UNKNOWN		W9/F02	28	18.2	9.8	35.0%					47	13	39	13	17.0%	0.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F02	29	19.5	9.5	32.8%	99.5	88.5	0.9	11.1%	49	14	41	13	16.3%	7.1%
	R9	RESIDENTIAL	UNKNOWN		W11/F02	29.7	20.7	9	30.3%	98.7	81.9	1.9	17.0%	51	16	46	16	9.8%	0.0%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	32.8	23.6	9.2	28.0%	95.9	57.5	5.9	40.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F03	32.6	22.6	10	30.7%	99.2	78.7	3.3	20.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F03	32.3	21.5	10.8	33.4%	99.4	89.6	2.0	9.8%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F03	32.1	20.8	11.3	35.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F03	31.6	19.5	12.1	38.3%	99.5	77.7	3.2	21.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F03	30.8	17.1	13.7	44.5%	98.3	62.2	4.9	36.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F03	30	14.9	15.1	50.3%	98.3	44.5	7.8	54.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F03	29.6	13.6	16	54.1%	99.5	97	0.4	2.5%	24	5	14	5	41.7%	0.0%
			UNKNOWN		W9/F03	31.5	19.4	12.1	38.4%					51	16	43	16	15.7%	0.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F03	32.1	20.7	11.4	35.5%	99.5	89.4	0.9	10.2%	54	17	45	16	16.7%	5.9%
	R9	RESIDENTIAL	UNKNOWN		W11/F03	32.5	22	10.5	32.3%	98.7	82.8	1.8	16.1%	53	16	46	16	13.2%	0.0%
F04	R1	RESIDENTIAL	UNKNOWN		W1/F04	34.5	25	9.5	27.5%	95.9	60.1	5.5	37.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F04	34.5	23.9	10.6	30.7%	99.2	80.2	3.1	19.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F04	34.5	22.7	11.8	34.2%	99.4	90.5	1.8	9.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F04	34.5	22	12.5	36.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F04	34.4	20.6	13.8	40.1%	99.5	78.3	3.1	21.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F04	34	18.2	15.8	46.5%	98.3	63	4.8	35.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F04	33.8	16	17.8	52.7%	98.3	45.7	7.6	53.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F04	33.6	14.7	18.9	56.2%	99.6	97.1	0.4	2.5%	23	5	14	5	31.7%	0.7%
			UNKNOWN		W9/F04	34.7	20.7	14	40.3%					57	18	44	17	22.8%	5.6%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
FOUNTAIN COURT (CONTINUED)																			
	R8	RESIDENTIAL	UNKNOWN		W10/F04	34.9	22	12.9	37.0%	99.5	90.7	0.8	8.8%	57	18	46	17	19.3%	5.6%
	R9	RESIDENTIAL	UNKNOWN		W11/F04	35.1	23.3	11.8	33.6%	98.7	84	1.7	14.9%	59	19	50	19	15.3%	0.0%
F05	R1	RESIDENTIAL	UNKNOWN		W1/F05	35.8	26.4	9.4	26.3%	95.9	62.7	5.1	34.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F05	35.8	25.3	10.5	29.3%	99.2	82	2.8	17.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F05	35.9	24.1	11.8	32.9%	99.4	91.1	1.7	8.3%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F05	35.9	23.2	12.7	35.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F05	35.9	21.8	14.1	39.3%	99.5	79.2	2.9	20.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F05	35.9	19.5	16.4	45.7%	98.3	64.3	4.6	34.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F05	35.9	17.2	18.7	52.1%	98.3	47	7.4	52.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F05	36	15.8	20.2	56.1%	99.6	97.4	0.3	2.1%	32	7	16	5	50.0%	28.6%
			UNKNOWN		W9/F05	36.6	21.9	14.7	40.2%					59	20	44	18	25.4%	10.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F05	36.6	23.3	13.3	36.3%	99.5	92.2	0.6	7.3%	61	20	47	18	23.0%	10.0%
	R9	RESIDENTIAL	UNKNOWN		W11/F05	36.6	24.6	12	32.8%	98.7	86.2	1.5	12.7%	60	19	50	19	16.7%	0.0%
F06	R1	RESIDENTIAL	UNKNOWN		W1/F06	36.7	27.7	9	24.5%	95.9	66.4	4.6	30.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F06	36.7	26.6	10.1	27.5%	99.2	84.8	2.3	14.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F06	36.7	25.3	11.4	31.1%	99.4	92.1	1.5	7.3%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F06	36.7	24.5	12.2	33.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F06	36.8	23	13.8	37.5%	99.5	80.3	2.8	19.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F06	36.8	20.6	16.2	44.0%	98.3	66.1	4.4	32.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F06	36.8	18.3	18.5	50.3%	98.3	48.9	7.2	50.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F06	36.8	17	19.8	53.8%	99.6	97.8	0.3	1.8%	32	7	17	5	46.9%	28.0%
			UNKNOWN		W9/F06	37.5	23.1	14.4	38.4%					59	21	45	19	23.7%	9.5%
	R8	RESIDENTIAL	UNKNOWN		W10/F06	37.4	24.5	12.9	34.5%	99.5	94.4	0.4	5.2%	59	21	46	19	22.0%	9.5%
	R9	RESIDENTIAL	UNKNOWN		W11/F06	37.4	25.8	11.6	31.0%	98.7	89	1.1	9.9%	61	21	51	21	16.4%	0.0%
F07	R1	RESIDENTIAL	UNKNOWN		W1/F07	35.3	27	8.3	23.5%	95.8	69.3	4.1	27.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F07	34.9	25.5	9.4	26.9%	99.1	86.6	2.0	12.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F07	34.5	23.8	10.7	31.0%	99.4	93.1	1.3	6.3%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F07	34.2	22.6	11.6	33.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F07	33.7	20.6	13.1	38.9%	99.5	80.7	2.7	18.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F07	33.2	17.8	15.4	46.4%	98.3	65.5	4.4	33.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F07	32.6	15	17.6	54.0%	98.2	48	7.3	51.1%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

FOUNTAIN COURT (CONTINUED)																			
	R7	RESIDENTIAL	UNKNOWN		W8/F07	32.3	13.2	19.1	59.1%	99.5	97.9	0.3	1.7%	24	7	9	5	62.5%	28.6%
			UNKNOWN		W9/F07	35	21.5	13.5	38.6%					53	20	39	18	26.4%	10.0%
	R8	RESIDENTIAL	UNKNOWN		W10/F07	35	22.9	12.1	34.6%	99.5	95.5	0.3	4.0%	53	20	40	18	24.5%	10.0%
	R9	RESIDENTIAL	UNKNOWN		W11/F07	35	24.2	10.8	30.9%	98.7	90.9	0.9	7.9%	54	21	44	21	18.5%	0.0%
F08	R1	RESIDENTIAL	UNKNOWN		W1/F08	37.8	30.4	7.4	19.6%	83.5	55.9	3.9	33.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F08	38	29.6	8.4	22.1%	96.4	77.6	2.8	19.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F08	38	28.3	9.7	25.5%	97.6	88.3	1.7	9.6%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F08	38	27.5	10.5	27.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	UNKNOWN		W5/F08	38.2	26.2	12	31.4%	97.6	77.7	2.7	20.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R5	RESIDENTIAL	UNKNOWN		W6/F08	38.1	24.1	14	36.7%	93.8	63.8	3.8	32.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	UNKNOWN		W7/F08	38.1	21.9	16.2	42.5%	93.7	39.1	7.3	58.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	UNKNOWN		W8/F08	38.2	20.6	17.6	46.1%	98	96.6	0.2	1.4%	61	6	17	4	35.2%	33.3%
			UNKNOWN		W9/F08	39.2	26.8	12.4	31.6%					62	21	49	19	21.0%	9.5%
	R8	RESIDENTIAL	UNKNOWN		W10/F08	39.2	28.2	11	28.1%	99.9	97.9	0.2	2.0%	62	21	49	19	21.0%	9.5%
	R9	RESIDENTIAL	UNKNOWN		W11/F08	39.2	29.4	9.8	25.0%	99.8	90.2	1.0	9.5%	62	21	54	21	12.9%	0.0%

89-110 COLLESHILL FLATS																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	8	2.1	5.9	73.8%	84.3	21.7	5.8	74.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W2/B01	4.9	1.3	3.6	73.5%	41	9.4	2.3	76.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	KITCHEN-RESI (1)		W5/B01	21.4	7.5	13.9	65.0%	98.9	58.7	2.0	40.6%	4	0	4	0	0.0%	0.0%
			KITCHEN-RESI (1)		W6/B01	5.8	2.9	2.9	50.0%					0	0	0	0	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/B01	10.1	2	8.1	80.2%	74.6	15.9	6.0	78.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LIVING ROOM		W8/B01	10.4	1.9	8.5	81.7%	77.3	16.1	6.2	79.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	KITCHEN-RESI (1)		W9/B01	5.3	1.4	3.9	73.6%	99.3	63.1	1.8	36.5%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W10/B01	23.2	8.7	14.5	62.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/B01	4.5	2.8	1.7	37.8%	29.9	28.8	0.1	3.7%	0	0	0	0	0.0%	0.0%
	R10	RESIDENTIAL	BEDROOM		W14/B01	9.2	3.4	5.8	63.0%	73.3	30.6	3.9	58.2%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	11.2	5.2	6	53.6%	83.1	34.6	4.5	58.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F01	5.5	4	1.5	27.3%	40.6	37.5	0.3	7.6%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F01	8.8	7	1.8	20.5%	99.4	62.1	1.6	37.5%	0	0	0	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F01	27.7	11.9	15.8	57.0%					4	0	4	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
89-110 COLLESHILL FLATS (CONTINUED)																			
	R6	RESIDENTIAL	BEDROOM		W7/F01	12.1	3.2	8.9	73.6%	81.7	16.5	6.5	79.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F01	12	3.3	8.7	72.5%	85	20.5	6.4	75.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F01	25.6	10.2	15.4	60.2%	99.5	60.8	1.7	38.9%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F01	16.9	6.1	10.8	63.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F01	10.7	4.1	6.6	61.7%	50.4	34.9	1.5	30.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	13	4.8	8.2	63.1%	92.6	23.1	6.5	75.0%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	12.4	6.4	6	48.4%	89.7	40.5	4.6	54.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F02	6.3	4.9	1.4	22.2%	42.1	40.1	0.2	4.7%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F02	10	8.3	1.7	17.0%	99.4	68.7	1.3	30.9%	1	0	1	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F02	29.8	13.8	16	53.7%					6	0	6	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F02	12.8	3.9	8.9	69.5%	85.4	20.9	6.4	75.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F02	12.8	4.1	8.7	68.0%	87.1	24.9	6.2	71.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F02	27.6	11.9	15.7	56.9%	99.5	71.8	1.2	27.8%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F02	19.1	7.6	11.5	60.2%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F02	12.6	5.1	7.5	59.5%	60	38	2.2	36.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	14.5	6.1	8.4	57.9%	95.1	29.5	6.1	69.0%	N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	14.1	8.4	5.7	40.4%	92.8	48.7	4.1	47.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F03	8	6.8	1.2	15.0%	47.9	47	0.1	1.7%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F03	12.1	10.6	1.5	12.4%	99.4	85.3	0.6	14.2%	1	0	1	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F03	31.9	16.1	15.8	49.5%					6	0	6	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F03	13.1	4.5	8.6	65.6%	87	27.2	6.0	68.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F03	13.1	4.7	8.4	64.1%	87.3	30.2	5.7	65.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F03	29.9	14	15.9	53.2%	99.5	90.7	0.4	8.9%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F03	21.9	10.4	11.5	52.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F03	15.1	7.2	7.9	52.3%	69	45.4	2.3	34.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	16.5	7.9	8.6	52.1%	95.7	38.3	5.4	60.0%	N/A	N/A	N/A	N/A	N/A	N/A
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	17.2	11.9	5.3	30.8%	95.8	62.1	3.2	35.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F04	11.9	10.8	1.1	9.2%	69.3	69.1	0.0	0.4%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F04	16.9	15.6	1.3	7.7%	99.4	99.4	0.0	0.0%	6	0	6	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F04	34	18.9	15.1	44.4%					6	0	6	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F04	8.6	0.7	7.9	91.9%	86.8	11.3	7.5	87.0%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

89-110 COLLESHILL FLATS (CONTINUED)																			
	R7	RESIDENTIAL	BEDROOM		W8/F04	8.8	1	7.8	88.6%	87.1	20	6.7	77.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F04	32.4	16.8	15.6	48.1%	99.6	98.9	0.0	0.7%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F04	25.9	15.7	10.2	39.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F04	18.8	12.2	6.6	35.1%	82.1	68.6	1.3	16.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	19.3	11.2	8.1	42.0%	96.8	52.5	4.1	45.8%	N/A	N/A	N/A	N/A	N/A	N/A
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	25.6	19.3	6.3	24.6%	98.9	94.6	0.3	4.3%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W2/F05	31.7	24.3	7.4	23.3%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W3/F05	29.5	16.6	12.9	43.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	32.3	21	11.3	35.0%	100	92.5	0.6	7.5%	0	0	0	0	0.0%	0.0%
			UNKNOWN-RESI		W5/F05	28.5	27.4	1.1	3.9%					39	2	39	2	0.0%	0.0%
			UNKNOWN-RESI		W6/F05	20.3	19.4	0.9	4.4%					10	0	10	0	0.0%	0.0%

176 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	19.4	13.3	6.1	31.4%	76.5	31.7	27.6	58.5%	32	8	19	3	40.6%	62.5%
			UNKNOWN		W2/B01	0	0	0	-					0	0	0	0	0.0%	0.0%
			UNKNOWN		W3/B01	17.3	11.7	5.6	32.4%					34	8	25	4	26.5%	50.0%
			UNKNOWN		W4/B01	14.6	10.4	4.2	28.8%					35	9	26	4	25.7%	55.6%
			UNKNOWN		W5/B01	8.5	8.5	0	0.0%					6	1	6	1	0.0%	0.0%
F00	R1	RESIDENTIAL	BEDROOM		W1/F00	22.3	16.6	5.7	25.6%	95.3	74.3	3.2	22.0%	39	9	29	4	25.6%	55.6%
	R2	RESIDENTIAL	LIVING ROOM		W2/F00	16.6	12.7	3.9	23.5%	88.4	71	3.3	19.7%	41	10	32	5	22.0%	50.0%
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	23.8	18.4	5.4	22.7%	93.1	70.2	3.6	24.6%	35	6	23	2	34.3%	66.7%
	R2	RESIDENTIAL	BEDROOM		W2/F01	26.1	21	5.1	19.5%	93.3	71.7	3.3	23.1%	47	11	40	7	14.9%	36.4%
	R3	RESIDENTIAL	LIVING ROOM		W3/F01	19.7	16.2	3.5	17.8%	77.6	61.7	3.0	20.5%	48	15	42	11	12.5%	26.7%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	28.2	23.4	4.8	17.0%	86.8	55.4	6.0	36.2%	46	8	37	4	19.6%	50.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	30.3	25.8	4.5	14.9%	89.5	68.7	3.2	23.2%	59	17	50	12	15.3%	29.4%
	R3	RESIDENTIAL	LKD		W3/F02	26.9	23.7	3.2	11.9%	70.5	45.7	7.2	35.3%	56	18	52	14	7.1%	22.2%

174 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	17.5	12.7	4.8	27.4%	58.8	18.6	7.0	68.4%	26	1	17	0	34.6%	100.0%
	R2	RESIDENTIAL	UNKNOWN		W2/B01	11.9	10.1	1.8	15.1%	55	15	6.2	72.7%	27	6	23	5	14.8%	16.7%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.4	16	7.4	31.6%	96.6	42.3	11.9	56.2%	47	14	28	6	40.4%	57.1%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

174 MOZART TERRACE (CONTINUED)																			
			UNKNOWN		W2/F00	23.4	16	7.4	31.6%					46	12	28	6	39.1%	50.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.6	18.9	6.7	26.2%	73.7	49.3	2.9	33.1%	48	14	33	7	31.3%	50.0%
	R3	RESIDENTIAL	UNKNOWN		W2/F01	25.6	19	6.6	25.8%	95.5	46.8	10.1	51.0%	51	15	34	7	33.3%	53.3%
			UNKNOWN		W3/F01	25.7	19.1	6.6	25.7%					51	13	35	7	31.4%	46.2%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28	22.4	5.6	20.0%	74.3	53.4	2.5	28.2%	56	16	42	9	25.0%	43.8%
	R3	RESIDENTIAL	UNKNOWN		W2/F02	28.1	22.6	5.5	19.6%	95	51.5	9.0	45.8%	53	16	44	9	17.0%	43.8%
			UNKNOWN		W3/F02	28.1	22.7	5.4	19.2%					53	15	44	9	17.0%	40.0%

172 MOZART TERRACE																			
B01	R1	RESIDENTIAL	DINING ROOM		W1/B01	18.2	13	5.2	28.6%	74.7	21.7	8.5	71.0%	30	1	17	0	43.3%	100.0%
			DINING ROOM		W2/B01	16	9.2	6.8	42.5%					29	6	13	2	55.2%	66.7%
	R2	RESIDENTIAL	LIVING ROOM		W3/B01	20.2	13.7	6.5	32.2%	83.5	22.7	12.7	72.8%	39	7	26	5	33.3%	28.6%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.7	16	7.7	32.5%	96.6	92.6	1.2	4.2%	45	11	23	4	48.9%	63.6%
			UNKNOWN		W2/F00	24	16.2	7.8	32.5%					46	12	26	6	43.5%	50.0%
			UNKNOWN		W5/F00	22.6	22.6	0	0.0%					8	0	0	0	0.0%	0.0%
			UNKNOWN		W6/F00	27.4	27.4	0	0.0%					8	0	8	0	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W3/F00	24.3	16.5	7.8	32.1%	93.1	32.7	10.0	64.9%	46	13	28	6	39.1%	53.8%
			BEDROOM		W4/F00	24.4	16.6	7.8	32.0%					46	12	28	6	39.1%	50.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.5	18.5	7	27.5%	97	37.1	7.7	61.7%	48	12	28	5	41.7%	58.3%
			UNKNOWN		W2/F01	25.7	18.7	7	27.2%					49	13	31	7	36.7%	46.2%
	R2	RESIDENTIAL	UNKNOWN		W3/F01	26	18.9	7.1	27.3%	85.4	34.1	4.7	60.1%	49	13	32	7	34.7%	46.2%
	R3	RESIDENTIAL	UNKNOWN		W4/F01	26.1	19	7.1	27.2%	92.7	33.1	9.9	64.3%	50	14	35	7	30.0%	50.0%
			UNKNOWN		W5/F01	26.2	19.1	7.1	27.1%					49	13	35	7	28.6%	46.2%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.5	21.6	5.9	21.5%	90.4	41.8	9.0	53.7%	52	15	37	7	28.8%	53.3%
			UNKNOWN		W2/F02	27.8	21.8	6	21.6%					52	15	40	10	23.1%	33.3%
	R2	RESIDENTIAL	UNKNOWN		W3/F02	28.1	22.1	6	21.4%	93.5	42	10.6	55.1%	54	15	43	10	20.4%	33.3%
			UNKNOWN		W4/F02	28.2	22.2	6	21.3%					53	15	42	10	20.8%	33.3%

170 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18	13.2	4.8	26.7%	98.9	35.3	7.9	64.3%	21	1	10	0	52.4%	100.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	21.8	16.1	5.7	26.1%	99.1	43	7.0	56.6%	27	4	16	0	40.7%	100.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

170 MOZART TERRACE (CONTINUED)																			
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	20.4	16	4.4	21.6%	98.5	58.2	7.3	40.9%	21	2	16	0	23.8%	100.0%
			UNKNOWN		W2/F01	24.6	19.7	4.9	19.9%					34	5	25	2	26.5%	60.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	23.5	20.1	3.4	14.5%	98.7	60.8	6.9	38.4%	25	3	22	1	12.0%	66.7%
			UNKNOWN		W2/F02	28.1	24.2	3.9	13.9%					44	8	38	4	13.6%	50.0%

168 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	16	12.6	3.4	21.3%	92.3	35.7	10.4	61.3%	16	0	9	0	43.8%	0.0%
			UNKNOWN		W2/B01	17.8	14.1	3.7	20.8%					31	4	23	3	25.8%	25.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	24.7	18.5	6.2	25.1%	95.4	38.7	9.7	59.5%	38	8	28	4	26.3%	50.0%
			UNKNOWN		W3/F00	24.8	18.8	6	24.2%					41	11	30	5	26.8%	54.5%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	26.7	21.4	5.3	19.9%	93.3	59.9	3.0	35.8%	45	9	36	4	20.0%	55.6%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.1	21.9	5.2	19.2%	98.7	60.4	6.2	38.8%	49	12	39	6	20.4%	50.0%
			UNKNOWN		W3/F01	27.2	22.2	5	18.4%					53	15	42	8	20.8%	46.7%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.5	25.3	4.2	14.2%	94.7	66.2	2.5	30.0%	55	15	48	10	12.7%	33.3%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	29.6	25.5	4.1	13.9%	98.4	67.2	5.1	31.7%	58	17	49	12	15.5%	29.4%
			UNKNOWN		W3/F02	29.6	25.6	4	13.5%					58	17	49	12	15.5%	29.4%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	31.7	28.1	3.6	11.4%	93.2	65.8	2.3	29.4%	59	18	56	15	5.1%	16.7%
	R2	RESIDENTIAL	UNKNOWN		W2/F03	31.7	28.2	3.5	11.0%	97.5	70.6	4.3	27.6%	60	19	56	15	6.7%	21.1%
			UNKNOWN		W3/F03	31.6	28.2	3.4	10.8%					62	20	56	15	9.7%	25.0%

166 MOZART TERRACE																			
B01	R1	RESIDENTIAL	LIVING ROOM		W1/B01	14.5	11.9	2.6	17.9%	67.2	27.6	10.5	58.9%	16	1	9	0	43.8%	100.0%
			LIVING ROOM		W2/B01	17.8	14.1	3.7	20.8%					33	4	23	2	30.3%	50.0%
			LIVING ROOM		W3/B01	16.3	12.8	3.5	21.5%					36	6	26	4	27.8%	33.3%
F00	R2	RESIDENTIAL	DINING ROOM		W2/F00	24.8	19.4	5.4	21.8%	87.7	44.6	9.6	49.2%	46	12	33	5	28.3%	58.3%
			DINING ROOM		W3/F00	24.7	19.5	5.2	21.1%					45	11	35	6	22.2%	45.5%
F01	R2	RESIDENTIAL	DRAWING ROOM		W1/F01	27.3	22.7	4.6	16.8%	98.4	67.1	8.8	31.7%	52	16	43	10	17.3%	37.5%
			DRAWING ROOM		W2/F01	27.1	22.8	4.3	15.9%					52	17	44	11	15.4%	35.3%
			DRAWING ROOM		W3/F01	27	22.9	4.1	15.2%					53	16	44	11	17.0%	31.3%
F02	R2	RESIDENTIAL	BEDROOM		W1/F02	29.7	26.2	3.5	11.8%	99.1	99.1	0.0	0.0%	58	17	52	14	10.3%	17.6%
			BEDROOM		W2/F02	29.6	26.3	3.3	11.1%					58	17	52	14	10.3%	17.6%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
166 MOZART TERRACE (CONTINUED)																			
			BEDROOM		W3/F02	29.5	26.3	3.2	10.8%					59	18	53	14	10.2%	22.2%
F03	R1	RESIDENTIAL	DRESSING ROOM		W1/F03	31.4	28.4	3	9.6%	89	87.9	0.1	1.2%	60	19	55	15	8.3%	21.1%
164 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	14.3	10.6	3.7	25.9%	64.9	32.7	8.0	49.7%	25	2	13	0	48.0%	100.0%
			UNKNOWN		W2/B01	10.5	10.5	0	0.0%					22	3	22	3	0.0%	0.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	24.6	19.8	4.8	19.5%	95.6	54.3	7.4	43.1%	48	13	35	8	27.1%	38.5%
			UNKNOWN		W3/F00	24.6	19.9	4.7	19.1%					46	12	35	8	23.9%	33.3%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	27	23	4	14.8%	91.1	77	1.0	15.5%	52	15	45	12	13.5%	20.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27	23.1	3.9	14.4%	99.2	79.1	3.4	20.3%	54	16	47	12	13.0%	25.0%
			UNKNOWN		W3/F01	27	23.2	3.8	14.1%					54	15	46	11	14.8%	26.7%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.4	26.4	3	10.2%	88.8	78.2	0.8	11.9%	57	16	54	14	5.3%	12.5%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	29.4	26.5	2.9	9.9%	99.2	79.8	3.3	19.5%	57	16	53	14	7.0%	12.5%
			UNKNOWN		W3/F02	29.4	26.6	2.8	9.5%					59	17	54	14	8.5%	17.6%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	29.8	27.2	2.6	8.7%	86.1	70.7	1.9	17.9%	53	17	48	13	9.4%	23.5%
	R2	RESIDENTIAL	UNKNOWN		W2/F03	29.7	27.2	2.5	8.4%	85.6	64.1	2.6	25.1%	54	18	49	13	9.3%	27.8%
162 MOZART TERRACE																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	17	15.1	1.9	11.2%	71.3	38.9	8.5	45.5%	29	2	21	0	27.6%	100.0%
			BEDROOM		W2/B01	14.9	13.4	1.5	10.1%					33	6	27	5	18.2%	16.7%
F00	R2	RESIDENTIAL	DINING ROOM		W2/F00	24.7	20	4.7	19.0%	94.4	55	8.2	41.8%	51	14	36	8	29.4%	42.9%
			DINING ROOM		W3/F00	24.7	20.1	4.6	18.6%					52	15	37	8	28.8%	46.7%
F01	R1	RESIDENTIAL	DRAWING ROOM		W1/F01	27.1	23.3	3.8	14.0%	99	83.6	4.1	15.6%	53	15	46	12	13.2%	20.0%
			DRAWING ROOM		W2/F01	27.1	23.4	3.7	13.7%					53	15	45	12	15.1%	20.0%
			DRAWING ROOM		W3/F01	27.3	23.5	3.8	13.9%					54	16	47	12	13.0%	25.0%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	29.5	26.8	2.7	9.2%	98.5	88.9	2.5	9.7%	60	17	55	14	8.3%	17.6%
			BEDROOM		W2/F02	29.6	26.9	2.7	9.1%					59	17	54	14	8.5%	17.6%
			BEDROOM		W3/F02	29.7	27	2.7	9.1%					59	17	54	14	8.5%	17.6%
102 EATON TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	4.7	4.7	0	0.0%	56.6	37.3	3.7	34.1%	1	0	1	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES	%	%		%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
102 EATON TERRACE (CONTINUED)																			
	R2	RESIDENTIAL	UNKNOWN		W2/B01	9	8.9	0.1	11%	56.5	56.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/B01	9	9	0	0.0%	57	57	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	14.3	11.8	2.5	17.5%	86.7	65	3.3	25.1%	25	4	20	1	20.0%	75.0%
	R3	RESIDENTIAL	UNKNOWN		W3/F00	14.4	13.2	1.2	8.3%	99.1	99	0.0	0.1%	38	13	32	8	15.8%	38.5%
			UNKNOWN		W4/F00	22.5	19.4	3.1	13.8%					50	14	42	10	16.0%	28.6%
			UNKNOWN		W5/F00	25	21.2	3.8	15.2%					51	15	42	10	17.6%	33.3%
			UNKNOWN		W6/F00	24.7	21.4	3.3	13.4%					48	13	40	8	16.7%	38.5%
			UNKNOWN		W7/F00	24.6	22.2	2.4	9.8%					39	10	31	5	20.5%	50.0%
			UNKNOWN		W8/F00	23.1	22.1	1	4.3%					34	9	19	4	20.5%	50.0%
			UNKNOWN		W9/F00	15.4	15.4	0	0.0%					10	0	10	0	0.0%	0.0%
			UNKNOWN		W10/F00	24.3	24.2	0.1	0.4%					10	0	10	0	0.0%	0.0%
	R5	RESIDENTIAL	UNKNOWN		W12/F00	23.1	23.1	0	0.0%	89.2	89.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	15.1	13.2	1.9	12.6%	91	68.2	4.4	25.1%	22	2	19	0	13.6%	100.0%
			UNKNOWN		W2/F01	16.6	13.7	2.9	17.5%					34	10	28	6	17.6%	40.0%
	R2	RESIDENTIAL	UNKNOWN		W3/F01	11.8	10.7	1.1	9.3%	69	68.7	0.0	0.4%	33	12	30	9	9.1%	25.0%
	R3	RESIDENTIAL	UNKNOWN		W4/F01	27.3	24.7	2.6	9.5%	99.2	97.9	0.2	1.3%	55	16	50	13	9.1%	18.8%
			UNKNOWN		W5/F01	27.2	27.1	0.1	0.4%					15	0	15	0	0.0%	0.0%
	R4	RESIDENTIAL	UNKNOWN		W6/F01	26.9	26.8	0.1	0.4%	97.7	97.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F01	26.2	26.1	0.1	0.4%					N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	17.8	16.5	1.3	7.3%	85.6	66.4	3.8	22.4%	26	3	23	1	11.5%	66.7%
			UNKNOWN		W2/F02	19.3	17.2	2.1	10.9%					38	10	34	6	10.5%	40.0%
	R2	RESIDENTIAL	UNKNOWN		W3/F02	20.8	20	0.8	3.8%	88.3	88.2	0.0	0.1%	44	14	41	11	6.8%	21.4%
	R3	RESIDENTIAL	UNKNOWN		W4/F02	29.6	27.7	1.9	6.4%	99.2	98.4	0.1	0.7%	59	18	57	16	3.4%	11.1%
			UNKNOWN		W5/F02	29.4	29.3	0.1	0.3%					15	0	15	0	0.0%	0.0%
	R4	RESIDENTIAL	UNKNOWN		W6/F02	29.1	29	0.1	0.3%	97.8	97.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F02	28.4	28.4	0	0.0%					N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	31.8	31	0.8	2.5%	91.3	90.8	0.0	0.6%	69	20	65	16	5.8%	20.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F03	32.1	30.4	1.7	5.3%	96.2	96.1	0.0	0.0%	65	21	62	18	4.6%	14.3%
			UNKNOWN		W3/F03	31.8	31.8	0	0.0%					20		20		0.0%	0.0%
	R3	RESIDENTIAL	UNKNOWN		W4/F03	31.4	31.4	0	0.0%	97	97	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F03	30.8	30.7	0.1	0.3%					N/A	N/A	N/A	N/A	N/A	N/A

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

180 MOZART TERRACE

B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	15.1	9.3	5.8	38.4%	67	25.1	2.8	62.6%	16	1	4	0	75.0%	100.0%
	R2	RESIDENTIAL	UNKNOWN		W2/B01	20.7	14	6.7	32.4%	95.7	31.2	10.3	67.4%	36	4	22	2	38.9%	50.0%
			UNKNOWN		W3/B01	19.2	13.2	6	31.2%					39	10	29	8	25.6%	20.0%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	24.7	17.5	7.2	29.1%	96	47.7	8.5	50.3%	48	12	32	9	33.3%	25.0%
			UNKNOWN		W2/F00	24.8	17.3	7.5	30.2%					47	12	32	9	31.9%	25.0%
F01	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.2	20.7	6.5	23.9%	96.3	66.2	5.3	31.3%	53	13	39	10	26.4%	23.1%
			UNKNOWN		W3/F01	27.3	20.5	6.8	24.9%					54	14	39	10	27.8%	28.6%
F02	R2	RESIDENTIAL	UNKNOWN		W2/F02	29.9	24.2	5.7	19.1%	97.2	75.9	3.8	21.9%	59	18	49	15	16.9%	16.7%
			UNKNOWN		W3/F02	30	24	6	20.0%					60	19	50	15	16.7%	21.1%

182 MOZART TERRACE

B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18.5	14.1	4.4	23.8%	95.5	32.8	10.1	65.7%	30	1	21	1	30.0%	0.0%
			UNKNOWN		W2/B01	18.2	14.3	3.9	21.4%					36	5	26	5	27.8%	0.0%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.9	18.5	5.4	22.6%	95.9	54.8	7.0	42.9%	44	11	34	9	22.7%	18.2%
			UNKNOWN		W2/F00	24	18.2	5.8	24.2%					43	10	32	8	25.6%	20.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	26.6	21.8	4.8	18.0%	96.5	89.7	1.2	7.1%	51	14	42	12	17.6%	14.3%
			UNKNOWN		W2/F01	26.8	21.5	5.3	19.8%					51	14	41	11	19.6%	21.4%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.6	25.4	4.2	14.2%	96.4	92.5	0.7	4.1%	58	17	51	15	12.1%	11.8%
			UNKNOWN		W2/F02	29.7	25.1	4.6	15.5%					59	18	50	15	15.3%	16.7%

184 MOZART TERRACE

B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18	14.4	3.6	20.0%	67.2	22.3	11.0	66.8%	34	3	25	2	26.5%	33.3%
			UNKNOWN		W2/B01	16	13.3	2.7	16.9%					34	7	27	6	20.6%	14.3%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	22.3	18.6	3.7	16.6%	81.3	50	7.3	38.5%	45	11	35	10	22.2%	9.1%
			UNKNOWN		W3/F00	22.9	18.6	4.3	18.8%					47	12	35	10	25.5%	16.7%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24.4	21.8	2.6	10.7%	81.1	63.2	2.0	22.1%	46	10	40	10	13.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	24.9	21.7	3.2	12.9%	84.1	65.7	4.0	21.9%	50	12	43	11	14.0%	8.3%
			UNKNOWN		W3/F01	25.5	21.6	3.9	15.3%					52	13	42	11	19.2%	15.4%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.1	24.7	2.4	8.9%	100	100	0.0	0.0%	52	12	47	12	9.6%	0.0%
			UNKNOWN		W3/F02 / HZ (2)	78.4	77.8	0.6	0.8%					37	4	34	4	8.1%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

184 MOZART TERRACE (CONTINUED)																			
	R2	RESIDENTIAL	UNKNOWN		W2/F02	27.6	24.6	3	10.9%	82.8	62.2	4.5	24.9%	54	15	48	14	11.1%	6.7%
			UNKNOWN		W4/F02	28	24.5	3.5	12.5%					56	16	49	14	12.5%	12.5%

186 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	15.6	14.3	1.3	8.3%	45	26.2	4.5	41.8%	25	1	23	1	8.0%	0.0%
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	20.4	18.8	1.6	7.8%	71.4	45.6	5.0	36.0%	34	8	33	8	2.9%	0.0%
			UNKNOWN		W2/F00	20.9	18.8	2.1	10.0%					38	9	33	9	13.2%	0.0%
F01	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.4	21.8	1.6	6.8%	80.6	63.3	2.9	21.4%	46	12	43	12	6.5%	0.0%
			UNKNOWN		W3/F01	23.6	21.7	1.9	8.1%					43	10	39	10	9.3%	0.0%
F02	R2	RESIDENTIAL	UNKNOWN		W2/F02	26.2	24.8	1.4	5.3%	75.6	56.7	3.2	25.0%	51	14	49	14	3.9%	0.0%
			UNKNOWN		W3/F02	26.5	24.6	1.9	7.2%					51	14	49	14	3.9%	0.0%

188 MOZART TERRACE																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	13.4	12.8	0.6	4.5%	34.3	33.2	0.2	3.0%	13	0	13	0	0.0%	0.0%
			UNKNOWN		W2/B01	11.6	11.6	0	0.0%					21	1	21	1	0.0%	0.0%
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	18.4	17.6	0.8	4.3%	61.5	51.5	2.0	16.4%	29	3	29	3	0.0%	0.0%
			UNKNOWN		W3/F00	19.3	18.3	1	5.2%					34	8	34	8	0.0%	0.0%
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	23.5	22.9	0.6	2.6%	62.1	62.1	0.0	0.0%	47	14	46	14	2.1%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.4	22.6	0.8	3.4%	71.8	64.6	1.3	10.0%	47	14	46	14	2.1%	0.0%
			UNKNOWN		W3/F01	23.2	22.2	1	4.3%					43	12	42	12	2.3%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	26.5	25.9	0.6	2.3%	59.5	59.5	0.0	0.0%	52	15	51	15	1.9%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	26.3	25.6	0.7	2.7%	68.4	62.2	1.1	9.1%	53	15	51	15	3.8%	0.0%
			UNKNOWN		W3/F02	26.1	25.2	0.9	3.4%					51	13	49	13	3.9%	0.0%

190 EBURY STREET																			
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24.4	24.1	0.3	1.2%	48.7	48.7	0.0	0.0%	45	14	45	14	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F01	24	23.5	0.5	2.1%	48.1	48.1	0.0	0.0%	46	14	46	14	0.0%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.2	26.8	0.4	1.5%	61.7	61.7	0.0	0.0%	51	16	51	16	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	26.8	26.4	0.4	1.5%	60.3	60.3	0.0	0.0%	51	15	51	15	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
192 EBURY STREET																			
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.5	25.3	0.2	0.8%	80.9	80.5	0.1	0.5%	44	15	44	15	0.0%	0.0%
			UNKNOWN		W2/F01	24.9	24.6	0.3	1.2%					44	14	44	14	0.0%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28.1	27.8	0.3	1.1%	95.5	95.4	0.0	0.1%	53	17	53	17	0.0%	0.0%
			UNKNOWN		W2/F02	27.6	27.3	0.3	1.1%					51	16	51	16	0.0%	0.0%
			UNKNOWN		W3/F02 / INC (2)	63	63	0	0.0%					53	15	53	15	0.0%	0.0%
194 EBURY STREET																			
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	25.9	25.7	0.2	0.8%	94.4	94.4	0.0	0.0%	36	12	36	12	0.0%	0.0%
			UNKNOWN		W2/F01	25.9	25.7	0.2	0.8%					42	13	42	13	0.0%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28.3	28.1	0.2	0.7%	95.4	95.4	0.0	0.0%	44	12	44	12	0.0%	0.0%
			UNKNOWN		W2/F02	28.4	28.2	0.2	0.7%					49	13	49	13	0.0%	0.0%
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	31.5	31.2	0.3	1.0%	85.8	85.8	0.0	0.0%	58	18	57	18	1.7%	0.0%
17A PIMLICO ROAD																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	18.1	12.9	5.2	28.7%	96.7	57.7	4.2	40.3%	N/A	N/A	N/A	N/A	N/A	N/A
F00	R1	RESIDENTIAL	KITCHEN		W1/F00	21.3	16	5.3	24.9%	81.1	58.9	3.6	27.3%	N/A	N/A	N/A	N/A	N/A	N/A
17 PIMLICO ROAD																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	13.8	11.8	2	14.5%	51.8	36.6	2.5	29.4%	N/A	N/A	N/A	N/A	N/A	N/A
F00	R2	RESIDENTIAL	UNKNOWN		W3/F00	17.8	15.2	2.6	14.6%	71.9	54.3	2.9	24.5%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24.3	19.5	4.8	19.8%	92.8	74.2	3.5	20.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.4	20	3.4	14.5%	80.9	68.8	1.3	15.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F01	22.6	20.2	2.4	10.6%	87	73.9	2.2	15.0%	7	0	7	0	0.0%	0.0%
			UNKNOWN		W4/F01	0	0	0	-					0	0	0	0	0.0%	0.0%
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.7	23.6	4.1	14.8%	77.4	67.3	1.9	13.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	27	23.9	3.1	11.5%	89.1	78	1.2	12.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	UNKNOWN		W3/F02	26.3	24.1	2.2	8.4%	80.4	72.3	1.3	10.0%	8	0	8	0	0.0%	0.0%
			UNKNOWN		W4/F02	0	0	0	-					0	0	0	0	0.0%	0.0%
15 PIMLICO ROAD																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	17.3	12.1	5.2	30.1%	91.8	31.9	8.9	65.2%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

15 PIMLICO ROAD (CONTINUED)																			
			UNKNOWN		W2/B01	19.5	13	6.5	33.3%					N/A	N/A	N/A	N/A	N/A	N/A
F00	R2	RESIDENTIAL	UNKNOWN		W2/F00	22.3	15.5	6.8	30.5%	96.9	51.3	6.8	47.1%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R2	RESIDENTIAL	UNKNOWN		W2/F01	25.4	19.1	6.3	24.8%	99.1	68.4	4.5	30.9%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	28.3	22.8	5.5	19.4%	74.4	57.7	2.5	22.4%	N/A	N/A	N/A	N/A	N/A	N/A

13 PIMLICO ROAD																			
B01	R1	RESIDENTIAL	UNKNOWN		W1/B01	18.5	9.6	8.9	48.1%	70.2	30.3	5.9	56.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/B01	18	11.4	6.6	36.7%	86.9	29.3	9.4	66.3%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W3/B01	19.3	11	8.3	43.0%					N/A	N/A	N/A	N/A	N/A	N/A
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	23.1	14.1	9	39.0%	97	82.5	2.2	14.9%	1	0	2	1	0.0%	0.0%
			UNKNOWN		W4/F00	11.5	11.4	0.1	0.9%					19	2	19	2	0.0%	0.0%
	R3	RESIDENTIAL	UNKNOWN		W3/F00	23.3	15	8.3	35.6%	94.7	49.1	7.5	48.2%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	26.5	17.7	8.8	33.2%	98.5	95.4	0.5	3.2%	4	0	4	0	0.0%	0.0%
			UNKNOWN		W4/F01	19.3	19.3	0	0.0%					38	7	38	7	0.0%	0.0%
	R3	RESIDENTIAL	UNKNOWN		W3/F01	26.1	18.2	7.9	30.3%	98.8	65.9	5.4	33.3%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	29.4	21.4	8	27.2%	99.4	98.5	0.1	0.9%	7	0	7	0	0.0%	0.0%
			UNKNOWN		W3/F02	28.9	28.8	0.1	0.3%					60	18	60	18	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN		W2/F02	29	22.1	6.9	23.8%	67	47.8	3.1	28.7%	N/A	N/A	N/A	N/A	N/A	N/A

2 RANELAGH GROVE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	12.9	11.3	1.6	12.4%	89.3	80.3	1.0	10.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	23.5	18.4	5.1	21.7%	98	88.1	1.7	10.1%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F01	24	18.7	5.3	22.1%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W3/F01	16.2	15	1.2	7.4%	88.3	86	0.3	2.6%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	27.6	22.7	4.9	17.8%	98.2	96.8	0.2	1.5%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F02	28.2	22.9	5.3	18.8%					N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	30.3	25.5	4.8	15.8%	72.3	43.4	3.6	40.0%	N/A	N/A	N/A	N/A	N/A	N/A

4 RANELAGH GROVE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	12.9	9.4	3.5	27.1%	59.8	56.3	0.5	5.8%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	15.7	12.3	3.4	21.7%	65.3	65.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
4 RANELAGH GROVE (CONTINUED)																			
	R2	RESIDENTIAL	UNKNOWN		W2/F01	16.6	13.7	2.9	17.5%	52.7	50.5	0.2	4.2%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	23.7	20	3.7	15.6%	95.7	95.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	22.9	19.8	3.1	13.5%	71.6	71.2	0.0	0.6%	N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	28	25.6	2.4	8.6%	69.7	65.2	0.5	6.3%	N/A	N/A	N/A	N/A	N/A	N/A
67-88 COLLESHILL FLATS																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	8.5	2.1	6.4	75.3%	77.3	16.9	5.5	78.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W2/B01	4.3	1.1	3.2	74.4%	27.2	6.8	1.5	75.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	KITCHEN-RESI (1)		W5/B01	24.3	11.4	12.9	53.1%	96.9	75.7	1.1	21.9%	4	0	4	0	0.0%	0.0%
			KITCHEN-RESI (1)		W6/B01	5.2	4.2	1	19.2%					0	0	0	0	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/B01	11.2	6.2	5	44.6%	82.1	53.8	2.9	34.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LIVING ROOM		W8/B01	9.9	3.4	6.5	65.7%	77	27.5	5.0	64.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	KITCHEN-RESI (1)		W9/B01	5.1	1.2	3.9	76.5%	97.2	86.4	0.5	11.1%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W10/B01	24.1	13	11.1	46.1%					N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/B01	3.3	3.1	0.2	6.1%	27	27	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R10	RESIDENTIAL	BEDROOM		W14/B01	10.1	6.7	3.4	33.7%	87.7	64.6	2.1	26.4%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	12.1	9	3.1	25.6%	91.4	72.7	1.8	20.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F01	4.6	4.4	0.2	4.3%	36.7	36.7	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F01	7.4	7.2	0.2	2.7%	98.9	98.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F01	27.9	17.8	10.1	36.2%					0	0	0	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F01	11.8	5	6.8	57.6%	83.8	32.7	5.1	61.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F01	12.9	8.2	4.7	36.4%	86.1	59.8	2.6	30.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F01	28.2	14.1	14.1	50.0%	99.1	76.4	1.0	22.9%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F01	8.6	3.5	5.1	59.3%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F01	5.2	2.1	3.1	59.6%	40.4	10.8	2.9	73.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	10.6	3.7	6.9	65.1%	89.3	21.5	6.3	75.9%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	13.1	10.4	2.7	20.6%	91.9	78.2	1.3	14.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F02	5.6	5.5	0.1	1.8%	41.4	41.4	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F02	8.9	8.7	0.2	2.2%	98.9	98.9	0.0	0.0%	0	0	0	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F02	30.2	20.4	9.8	32.5%					0	0	0	0	0.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F02	12.6	5.9	6.7	53.2%	86.3	39.7	4.6	53.9%	N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
67-88 COLLESHILL FLATS (CONTINUED)																			
	R7	RESIDENTIAL	BEDROOM		W8/F02	13.7	9.1	4.6	33.6%	86.9	65.6	2.1	24.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F02	30.3	16.2	14.1	46.5%	99.1	82.8	0.7	16.5%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F02	9.7	4.8	4.9	50.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F02	6.1	3.1	3	49.2%	42.2	15.5	2.6	63.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	11.8	5	6.8	57.6%	91.8	28.2	5.9	69.3%	N/A	N/A	N/A	N/A	N/A	N/A
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	14.7	12.3	2.4	16.3%	93	85.9	0.7	7.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F03	7.5	7.3	0.2	2.7%	47.3	47.3	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F03	11.3	11.2	0.1	0.9%	98.9	98.9	0.0	0.0%	1	0	1	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F03	32.4	23.2	9.2	28.4%					5	0	5	0	1.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F03	12.9	6.6	6.3	48.8%	87.2	51.2	3.6	41.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F03	13.8	9.6	4.2	30.4%	87.1	72.6	1.4	16.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F03	32.4	18.7	13.7	42.3%	99.1	89.8	0.4	9.4%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F03	11.8	7.2	4.6	39.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F03	7.7	5	2.7	35.1%	47.9	25.5	2.2	46.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	13.5	7	6.5	48.1%	93.1	38.6	5.1	58.6%	N/A	N/A	N/A	N/A	N/A	N/A
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	17.8	15.7	2.1	11.8%	95.8	95.3	0.1	0.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F04	11.5	11.3	0.2	1.7%	67.5	67.5	0.0	0.0%	0	0	0	0	0.0%	0.0%
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F04	16.4	16.2	0.2	1.2%	98.9	98.9	0.0	0.0%	4	0	4	0	0.0%	0.0%
			KITCHEN-RESI (1)		W4/F04	34.5	26.3	8.2	23.8%					5	0	5	0	1.0%	0.0%
	R6	RESIDENTIAL	BEDROOM		W7/F04	8.4	2.7	5.7	67.9%	87.1	54.5	3.3	37.5%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F04	9.2	5.5	3.7	40.2%	86.9	78.9	0.8	9.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F04	34.4	21.7	12.7	36.9%	99.1	98.9	0.0	0.3%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W12/F04	16.7	12.5	4.2	25.1%					N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	LIVING ROOM		W13/F04	11.6	8.9	2.7	23.3%	69.1	48.3	2.1	30.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	16.8	10.6	6.2	36.9%	96	56.3	3.7	41.4%	N/A	N/A	N/A	N/A	N/A	N/A
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	19.7	16.8	2.9	14.7%	98.9	98	0.1	0.9%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W2/F05	27	22.9	4.1	15.2%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W3/F05	30.2	20	10.2	33.8%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	31.4	26.6	4.8	15.3%	98.8	98.3	0.0	0.5%	13	1	12	1	1.0%	1.0%
			UNKNOWN-RESI		W5/F05	27.3	27.2	0.1	0.4%					34	1	34	1	0.0%	0.0%
			UNKNOWN-RESI		W6/F05	19.8	19.6	0.2	1.0%					10	0	10	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
45-66 COLLESHILL FLATS																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	10.3	5.9	4.4	42.7%	86.7	58.5	2.6	32.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	BEDROOM		W2/B01	3.6	1.9	1.7	47.2%	27.6	14.1	1.0	49.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R4	RESIDENTIAL	KITCHEN-RESI (1)		W5/B01	20.8	14.3	6.5	31.2%	99.4	99.2	0.0	0.2%	4	0	4	0	0.0%	0.0%
			KITCHEN-RESI (1)		W6/B01	3.2	3.2	0	0.0%					0	0	0	0	0.0%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/B01	8.8	6.9	1.9	21.6%	65.9	52	1.4	21.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	LIVING ROOM		W8/B01	10.2	7.1	3.1	30.4%	80.2	54.4	2.6	32.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	KITCHEN-RESI (1)		W9/B01	5.2	3.2	2	38.5%	98.9	98.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W10/B01	18.3	14.2	4.1	22.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R9	RESIDENTIAL	BEDROOM		W13/B01	10.3	14.4	-4.1	-39.8%	84.1	84.2	0.0	-0.1%	5	0	11	1	-120.0%	-
	R10	RESIDENTIAL	BEDROOM		W14/B01	8.8	10.1	-1.3	-14.8%	50.8	50.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	12	7.9	4.1	34.2%	91.5	71.6	1.9	21.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F01	4.7	3	1.7	36.2%	39.5	14.6	2.5	63.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F01	8.3	4.6	3.7	44.6%	99.3	99.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W4/F01	27.1	19.9	7.2	26.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W7/F01	11.2	9.5	1.7	15.2%	77.8	71.9	0.6	7.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F01	12.2	9.5	2.7	22.1%	83.9	68.6	1.5	18.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F01	23.6	19.8	3.8	16.1%	99.6	99.6	0.0	0.0%	5	0	5	0	0.0%	0.0%
			KITCHEN-RESI (1)		W12/F01	26.8	26.8	0	0.0%					29	6	29	6	0.0%	0.0%
	R11	RESIDENTIAL	LIVING ROOM		W13/F01	19.6	19.6	0	0.0%	71.9	71.9	0.0	0.0%	16	2	16	2	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W14/F01	14.1	14.1	0	0.0%	74.5	74.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	13	9.3	3.7	28.5%	91.6	80.8	1.0	11.8%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F02	5.6	4	1.6	28.6%	41.4	19.8	2.1	52.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F02	9.4	6.1	3.3	35.1%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W4/F02	29.6	22.9	6.7	22.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W7/F02	12.3	10.8	1.5	12.2%	86.5	84.4	0.2	2.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F02	13.1	10.6	2.5	19.1%	86.7	78.1	0.9	10.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F02	26.5	23	3.5	13.2%	99.6	99.6	0.0	0.0%	5	0	5	0	0.0%	0.0%
			KITCHEN-RESI (1)		W12/F02	28.5	28.5	0	0.0%					30	7	30	7	0.0%	0.0%
	R11	RESIDENTIAL	LIVING ROOM		W13/F02	20.9	20.9	0	0.0%	81.1	81.1	0.0	0.0%	16	2	16	2	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W14/F02	16.2	16.2	0	0.0%	93	92.9	0.0	0.0%		N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

45-66 COLLESHILL FLATS (CONTINUED)																			
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	14.6	11.1	3.5	24.0%	93.1	89.8	0.3	3.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F03	7.4	5.9	1.5	20.3%	47.5	30.6	1.7	35.7%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F03	11.6	8.5	3.1	26.7%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W4/F03	32.1	26	6.1	19.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W7/F03	12.9	11.6	1.3	10.1%	87.2	86.7	0.1	0.6%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F03	13.4	11.2	2.2	16.4%	86.9	83.3	0.4	4.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F03	29.7	26.6	3.1	10.4%	99.8	99.8	0.0	0.0%	5	0	5	0	0.0%	0.0%
			KITCHEN-RESI (1)		W12/F03	30.5	30.5	0	0.0%					31	7	31	7	0.0%	0.0%
	R11	RESIDENTIAL	LIVING ROOM		W13/F03	22.4	22.4	0	0.0%	86.2	86.2	0.0	0.0%	16	2	16	2	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W14/F03	18.7	18.7	0	0.0%	96.4	96.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	17.7	14.5	3.2	18.1%	96	96	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	LIVING ROOM		W2/F04	11.4	9.8	1.6	14.0%	67.6	59.5	0.8	12.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R3	RESIDENTIAL	KITCHEN-RESI (1)		W3/F04	16.3	13.6	2.7	16.6%	99.3	99.3	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			KITCHEN-RESI (1)		W4/F04	34.5	29.1	5.4	15.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R6	RESIDENTIAL	BEDROOM		W7/F04	8.8	7.7	1.1	12.5%	86.9	86.8	0.0	0.2%	N/A	N/A	N/A	N/A	N/A	N/A
	R7	RESIDENTIAL	BEDROOM		W8/F04	9	7	2	22.2%	86.7	86.5	0.0	0.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	KITCHEN-RESI (1)		W11/F04	32.8	30	2.8	8.5%	99.6	99.6	0.0	0.0%	7	0	6	0	14.3%	0.0%
			KITCHEN-RESI (1)		W12/F04	33	33	0	0.0%					36	8	36	8	0.0%	0.0%
	R11	RESIDENTIAL	LIVING ROOM		W13/F04	24.7	24.7	0	0.0%	87.3	87.3	0.0	0.0%	18	2	18	2	0.0%	0.0%
	R12	RESIDENTIAL	BEDROOM		W14/F04	21.8	21.8	0	0.0%	97.5	97.5	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	19.1	17.3	1.8	9.4%	98.9	98.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W2/F05	26.2	23.2	3	11.5%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN-RESI		W3/F05	30.5	26.1	4.4	14.4%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	27.4	26.2	1.2	4.4%	98	97.6	0.0	0.4%	11	1	10	1	1.0%	0.0%
			UNKNOWN-RESI		W5/F05	36.3	36.3	0	0.0%					45	10	45	10	0.0%	0.0%
			UNKNOWN-RESI		W6/F05	28.4	28.4	0	0.0%					23	3	23	3	0.0%	0.0%

23-44 COLLESHILL FLATS																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	8.2	8.2	0	0.0%	61.5	61.5	0.0	0.0%	10	1	10	1	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/B01	10.6	10.6	0	0.0%	79.4	79.4	0.0	0.0%	26	3	26	3	0.0%	0.0%
	R3	RESIDENTIAL	BEDROOM		W3/B01	10	10	0	0.0%	74.2	74.2	0.0	0.0%	27	4	27	4	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
23-44 COLLESHILL FLATS (CONTINUED)																			
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W6/B01	20.5	19.5	1	4.9%	88.1	88	0.0	0.1%	34	9	34	10	0.0%	-11.1%
			KITCHEN-RESI (1)		W7/B01	5.5	4.8	0.7	12.7%					7	0	6	0	14.3%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W8/B01	7.5	7.4	0.1	1.3%	46.9	46.8	0.0	0.1%	9	0	9	0	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W9/B01	7.7	7.7	0	0.0%	50.1	50.1	0.0	0.0%	14	3	14	3	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W10/B01	5.5	5.5	0	0.0%	89.1	89.1	0.0	0.0%	20	8	20	8	0.0%	0.0%
			KITCHEN-RESI (1)		W11/B01	21.2	19.4	1.8	8.5%					41	14	40	14	2.4%	0.0%
	R10	RESIDENTIAL	BEDROOM		W14/B01	4.2	3.6	0.6	14.3%	28.7	21.1	0.6	26.4%	N/A	N/A	N/A	N/A	N/A	N/A
	R11	RESIDENTIAL	BEDROOM		W15/B01	8.3	8.1	0.2	2.4%	63.5	63.4	0.0	0.1%	15	0	15	0	0.0%	0.0%
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	18.1	18.1	0	0.0%	85.5	85.5	0.0	0.0%	44	17	44	17	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F01	22.3	22.3	0	0.0%	91.7	91.7	0.0	0.0%	50	22	50	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F01	26.8	25.6	1.2	4.5%	99.5	99.5	0.0	0.0%	51	17	50	17	2.0%	0.0%
			KITCHEN-RESI (1)		W6/F01	6.7	5.9	0.8	11.9%					13	0	12	0	7.7%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F01	10.1	10	0.1	1.0%	71.7	71.7	0.0	0.0%	14	0	14	0	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F01	10.5	10.5	0	0.0%	70.9	70.9	0.0	0.0%	21	4	21	4	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F01	7	7	0	0.0%	99.3	99.3	0.0	0.0%	23	9	23	9	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F01	26.9	25.2	1.7	6.3%					53	16	52	16	1.9%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F01	5.3	4.7	0.6	11.3%	35.3	29.9	0.4	15.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	10.7	10.5	0.2	1.9%	87.6	87.6	0.0	0.0%	18	1	18	1	0.0%	0.0%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	19.5	19.5	0	0.0%	91.7	91.7	0.0	0.0%	46	17	46	17	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	23.3	23.3	0	0.0%	91.7	91.7	0.0	0.0%	50	22	50	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F02	29.6	28.4	1.2	4.1%	99.8	99.8	0.0	0.0%	59	18	58	18	1.7%	0.0%
			KITCHEN-RESI (1)		W6/F02	6.9	6.2	0.7	10.1%					15	0	14	0	9.7%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F02	11.3	11.2	0.1	0.9%	84.2	84.2	0.0	0.0%	17	0	17	0	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F02	11.5	11.5	0	0.0%	85.2	85.2	0.0	0.0%	22	4	22	4	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F02	7.4	7.4	0	0.0%	99.3	99.3	0.0	0.0%	23	9	23	9	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F02	29.6	28	1.6	5.4%					60	17	58	17	3.3%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F02	6.1	5.6	0.5	8.2%	38	35.6	0.2	6.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	12	11.9	0.1	0.8%	90.6	90.6	0.0	0.0%	19	1	19	1	0.0%	0.0%
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	20.9	20.9	0	0.0%	93.9	93.9	0.0	0.0%	45	17	45	17	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F03	24.3	24.3	0	0.0%	91.9	91.9	0.0	0.0%	50	22	50	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F03	31.9	30.7	1.2	3.8%	99.5	99.5	0.0	0.0%	59	17	57	17	3.4%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

23-44 COLLESHILL FLATS (CONTINUED)																			
			KITCHEN-RESI (1)		W6/F03	7.6	6.9	0.7	9.2%					16	0	15	0	6.3%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F03	12	11.9	0.1	0.8%	88.1	88.1	0.0	0.0%	19	1	19	1	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F03	12	12	0	0.0%	87.9	87.9	0.0	0.0%	24	6	24	6	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F03	7.7	7.7	0	0.0%	99.3	99.3	0.0	0.0%	25	10	25	10	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F03	32	30.4	1.6	5.0%					59	17	57	17	3.4%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F03	7.9	7.3	0.6	7.6%	46.1	45.1	0.1	2.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	13.9	13.7	0.2	1.4%	91.8	91.8	0.0	0.0%	20	2	20	2	0.0%	0.0%
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	22.7	22.7	0	0.0%	94.8	94.8	0.0	0.0%	48	18	48	18	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F04	25.2	25.2	0	0.0%	92.3	92.3	0.0	0.0%	49	22	49	22	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F04	34.2	33.1	1.1	3.2%	99.5	99.5	0.0	0.0%	62	19	61	19	1.6%	0.0%
			KITCHEN-RESI (1)		W6/F04	5.6	4.9	0.7	12.5%					17	1	17	1	0.0%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F04	5.9	5.8	0.1	1.7%	87.7	87.6	0.0	0.1%	8	2	8	2	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F04	5.8	5.8	0	0.0%	87.5	87.5	0.0	0.0%	8	6	8	6	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F04	5.7	5.7	0	0.0%	99.3	99.3	0.0	0.0%	19	11	19	11	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F04	34.1	32.6	1.5	4.4%					61	20	59	20	3.3%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F04	12.1	11.6	0.5	4.1%	73.3	73.2	0.0	0.1%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	17.2	17.1	0.1	0.6%	94.7	94.7	0.0	0.0%	23	2	23	2	0.0%	0.0%
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	30.4	30.4	0	0.0%	99.6	99.6	0.0	0.0%	60	24	60	24	0.0%	0.0%
			UNKNOWN-RESI		W2/F05	37.9	37.9	0	0.0%					70	26	70	26	0.0%	0.0%
			UNKNOWN-RESI		W3/F05	33.4	33	0.4	1.2%					66	22	66	22	0.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	30.9	29.4	1.5	4.9%	98.8	98.8	0.0	0.0%	41	9	41	9	0.0%	0.0%
			UNKNOWN-RESI		W5/F05	27.9	25.8	2.1	7.5%					19	3	18	3	9.3%	0.0%
			UNKNOWN-RESI		W6/F05	21.4	20.5	0.9	4.2%					20	2	18	2	10.0%	0.0%

01-22 COLLESHILL FLATS																			
B01	R1	RESIDENTIAL	BEDROOM		W1/B01	6.7	6.7	0	0.0%	50.1	50.1	0.0	0.0%	12	0	12	0	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/B01	3.5	3.5	0	0.0%	26.8	26.8	0.0	0.0%	13	2	13	2	0.0%	0.0%
	R4	RESIDENTIAL	KITCHEN-RESI (1)		W5/B01	22.4	18.6	3.8	17.0%	96.8	96.8	0.0	0.0%	48	11	46	11	4.2%	0.0%
			KITCHEN-RESI (1)		W6/B01	6	3.2	2.8	46.7%									83.3%	0.0%
	R5	RESIDENTIAL	LIVING ROOM		W7/B01	10.5	8.7	1.8	17.1%	72.9	67.8	0.5	7.1%	17	0	14	0	17.6%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W8/B01	8.4	8.4	0	0.0%	52.7	52.7	0.0	0.0%	18	0	18	0	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
01-22 COLLESHILL FLATS (CONTINUED)																			
	R7	RESIDENTIAL	KITCHEN-RESI (1)		W9/B01	4.3	4.3	0	0.0%	97.3	96.9	0.0	0.5%	18	3	18	3	0.0%	0.0%
			KITCHEN-RESI (1)		W10/B01	22.6	17.1	5.5	24.3%					46	8	38	8	17.4%	0.0%
	R9	RESIDENTIAL	BEDROOM		W13/B01	6.2	1.4	4.8	77.4%	47.5	7.1	2.9	85.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R10	RESIDENTIAL	BEDROOM		W14/B01	7.4	6.4	1	13.5%	80.5	76.2	0.4	5.4%	11	0	9	0	18.2%	0.0%
F01	R1	RESIDENTIAL	BEDROOM		W1/F01	9.4	9.4	0	0.0%	82.3	82.3	0.0	0.0%	18	3	18	3	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F01	4.9	4.9	0	0.0%	36.6	36.6	0.0	0.0%	18	5	18	5	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F01	27.3	23.6	3.7	13.6%	99.6	99.6	0.0	0.0%	53	13	50	13	5.7%	0.0%
			KITCHEN-RESI (1)		W6/F01	6.9	4.2	2.7	39.1%					15	3	11	3	35.4%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F01	12.4	10.8	1.6	12.9%	87.5	84.7	0.3	3.1%	19	1	17	1	10.5%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F01	11	11	0	0.0%	84.3	84.3	0.0	0.0%	21	3	21	3	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F01	5.7	5.7	0	0.0%	99.7	99.7	0.0	0.0%	20	6	20	6	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F01	27.4	21.8	5.6	20.4%					54	13	45	13	16.7%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F01	13.9	2	11.9	85.6%	79.3	4.7	5.7	94.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F01	16.3	8.4	7.9	48.5%	93.8	78.8	1.4	16.0%	19	1	11	1	42.1%	0.0%
F02	R1	RESIDENTIAL	BEDROOM		W1/F02	10.9	10.9	0	0.0%	90.7	90.7	0.0	0.0%	22	5	22	5	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F02	5.9	5.9	0	0.0%	38.4	38.4	0.0	0.0%	21	7	21	7	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F02	29.8	26.3	3.5	11.7%	99.6	99.6	0.0	0.0%	56	14	52	14	7.1%	0.0%
			KITCHEN-RESI (1)		W6/F02	7.3	4.8	2.5	34.2%									35.4%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F02	13.2	11.8	1.4	10.6%	87.9	87.2	0.1	0.8%	20	2	19	2	5.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F02	12.1	12.1	0	0.0%	87.4	87.4	0.0	0.0%	23	5	23	5	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F02	6.4	6.4	0	0.0%	99.7	99.7	0.0	0.0%	22	8	22	8	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F02	29.9	24.3	5.6	18.7%					58	16	49	16	15.5%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F02	15.8	2.8	13	82.3%	91.6	8.9	6.3	90.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F02	17.7	9.5	8.2	46.3%	94	81.1	1.2	13.8%	20	2	14	2	30.0%	0.0%
F03	R1	RESIDENTIAL	BEDROOM		W1/F03	12.9	12.9	0	0.0%	91.6	91.6	0.0	0.0%	23	5	23	5	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F03	7.7	7.7	0	0.0%	46.4	46.4	0.0	0.0%	24	8	24	8	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F03	32.3	29	3.3	10.2%	99.6	99.6	0.0	0.0%	60	18	56	18	6.7%	0.0%
			KITCHEN-RESI (1)		W6/F03	7.7	5.4	2.3	29.9%					15	3	11	3	35.5%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F03	13.5	12.1	1.4	10.4%	88.1	88	0.0	0.2%	20	2	20	2	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F03	12.7	12.7	0	0.0%	87.6	87.6	0.0	0.0%	25	7	25	7	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F03	7.1	7.1	0	0.0%	99.7	99.7	0.0	0.0%	25	10	25	10	0.0%	0.0%

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

FLOOR	ROOM	PROPERTY TYPE	ROOM USE	ROOM NOTES	WINDOW	VSC (WINDOW)				NSL				APSH (WINDOW)					
						EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
						%	%	%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER

01-22 COLLESHILL FLATS (CONTINUED)																			
			KITCHEN-RESI (1)		W10/F03	32.3	26.9	5.4	16.7%					60	18	52	18	13.3%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F03	17.9	3.9	14	78.2%	92.2	16.7	5.8	81.9%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F03	19.3	10.9	8.4	43.5%	94.3	83.5	1.0	11.5%	21	3	15	3	28.6%	0.0%
F04	R1	RESIDENTIAL	BEDROOM		W1/F04	16.5	16.5	0	0.0%	94.1	94.1	0.0	0.0%	32	7	32	7	0.0%	0.0%
	R2	RESIDENTIAL	BEDROOM		W2/F04	11.5	11.5	0	0.0%	73.1	73.1	0.0	0.0%	33	11	33	11	0.0%	0.0%
	R5	RESIDENTIAL	KITCHEN-RESI (1)		W5/F04	34.3	31.3	3	8.7%	99.6	99.6	0.0	0.0%	62	21	58	21	6.5%	0.0%
			KITCHEN-RESI (1)		W6/F04	5.7	3.7	2	35.1%					15	5	14	5	22.2%	0.0%
	R6	RESIDENTIAL	LIVING ROOM		W7/F04	7	5.8	1.2	17.1%	87.7	84.4	0.3	3.8%	10	3	10	3	0.0%	0.0%
	R7	RESIDENTIAL	LIVING ROOM		W8/F04	6.5	6.5	0	0.0%	87.1	87.1	0.0	0.0%	11	8	11	8	0.0%	0.0%
	R8	RESIDENTIAL	KITCHEN-RESI (1)		W9/F04	5.3	5.3	0	0.0%	99.7	99.7	0.0	0.0%	19	11	19	11	0.0%	0.0%
			KITCHEN-RESI (1)		W10/F04	34.2	29.1	5.1	14.9%					61	20	56	20	8.2%	0.0%
	R11	RESIDENTIAL	BEDROOM		W13/F04	20.9	6.4	14.5	69.4%	92.5	31.2	4.7	66.3%	N/A	N/A	N/A	N/A	N/A	N/A
	R12	RESIDENTIAL	BEDROOM		W14/F04	21.6	13.3	8.3	38.4%	95.2	89.3	0.6	6.2%	26	3	17	3	34.6%	0.0%
F05	R1	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W1/F05	21.3	21.4	-0.1	-0.5%	99.8	99.8	0.0	0.0%	48	17	48	17	0.0%	0.0%
			UNKNOWN-RESI		W2/F05	29.1	29.1	0	0.0%					60	20	60	20	0.0%	0.0%
			UNKNOWN-RESI		W3/F05	33.2	32.1	1.1	3.3%					67	23	63	23	6.0%	0.0%
	R2	RESIDENTIAL	UNKNOWN-RESI	ASSUMED	W4/F05	30.6	24.8	5.8	19.0%	99.8	98.3	0.1	1.5%	42	10	37	10	11.9%	0.0%
			UNKNOWN-RESI		W5/F05	34.3	14.4	19.9	58.0%					21	2	15	2	28.6%	0.0%
			UNKNOWN-RESI		W6/F05	27.2	11.7	15.5	57.0%					11	4	14	4	13.3%	0.0%

8 RANELAGH GROVE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	8.9	8.3	0.6	6.7%	43.4	43.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	19.2	18.6	0.6	3.1%	61.9	61.9	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	14.3	13.7	0.6	4.2%	83.1	83.1	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	27.7	26.7	1	3.6%	98.7	98.7	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	23.9	22	1.9	7.9%	99.8	99.8	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F02 / INC (2)	83.2	82.2	1	1.2%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W3/F02 / INC (2)	84.4	83	1.4	1.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W4/F02	26.2	25.9	0.3	1.1%	98	98	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F02	34.5	32.1	2.4	7.0%					N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL	WINTER
6 RANELAGH GROVE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	9.9	9.9	0	0.0%	43	43	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	15.6	13.4	2.2	14.1%	40.4	40.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	15.2	15.2	0	0.0%	80.6	80.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F01	23.1	20.9	2.2	9.5%	88.4	88.4	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	24.7	24.7	0	0.0%	98.6	98.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F02	28.2	26.7	1.5	5.3%	72.6	72.3	0.0	0.5%	N/A	N/A	N/A	N/A	N/A	N/A
1 EBURY BRIDGE																			
F00	R1	RESIDENTIAL	UNKNOWN		W1/F00	24.4	22	2.4	9.8%	92	92	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W2/F00	24	21.7	2.3	9.6%	92.7	92.6	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W3/F00	23.6	21.4	2.2	9.3%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F00	23.7	21.8	1.9	8.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W5/F00	22.4	20.7	1.7	7.6%	78.8	77.7	0.7	1.4%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W6/F00	21.8	20.4	1.4	6.4%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F00	21.1	20	1.1	5.2%					N/A	N/A	N/A	N/A	N/A	N/A
F01	R1	RESIDENTIAL	UNKNOWN		W1/F01	24	23.8	0.2	0.8%	95.2	95.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F01	27	24.6	2.4	8.9%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W3/F01	26.4	24.1	2.3	8.7%	97.9	86.7	4.3	11.4%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F01	26.2	24.1	2.1	8.0%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F01	25.4	23.5	1.9	7.5%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W6/F01	25.1	23.5	1.6	6.4%	74.9	64.5	6.8	14.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F01	24.4	23	1.4	5.7%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W8/F01	24.1	23	1.1	4.6%					N/A	N/A	N/A	N/A	N/A	N/A
F02	R1	RESIDENTIAL	UNKNOWN		W1/F02	25.2	24.9	0.3	1.2%	95.2	95.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F02	28.3	26	2.3	8.1%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W3/F02	28.1	25.9	2.2	7.8%	97.4	67.5	11.4	30.6%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F02	27.7	25.7	2	7.2%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F02	27.2	25.4	1.8	6.6%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W6/F02	26.7	25.2	1.5	5.6%	69.4	50.1	12.6	27.8%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F02	26.3	25	1.3	4.9%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W8/F02	25.9	24.8	1.1	4.2%					N/A	N/A	N/A	N/A	N/A	N/A

(1) KITCHEN SMALLER THAN 13m2

(2) INC\HZ = SKY COMPONENT (INCLINED\HORIZONTAL WINDOWS)

(3) SINGLE ASPECT ROOM DEEPER THAN 5m

						VSC (WINDOW)				NSL				APSH (WINDOW)					
FLOOR	ROOM	PROPERTY	ROOM	ROOM	WINDOW	EX.	PR.	LOSS	LOSS	EX.	PR.	LOSS	LOSS	EX.		PR.		LOSS %	
		TYPE	USE	NOTES		%	%		%	%	%	%	SQM	%	ANNUAL	WINTER	ANNUAL	WINTER	ANNUAL
1 EBURY BRIDGE (CONTINUED)																			
F03	R1	RESIDENTIAL	UNKNOWN		W1/F03	24.6	24.4	0.2	0.8%	95.2	95.2	0.0	0.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W2/F03	27.6	25.4	2.2	8.0%					N/A	N/A	N/A	N/A	N/A	N/A
	R2	RESIDENTIAL	UNKNOWN		W3/F03	27.8	25.7	2.1	7.6%	97.4	88.6	3.3	9.0%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W4/F03	27.3	25.4	1.9	7.0%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W5/F03	26.8	25	1.8	6.7%					N/A	N/A	N/A	N/A	N/A	N/A
	R3 (3)	RESIDENTIAL	UNKNOWN		W6/F03	26.4	24.9	1.5	5.7%	78.2	69.2	5.9	11.5%	N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W7/F03	26	24.8	1.2	4.6%					N/A	N/A	N/A	N/A	N/A	N/A
			UNKNOWN		W8/F03	25.6	24.6	1	3.9%					N/A	N/A	N/A	N/A	N/A	N/A

ADDRESS

.

THE WHITEHOUSE
BELVEDERE ROAD
LONDON SE1 8GA

.

CONTACT

.

TEL 020 7202 1400
FAX 020 7202 1401
MAIL@GIA.UK.COM

.

WWW.GIA.UK.COM